



## **Fire detection and alarm systems**

### **Part 10: Point-type flame detectors**

STANDARDS  
Australia



AS ISO 7240.10:2018

This Australian Standard® was prepared by FP-002, Fire Detection, Warning, Control and Intercom Systems. It was approved on behalf of the Council of Standards Australia on 30 November 2018.

This Standard was published on 20 December 2018.

The following are represented on Committee FP-002:

Association of Hydraulic Services Consultants Australia  
Australasian Fire and Emergency Service Authorities Council  
Australian Chamber of Commerce and Industry  
Australian Industry Group  
Australian Institute of Building Surveyors  
CSIRO  
Deafness Forum of Australia  
Department of Health and Human Services (VIC)  
Engineers Australia  
Fire Protection Association Australia  
National Electrical and Communications Association  
National Fire Industry Association  
Property Council of Australia  
Society of Fire Safety

This Standard was issued in draft form for comment as DR AS ISO 7240.10:2018.

#### **Keeping Standards up-to-date**

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

[www.standards.org.au](http://www.standards.org.au)

[www.saiglobal.com](http://www.saiglobal.com) (sales and distribution)

ISBN 978 1 76072 309 5



## Fire detection and alarm systems

### Part 10: Point-type flame detectors

First published as AS 7240.10—2007.  
This edition AS ISO 7240.10:2018.

#### **COPYRIGHT**

© ISO 2018 — All rights reserved  
© Standards Australia Limited 2018

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Published by SAI Global Pty Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia.

## Preface

This Standard was prepared by the Standards Australia Committee FP-002, Fire Detection, Warning, Control and Intercom Systems, to supersede AS 7240.10—2007, *Fire detection and alarm systems, Part 10: Point-type flame detectors*.

The objective of this Standard is to specify requirements, test methods and performance criteria for point-type, resettable flame detectors that operate using radiation from a flame for use in fire detection systems installed in buildings.

This Standard is not applicable to flame detectors with special characteristics, developed for specific risks. It can be used as guidance in assessing other types of flame detectors not included in this Standard.

The performance of flame detectors is assessed from results obtained in specific tests. This Standard is not intended to place any other restrictions on the design and construction of such flame detectors.

This Standard is identical with, and has been reproduced from, ISO 7240-10:2012, *Fire detection and alarm systems — Part 10: Point-type flame detectors*.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of ISO 7240” should read “this Australian Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian Standards that are identical adoptions of international standards or normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

# Contents

Preface .....	ii
Foreword .....	vi
Introduction .....	viii
<b>1 Scope .....</b>	<b>1</b>
<b>2 Normative references .....</b>	<b>1</b>
<b>3 Terms and definitions .....</b>	<b>1</b>
<b>4 Abbreviated terms .....</b>	<b>2</b>
<b>5 General requirements .....</b>	<b>3</b>
5.1 Compliance .....	3
5.2 Classification .....	3
5.3 Individual alarm indication .....	3
5.4 Connection of ancillary devices .....	3
5.5 Monitoring of detachable detectors .....	3
5.6 Manufacturer adjustments .....	3
5.7 On-site sensitivity adjustment .....	4
5.8 Ingress protection (IP) — Optional function .....	4
5.9 Marking .....	4
5.10 Data .....	5
5.11 Requirements for software-controlled detectors .....	5
5.11.1 General .....	5
5.11.2 Software documentation .....	5
5.11.3 Software design .....	6
5.11.4 Storage of programs and data .....	6
<b>6 Tests .....</b>	<b>6</b>
6.1 General .....	6
6.1.1 Atmospheric conditions for tests .....	6
6.1.2 Operating conditions for tests .....	6
6.1.3 Mounting arrangements .....	7
6.1.4 Tolerances .....	7
6.1.5 Determination of response point .....	7
6.1.6 Test procedure .....	8
6.1.7 Reduction of functional tests .....	8
6.1.8 Provision for tests .....	8
6.1.9 Test schedule .....	9
6.1.10 Test report .....	9
6.2 Reproducibility .....	9
6.2.1 Object of test .....	9
6.2.2 Test procedure .....	10
6.2.3 Requirements .....	10
6.3 Repeatability .....	10
6.3.1 Object of test .....	10
6.3.2 Test procedure .....	10
6.3.3 Requirements .....	10
6.4 Directional dependence .....	10
6.4.1 Object of test .....	10
6.4.2 Test procedure .....	10
6.4.3 Requirements .....	11
6.5 Fire sensitivity .....	12
6.5.1 Object of test .....	12
6.5.2 Test procedure .....	12
6.5.3 Classification .....	13
6.5.4 Requirements .....	14

6.6	Dazzling (operational)	15
6.6.1	Object of test	15
6.6.2	Test procedure and apparatus	15
6.6.3	Requirements	15
6.7	Dry heat (operational)	16
6.7.1	Object of test	16
6.7.2	Test procedure and apparatus	16
6.7.3	Requirements	16
6.8	Cold (operational)	17
6.8.1	Object of test	17
6.8.2	Test procedure	17
6.8.3	Requirements	17
6.9	Damp heat, cyclic (operational)	18
6.9.1	Object of test	18
6.9.2	Test procedure	18
6.9.3	Requirements	18
6.10	Damp heat, steady state (endurance)	19
6.10.1	Object of test	19
6.10.2	Test procedure	19
6.10.3	Requirements	19
6.11	Sulfur dioxide (SO <sub>2</sub> ) corrosion (endurance)	19
6.11.1	Object of test	19
6.11.2	Test procedure	20
6.11.3	Requirements	20
6.12	Shock (operational)	20
6.12.1	Object of test	20
6.12.2	Test procedure and apparatus	20
6.12.3	Requirements	21
6.13	Impact (operational)	21
6.13.1	Object of test	21
6.13.2	Test procedure	21
6.13.3	Requirements	22
6.14	Vibration, sinusoidal (operational)	22
6.14.1	Object of test	22
6.14.2	Test procedure	22
6.14.3	Requirements	23
6.15	Vibration, sinusoidal (endurance)	23
6.15.1	Object of test	23
6.15.2	Test procedure	23
6.15.3	Requirements	24
6.16	Variation of sample parameters (operational)	24
6.16.1	Object of test	24
6.16.2	Test procedure	24
6.16.3	Requirements	24
6.17	EMC immunity tests (operational)	25
6.18	Flame detector — Optional function	25
6.18.1	Object of test	25
6.18.2	Enclosure of the flame detector	25
6.18.3	Test procedure	25
6.18.4	Requirements	26
	Test report	27
<b>Annex A</b>	(normative) <b>Apparatus for response point determination</b>	<b>28</b>
<b>Annex B</b>	(normative) <b>Liquid (heptane) fire (TF5)</b>	<b>31</b>
<b>Annex C</b>	(normative) <b>Liquid (methylated spirit) fire (TF6)</b>	<b>32</b>
<b>Annex D</b>	(normative) <b>Apparatus for dazzling test</b>	<b>33</b>

<b>Annex E</b>	(normative) <b>Apparatus for impact test</b> .....	<b>34</b>
<b>Annex F</b>	(informative) <b>Example of methane burner</b> .....	<b>36</b>

Currently in preview, click buy full version

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 7240-10 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

This second edition cancels and replaces the first edition (ISO 7240-10:2007), which has been technically revised.

ISO 7240 consists of the following parts, under the general title *Fire detection and alarm systems*:

- *Part 1: General and definitions*
- *Part 2: Control and indicating equipment*
- *Part 3: Audible alarm devices*
- *Part 4: Power supply equipment*
- *Part 5: Point-type heat detectors*
- *Part 6: Carbon monoxide fire detectors using electro-chemical cells*
- *Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization*
- *Part 8: Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor*
- *Part 9: Test fires for fire detectors [Technical Specification]*
- *Part 10: Point-type flame detectors*
- *Part 11: Manual call points*
- *Part 12: Line-type smoke detectors using a transmitted optical beam*
- *Part 13: Compatibility assessment of system components*
- *Part 14: Guidelines for drafting codes of practice for design, installation and use of fire detection and fire alarm systems in and around buildings [Technical Report]*
- *Part 15: Point type fire detectors using scattered light, transmitted light or ionization sensors in combination with a heat sensor*
- *Part 16: Sound system control and indicating equipment*
- *Part 17: Short-circuit isolators*

- *Part 18: Input/output devices*
- *Part 19: Design, installation, commissioning and service of sound systems for emergency purposes*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Routing equipment*
- *Part 22: Smoke-detection equipment for ducts*
- *Part 23: Visual alarm devices*
- *Part 24: Sound-system loudspeakers*
- *Part 25: Components using radio transmission paths*
- *Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*
- *Part 28: Fire protection control equipment*

Currently in preview, click buy full version.

## Introduction

A fire detection and fire alarm system is required to function satisfactorily, not only in the event of a fire, but also during and after exposure to conditions likely to be met in practice, such as corrosion, vibration, direct impact, indirect shock and electromagnetic interference. Some tests specified in this part of ISO 7240 are intended to assess the performance of the fire detectors under such conditions.

Currently in preview, click buy full version

# Australian Standard®

## Fire detection and alarm systems

### Part 10: Point-type flame detectors

#### 1 Scope

This part of ISO 7240 specifies requirements, test methods and performance criteria for point-type, resettable flame detectors that operate using radiation from a flame for use in fire detection systems installed in buildings.

This part of ISO 7240 is not applicable to flame detectors with special characteristics, developed for specific risks. It can be used as guidance in assessing other types of flame detectors not included in this part of ISO 7240.

The performance of flame detectors is assessed from results obtained in specific tests. This part of ISO 7240 is not intended to place any other restrictions on the design and construction of such flame detectors.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 209, *Aluminium and aluminium alloys — Chemical composition*

ISO 7240-1, *Fire detection and alarm systems — Part 1: General and definitions*

IEC 60064, *Tungsten filament lamps for domestic and similar general lighting purposes — Performance requirements*

IEC 60068-1, *Environmental testing — Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing — Part 2-1: Tests — Test A: Cold*

IEC 60068-2-2, *Environmental testing — Part 2-2: Tests — Test B: Dry heat*

IEC 60068-2-6, *Environmental testing — Part 2-6: Tests — Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27, *Environmental testing — Part 2-27: Tests — Test Ea and guidance: Shock*

IEC 60068-2-30, *Environmental testing — Part 2-30: Tests — Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-42, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections*

IEC 60068-2-78, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

EN 50130-4, *Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

#### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 7240-1 and the following apply.