



Fire detection and alarm systems

Part 8: Point-type fire detectors using a carbon monoxide sensor in combination with a heat sensor

STANDARDS
Australia



AS ISO 7240.8:2018

This Australian Standard® was prepared by FP-002, Fire Detection, Warning, Control and Intercom Systems. It was approved on behalf of the Council of Standards Australia on 30 November 2018.

This Standard was published on 20 December 2018.

The following are represented on Committee FP-002:

Association of Hydraulic Services Consultants Australia
Australasian Fire and Emergency Service Authorities Council
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Institute of Building Surveyors
CSIRO
Deafness Forum of Australia
Department of Health and Human Services (VIC)
Engineers Australia
Fire Protection Association Australia
National Electrical and Communications Association
National Fire Industry Association
Property Council of Australia
Society of Fire Safety

This Standard was issued in draft form for comment as DR AS ISO 7240.8:2018.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.saiglobal.com (sales and distribution)

ISBN 978 1 76072 310 1



Fire detection and alarm systems

Part 8: Point-type fire detectors using a carbon monoxide sensor in combination with a heat sensor

First published as AS 7240.8—2007.
This edition AS ISO 7240.8:2018.

COPYRIGHT

© ISO 2018 — All rights reserved
© Standards Australia Limited 2018

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Published by SAI Global Pty Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia.

Preface

This Standard was prepared by the Standards Australia Committee FP-002, Fire Detection, Warning, Control and Intercom Systems, to supersede AS 7240.8—2007, *Fire detection and alarm systems, Part 8: Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor*.

The objective of this Standard is to specify requirements, test methods, and performance criteria for point-type multi-sensor fire detectors that incorporate at least one carbon monoxide (CO) sensor in combination with one or more heat sensors, for use in fire detection and alarm systems installed in buildings (refer to AS ISO 7240.1).

For the testing of other types of CO multi-sensor fire detectors, or CO and heat multi-sensor fire detectors working on different principles, this Standard is only to be used for guidance. CO and heat multi-sensor fire detectors with special characteristics and developed for specific risks are not covered by this Standard.

This Standard is identical with, and has been reproduced from, ISO 7240-8:2014, *Fire detection and alarm systems — Part 8: Point-type fire detectors using a carbon monoxide sensor in combination with a heat sensor*.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of ISO 7240” should read “this Australian Standard”.
- (b) A full point substitutes for a comma when referring to a decimal number.

Australian Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

Contents

Preface	ii
Foreword	vi
Introduction	viii
1 Scope	1
2 Normative references	1
3 Terms and definitions and abbreviated terms	1
3.1 Terms and definitions	1
3.2 Abbreviated terms	2
4 Requirements	2
4.1 Compliance	2
4.2 Individual alarm indication	2
4.3 Connection of ancillary devices	2
4.4 Monitoring of detachable detectors	2
4.5 Manufacturer's adjustments	3
4.6 On-site adjustment of response behaviour	3
4.7 Rate-sensitive response behaviour	3
4.8 Requirements for software-controlled detectors	3
4.8.1 General	3
4.8.2 Software design	3
4.8.3 The storage of programs and data	4
5 Tests	4
5.1 General	4
5.1.1 Atmospheric conditions for tests	4
5.1.2 Mounting arrangements	4
5.1.3 Operating conditions for tests	4
5.1.4 Tolerances	5
5.1.5 Measurement of CO response value	5
5.1.6 Measurement of heat sensor response value	5
5.1.7 Provision for tests	6
5.1.8 Test schedule	7
5.1.9 Test report	7
5.2 Repeatability of CO response	7
5.2.1 Object of the test	7
5.2.2 Test procedure	7
5.2.3 Requirements	7
5.3 Directional dependence of CO response	8
5.3.1 Object of the test	8
5.3.2 Test procedure	8
5.3.3 Requirements	8
5.4 Directional dependence of heat response	9
5.4.1 Object of the test	9
5.4.2 Test procedure	9
5.4.3 Requirements	9
5.5 Lower limit of heat sensitivity	9
5.5.1 Object of the test	9
5.5.2 Test procedure	9
5.5.3 Requirements	9
5.6 Reproducibility of CO response	10
5.6.1 Object of the test	10
5.6.2 Test procedure	10
5.6.3 Requirements	10
5.7 Reproducibility of heat response	10

5.7.1	Object of the test.....	10
5.7.2	Test procedure.....	10
5.7.3	Requirements.....	10
5.8	Exposure to chemical agents at environmental concentrations.....	10
5.8.1	Object of the test.....	10
5.8.2	Test procedure.....	11
5.8.3	Requirements.....	11
5.9	Long-term stability of CO response.....	12
5.9.1	Object of the test.....	12
5.9.2	Test procedure.....	12
5.9.3	Requirements.....	12
5.10	Saturation.....	12
5.10.1	Object of the test.....	12
5.10.2	Test procedure.....	13
5.10.3	Requirements.....	13
5.11	Exposure to chemical agents which may be present during a fire.....	13
5.11.1	Object of the test.....	13
5.11.2	Test procedure.....	13
5.11.3	Requirements.....	14
5.12	Variation in supply parameters.....	14
5.12.1	Object of the test.....	14
5.12.2	Test procedure.....	15
5.12.3	Requirements.....	15
5.13	Air movement.....	15
5.13.1	Object of the test.....	15
5.13.2	Test procedure.....	15
5.13.3	Requirements.....	15
5.14	Dry heat (operational).....	16
5.14.1	Object of the test.....	16
5.14.2	Test procedure.....	16
5.14.3	Requirements.....	16
5.15	Dry heat endurance.....	16
5.15.1	Object.....	16
5.15.2	Test procedure.....	17
5.15.3	Requirements.....	17
5.16	Cold (operational).....	17
5.16.1	Object of the test.....	17
5.16.2	Test procedure.....	18
5.16.3	Requirements.....	18
5.17	Damp heat, cyclic (operational).....	19
5.17.1	Object.....	19
5.17.2	Test procedure.....	19
5.17.3	Requirements.....	20
5.18	Damp heat, steady-state (endurance).....	20
5.18.1	Object of the test.....	20
5.18.2	Test procedure.....	20
5.18.3	Requirements.....	21
5.19	Low humidity, steady-state (endurance).....	21
5.19.1	Object of the test.....	21
5.19.2	Test procedure.....	21
5.19.3	Requirements.....	21
5.20	Sulfur dioxide SO ₂ corrosion (endurance).....	22
5.20.1	Object of the test.....	22
5.20.2	Test procedure.....	22
5.20.3	Requirements.....	22
5.21	Shock (operational).....	23
5.21.1	Object of the test.....	23
5.21.2	Test procedure.....	23

5.21.3	Requirements	24
5.22	Impact (operational)	24
5.22.1	Object of the test	24
5.22.2	Test procedure	24
5.22.3	Requirements	25
5.23	Vibration, sinusoidal, (operational)	25
5.23.1	Object of the test	25
5.23.2	Test procedure	25
5.23.3	Requirements	26
5.24	Vibration, sinusoidal (endurance)	26
5.24.1	Object of the test	26
5.24.2	Test procedure	26
5.24.3	Requirements	27
5.25	Electromagnetic Compatibility (EMC), Immunity tests (operational)	27
5.26	Fire sensitivity	28
5.26.1	Object of the test	28
5.26.2	Test procedure	28
6	Test report	30
7	Marking	30
8	Data	31
8.1	Hardware documentation	31
8.2	Software documentation	31
Annex A	(normative) Gas test chamber for CO response value and cross sensitivity measurements	33
Annex B	(normative) Heat tunnel for response time and response temperature measurements	34
Annex C	(normative) Apparatus for impact test	35
Annex D	(normative) Fire test room	37
Annex E	(normative) Smouldering (pyrolysis) wood fire (TF2)	39
Annex F	(normative) Glowing smouldering cotton fire (TF3)	43
Annex G	(normative) Open plastics (polyurethane) fire (TF4)	47
Annex H	(normative) Liquid (<i>n</i>-heptane) fire (TF5)	50
Annex I	(informative) Information concerning the construction of the gas test chamber	53
Annex J	(informative) Construction of the heat tunnel	55

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword — Supplementary information](#).

The committee responsible for this document is ISO/TC 21, *Equipment for fire protection and firefighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

This second edition cancels and replaces the first edition (ISO 7240-8:2007), which has been technically revised.

ISO 7240 consists of the following parts, under the general title *Fire detection and alarm systems*:

- Part 1: *General and definitions*
- Part 2: *Control and indicating equipment*
- Part 3: *Audible alarm devices*
- Part 4: *Power supply equipment*
- Part 5: *Point-type heat detectors*
- Part 6: *Carbon monoxide fire detectors using electro-chemical cells*
- Part 7: *Point-type smoke detectors using scattered light, transmitted light or ionization*
- Part 8: *Point-type fire detectors using a carbon monoxide sensor in combination with a heat sensor*
- Part 9: *Test fires for fire detectors* [Technical Specification]
- Part 10: *Point-type flame detectors*
- Part 11: *Manual call points*
- Part 12: *Line type smoke detectors using a transmitted optical beam*
- Part 13: *Compatibility assessment of system components*

- *Part 14: Design, installation, commissioning and service of fire detection and fire alarm systems in and around buildings*
- *Part 15: Point-type fire detectors using smoke and heat sensors*
- *Part 16: Sound system control and indicating equipment*
- *Part 17: Short-circuit isolators*
- *Part 18: Input/output devices*
- *Part 19: Design, installation, commissioning and service of sound systems for emergency purposes*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Routing equipment*
- *Part 22: Smoke-detection equipment for ducts*
- *Part 23: Visual alarm devices*
- *Part 24: Sound-system loudspeakers*
- *Part 25: Components using radio transmission paths*
- *Part 27: Point-type fire detectors using scattered light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*
- *Part 28: Fire protection control equipment*

The following parts are under preparation:

- *Part 29: Video fire detectors*

Introduction

This part of ISO 7240 has been prepared by the Subcommittee ISO/TC 21/SC 3 and is based on ISO 7240-8:2007.

A fire detection and fire alarm system is required to function satisfactorily not only in the event of a fire, but also during and after exposure to conditions likely to be met in practice such as corrosion, vibration, direct impact, indirect shock, and electromagnetic interference. Some tests specified are intended to assess the performance of the fire detectors under such conditions.

Test Fires TF2, TF3, TF4, and TF5 from ISO/TS 7240-9 have been included to verify the detection performance of point fire detectors using a combination of carbon monoxide and heat sensors (CO) sensors. TF4 and TF5 specifically demonstrate the influence of the heat sensor(s). For these Test Fires, the CO level and, where applicable, the temperature is used as test validity criteria. This part of ISO 7240 is not intended to place any other restrictions on the design and construction of such detectors.

Carbon monoxide (CO) fire detectors can react promptly to slow smouldering fires involving carbonaceous materials. Although in the majority of fires, the products of combustion will be transported by convection, the gaseous nature of CO means that it will also diffuse and, particularly in low energy fires, it can move ahead of the smoke plume and, thus, provide earlier detection.

CO fire detectors alone might not react quickly to flaming fires and the addition of a heat sensor as specified in this part of ISO 7240 provides better detection to a broader spectrum of fires.

CO fire detectors based on a combination of a CO sensor and a heat sensor might also be better suited to applications where smoke detectors can produce unwanted alarms due to the presence of dust, steam, or cooking vapours, etc.

While CO gas has greater mobility than smoke, it can be diluted by ventilation systems and be affected by convection currents. Hence, the same considerations as for point smoke detectors should be taken into account. Re-circulating systems confined to a single room have little effect on dilution, as this is similar to the natural diffusion of the CO gas.

It is important that the location of CO fire detectors take into account areas where false operation or non-operation is likely. Some typical locations where it is important to carefully evaluate the use of CO fire detectors are as follows:

- a) areas where CO gas can be present from exhausts and normal manufacturing processes;

EXAMPLE Car parks, car-park return air plenums, loading docks.

- b) confined areas where tobacco smoking is likely.

Australian Standard®

Fire detection and alarm systems

Part 8: Point-type fire detectors using a carbon monoxide sensor in combination with a heat sensor

1 Scope

This part of ISO 7240 specifies requirements, test methods, and performance criteria for point multi-sensor fire detectors that incorporate at least one carbon monoxide (CO) sensor in combination with one or more heat sensors, for use in fire detection and alarm systems installed in buildings (see ISO 7240-1).

For the testing of other types of CO multi-sensor fire detectors, or CO and heat multi-sensor fire detectors working on different principles, this part of ISO 7240 is only to be used for guidance. CO and heat multi-sensor fire detectors with special characteristics and developed for specific risks are not covered by this part of ISO 7240.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 209, *Aluminium and aluminium alloys — Chemical composition*

ISO 7240-1, *Fire detection and alarm systems — Part 1: General and definitions*

ISO 7240-5:2012, *Fire detection and alarm systems — Part 5: Point-type heat detectors*

IEC 60068-1, *Environmental testing Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing Part 2: Tests — Test A: Cold*

IEC 60068-2-2, *Environmental testing Part 2-2: Tests — Test B: Dry heat*

IEC 60068-2-6, *Environmental testing — Part 2: Tests — Test Fc: Vibration [sinusoidal]*

IEC 60068-2-27, *Basic environmental testing procedures Part 2: Tests — Test Ea and guidance: Shock*

IEC 60068-2-30, *Environmental testing — Part 2-30: Tests — Test Db Damp heat, cyclic (12 h+ 12 h cycle)*

IEC 60068-2-42, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections*

IEC 60068-2-78, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state*

IEC 62599-2, *Alarm systems — Part 2: Electromagnetic compatibility — Immunity requirements for components of fire and security alarm systems*

3 Terms and definitions and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the terms, definitions, and abbreviated terms given in ISO 7240-1 and the following apply.