

ANSI/ASABE/ASHRAE EP653 OCT2021

Heating, Ventilating, and Air Conditioning (HVAC) for Indoor Plant Environments without Sunlight



American Society of
Agricultural and Biological Engineers

STANDARD

ASABE is a professional and technical organization, of members worldwide, who are dedicated to advancement of engineering applicable to agricultural, food, and biological systems. ASABE Standards are consensus documents developed and adopted by the American Society of Agricultural and Biological Engineers to meet standardization needs within the scope of the Society; principally agricultural field equipment, farmstead equipment, structures, soil and water resource management, turf and landscape equipment, forest engineering, food and process engineering, electric power applications, plant and animal environment, and waste management.

NOTE: ASABE Standards, Engineering Practices, and Data are informational and advisory only. Their use by anyone engaged in industry or trade is entirely voluntary. The ASABE assumes no responsibility for results attributable to the application of ASABE Standards, Engineering Practices, and Data. Conformity does not ensure compliance with applicable ordinances, laws and regulations. Prospective users are responsible for protecting themselves against liability for infringement of patents.

ASABE Standards, Engineering Practices, and Data initially approved prior to the society name change in July of 2005 are designated as "ASAE", regardless of the revision approval date. Newly developed Standards, Engineering Practices, and Data approved after July of 2005 are designated as "ASABE".

Standards designated as "ANSI" are American National Standards as are all ISO adoptions published by ASABE. Adoption as an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by ASABE.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

CAUTION NOTICE: ASABE and ANSI standards may be revised or withdrawn at any time. Additionally, procedures of ASABE require that action be taken periodically to reaffirm, revise, or withdraw each standard.

Copyright American Society of Agricultural and Biological Engineers and ASHRAE. All rights reserved.

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating ventilation, air conditioning, refrigeration and their allied fields. For more information, visit www.ashrae.org.

ASABE, 2950 Niles Road, St. Joseph, MI 49085-9659, USA, phone 269-429-0300, fax 269-429-3852, hq@asabe.org

ANSI/ASABE/ASHRAE EP653 OCT2021

Approved October 2021 as an American National Standard

Heating, Ventilating, and Air Conditioning (HVAC) for Indoor Plant Environments without Sunlight

Developed by the X653 Development Committee in cooperation with ASHRAE and under the supervision of ASABE PAFS-30 Plant Systems Group. Approved as an ASABE/ASHRAE and ANSI standard October 2021

Keywords: Controlled environment agriculture, Controlled environment horticulture, Energy, Evapotranspiration, Grow room, HVAC, Indoor air quality, Indoor climate control, Indoor climate management, Indoor cultivation, Indoor farm, Indoor farming, Indoor growing, Indoor horticulture, Mechanical engineering, Odor mitigation, Plants, Thermodynamics, Vapor pressure deficit, VPD

0 Introduction

This Engineering Practice provides growers with the foundational information that will a) facilitate the understanding of HVAC equipment options that can be used to manage the indoor plant environment (IPE) and b) allow the grower to communicate knowledgeably with engineers, contractors, manufacturers, investors, and other growers.

The HVAC system selected, and air quality measures employed, affect plant growth and development.

To help facilitate the selection and design of the HVAC system, it is important to establish the design criteria of the IPE. The mechanical engineer, in consultation with the grower, is responsible for sizing and selecting the HVAC equipment based on the psychrometrics of the IPE. The grower will determine the design criteria, including target temperature and humidity ranges, plant transpiration, humidity control, lighting design and operation, and the envelope assemblies (wall, ceiling, etc.).

HVAC systems can be selected to control a single parameter (e.g.: temperature, humidity, air flow or air quality). There are also integrated HVAC systems that can perform multiple functions to control two or more parameters within the IPE. The selection of the HVAC systems will influence space planning, energy use, the number of different systems needed, and the ability to respond to changing conditions in the IPE.

1 Purpose and Scope

1.1 This Engineering Practice sets forth guidelines describing the plant shoot zone environment and the interactions with plants grown indoors without sunlight.

1.2 This Engineering Practice establishes criteria that will promote the cultivation of plants, with a focus on the thermodynamics and air quality of the indoor plant environment.

1.3 The intended audience of this Engineering Practice is the owner and operator of the indoor plant environment (i.e.: “the grower”).

1.4 This Engineering Practice presents design considerations associated with selecting HVAC equipment currently available and commonly used to manage the temperature, humidity, and air quality in the indoor plant environment.

1.5 Excluded from this Engineering Practice are: HVAC systems serving water-cooled LED lighting; HVAC condensate drainage capture, treatment and reuse; thermal storage; and phase change building materials.

ANSI/ASABE/ASHRAE EP653 OCT2021

Copyright American Society of Agricultural and Biological Engineers and ASHRAE. ASHRAE is a registered trademark in the U.S. Patent and Trademark Office, owned by the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.