

Design of Steel Transmission Pole Structures

This document uses both the
International System of Units (SI)
and customary units

American Society of Civil Engineers

Design of Steel Transmission Pole Structures

ASCE/SEI 48-11

This document uses both the International System of Units (SI) and customary units.



**STRUCTURAL
ENGINEERING
INSTITUTE**

Published by the American Society of Civil Engineers

Library of Congress Cataloging-in-Publication Data

Design of steel transmission pole structures: standard 48-11.

p. cm. – (ASCE standard)

“ASCE/SEI 48-11.”

“This document uses both the International System of Units (SI) and customary units.”

Includes bibliographical references and index.

ISBN 978-0-7844-1181-0 (alk. paper)

1. Electric lines—Poles and towers—Design and construction. I. American Society of Civil Engineers.

TK3242.D475 2011

621.319'22—dc23

2011031788

Published by American Society of Civil Engineers

1801 Alexander Bell Drive

Reston, Virginia 20191

www.pubs.asce.org

This standard was developed by a consensus standards development process which has been accredited by the American National Standards Institute (ANSI). Accreditation by ANSI, a voluntary accreditation body representing public and private sector standards development organizations in the U.S. and abroad, signifies that the standards development process used by ASCE has met the ANSI requirements for openness, balance, consensus, and due process.

While ASCE's process is designed to promote standards that reflect a fair and reasoned consensus among all interested participants, while preserving the public health, safety, and welfare that is paramount to its mission, it has not made an independent assessment of and does not warrant the accuracy, completeness, suitability, or utility of any information, apparatus, product, or process discussed herein. ASCE does not intend, nor should anyone interpret, ASCE's standards to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this standard.

ASCE has no authority to enforce compliance with its standards and does not undertake to certify products for compliance or to render any professional services to any person or entity.

ASCE disclaims any and all liability for any personal injury, property damage, financial loss or other damages of any nature whatsoever, including without limitation any direct, indirect, special, exemplary, or consequential damages, resulting from any person's use of, or reliance on, this standard. Any individual who relies on this standard assumes full responsibility for such use.

ASCE and American Society of Civil Engineers—Registered in U.S. Patent and Trademark Office.

Photocopies and reprints. You can obtain instant permission to photocopy ASCE publications by using ASCE's online permission service (<http://pubs.asce.org/permissions/requests/>). Requests for 100 copies or more should be submitted to the Reprints Department, Publications Division, ASCE (address above); e-mail: permissions@asce.org. A reprint order form can be found at <http://pubs.asce.org/support/reprints/>.

Copyright © 2012 by the American Society of Civil Engineers.

All Rights Reserved.

ISBN 978-0-7844-1181-0

Manufactured in the United States of America.

18 17 16 15 14 13 12 11 1 2 3 4 5

STANDARDS

In 2006, the Board of Direction approved the revision to the ASCE Rules for Standards Committees to govern the writing and maintenance of standards developed by the Society. All such standards are developed by a consensus standards process managed by the Society's Codes and Standards Committee (CSC). The consensus process includes balloting by a balanced standards committee made up of Society members and nonmembers, balloting by the membership of the Society as a whole, and balloting by the public. All standards are updated or reaffirmed by the same process at intervals not exceeding five years.

The following standards have been issued:

- ANSI/ASCE 1-82 N-725 Guideline for Design and Analysis of Nuclear Safety Related Earth Structures
- ASCE/EWRI 2-06 Measurement of Oxygen Transfer in Clean Water
- ANSI/ASCE 3-91 Standard for the Structural Design of Composite Slabs and ANSI/ASCE 9-91 Standard Practice for the Construction and Inspection of Composite Slabs
- ASCE 4-98 Seismic Analysis of Safety-Related Nuclear Structures
- Building Code Requirements for Masonry Structures (ACI 530-02/ASCE 5-02/TMS 402-02) and Specifications for Masonry Structures (ACI 530.1-02/ASCE 6-02/TMS 602-02)
- ASCE/SEI 7-10 Minimum Design Loads for Buildings and Other Structures
- SEI/ASCE 8-02 Standard Specification for the Design of Cold-Formed Stainless Steel Structural Members
- ANSI/ASCE 9-91 listed with ASCE 3-91
- ASCE 10-97 Design of Latticed Steel Transmission Structures
- SEI/ASCE 11-99 Guideline for Structural Condition Assessment of Existing Buildings
- ASCE/EWRI 12-05 Guideline for the Design of Urban Subsurface Drainage
- ASCE/EWRI 13-05 Standard Guidelines for Installation of Urban Subsurface Drainage
- ASCE/EWRI 14-05 Standard Guidelines for Operation and Maintenance of Urban Subsurface Drainage
- ASCE 15-98 Standard Practice for Direct Design of Buried Precast Concrete Pipe Using Standard Installations (SIDD)
- ASCE 16-95 Standard for Load Resistance Factor Design (LRFD) of Engineered Wood Construction
- ASCE 17-96 Air-Supported Structures
- ASCE 18-96 Standard Guidelines for In-Process Oxygen Transfer Testing
- ASCE/SEI 19-10 Structural Applications of Steel Cables for Buildings
- ASCE 20-05 Standard Guidelines for the Design and Installation of Pier Foundations
- ANSI/ASCE/T&DI 21-05 Automated People Mover Standards—Part 1
- ANSI/ASCE/T&DI 21.2-08 Automated People Mover Standards—Part 2
- ANSI/ASCE/T&DI 21.3-08 Automated People Mover Standards—Part 3
- ANSI/ASCE/T&DI 21.4-08 Automated People Mover Standards—Part 4
- SEI/ASCE 23-97 Specification for Structural Steel Beams with Web Openings
- ASCE/SEI 24-05 Flood Resistant Design and Construction
- ASCE/SEI 25-06 Earthquake-Actuated Automatic Gas Shut-off Devices
- ASCE 26-97 Standard Practice for Design of Buried Precast Concrete Box Sections
- ASCE 27-00 Standard Practice for Direct Design of Precast Concrete Pipe for Jacking in Trenchless Construction
- ASCE 28-00 Standard Practice for Direct Design of Precast Concrete Box Sections for Jacking in Trenchless Construction
- ASCE/SEI/SFPE 29-05 Standard Calculation Methods for Structural Fire Protection
- SEI/ASCE 30-00 Guideline for Condition Assessment of the Building Envelope
- SEI/ASCE 31-03 Seismic Evaluation of Existing Buildings
- SEI/ASCE 32-01 Design and Construction of Frost-Protected Shallow Foundations
- EWRI/ASCE 33-09 Comprehensive Transboundary International Water Quality Management Agreement
- EWRI/ASCE 34-01 Standard Guidelines for Artificial Recharge of Groundwater
- EWRI/ASCE 35-01 Guidelines for Quality Assurance of Installed Fine Pore Aeration Equipment
- ASCE 36-01 Standard Construction Guidelines for Microtunneling
- SEI/ASCE 37-02 Design Loads on Structures during Construction
- CI/ASCE 38-02 Standard Guideline for the Collection and Depiction of Existing Subsurface Utility Data
- EWRI/ASCE 39-03 Standard Practice for the Design and Operation of Hail Suppression Projects
- ASCE/EWRI 40-03 Regulated Riparian Model Water Code
- ASCE/SEI 41-06 Seismic Rehabilitation of Existing Buildings
- ASCE/EWRI 42-04 Standard Practice for the Design and Operation of Precipitation Enhancement Projects
- ASCE/SEI 43-05 Seismic Design Criteria for Structures, Systems, and Components in Nuclear Facilities
- ASCE/EWRI 44-05 Standard Practice for the Design and Operation of Supercooled Fog Dispersal Projects
- ASCE/EWRI 45-05 Standard Guidelines for the Design of Urban Stormwater Systems
- ASCE/EWRI 46-05 Standard Guidelines for the Installation of Urban Stormwater Systems
- ASCE/EWRI 47-05 Standard Guidelines for the Operation and Maintenance of Urban Stormwater Systems
- ASCE/SEI 48-11 Design of Steel Transmission Pole Structures
- ASCE/EWRI 50-08 Standard Guideline for Fitting Saturated Hydraulic Conductivity Using Probability Density Functions
- ASCE/EWRI 51-08 Standard Guideline for Calculating the Effective Saturated Hydraulic Conductivity
- ASCE/SEI 52-10 Design of Fiberglass-Reinforced Plastic (FRP) Stacks

ASCE/G-I 53-10 Compaction Grouting Consensus Guide
ASCE/EWRI 54-10 Standard Guideline for the Geostatistical
Estimation and Block-Averaging of Homogeneous and Isotropic Saturated Hydraulic Conductivity
ASCE/SEI 55-10 Tensile Membrane Structures
ANSI/ASCE/EWRI 56-10 Guidelines for the Physical Security of Water Utilities

ANSI/ASCE/EWRI 57-10 Guidelines for the Physical Security of Wastewater/Stormwater Utilities
ASCE/T&DI/ICPI 58-10 Structural Design of Interlocking Concrete Pavement for Municipal Streets and Roadways

Currently in preview, click buy full version

FOREWORD

This Standard includes commentary and appendices that are furnished as supplemental information. The commentary and appendices are not mandatory.

Before the initial publication of this Standard in 2005, most electric transmission design professionals used ASCE's Engineering Manual and Report on Engineering Practice No. 72, titled Design of Steel Transmission Pole Structures, as their primary reference for providing a uniform basis for designing, fabricating, testing, assembling, and erecting steel transmission pole structures. The second edition of Manual 72 served as the primary resource document for the development of the original version of this Standard, ASCE 48-05. This book is the first

revision to this Standard and is intended to replace ASCE 48-05 in its entirety.

This Standard has been prepared in accordance with recognized engineering principles and should not be used without the user's competent knowledge for a given application. The publication of this Standard by ASCE is not intended as a warranty that the information contained herein is suitable for any general or specific use, and the Society takes no position with regard to the validity of patent rights. Users are advised that the determination of patent rights or risk of infringement is entirely their own responsibility.

This page intentionally left blank

Currently in preview, click buy full version

COMMITTEE ROSTER

This Standard was prepared through the consensus standards process by balloting in compliance with procedures of the ASCE Code and Standards Committee. Those individuals who serve on the Design of Steel Transmission Pole Structures Standards Committee are

Richard F. Aichinger, P.E.
J. Kelly Bledsoe, P.E.
Gary E. Bowles, P.E.
David G. Brinker, P.E., S.E.
Michael D. Brown, P.E.
Jerry G. Crawford, P.E.
Dana R. Crissey, P.E.
Martin L. de la Rosa, P.E.
Joel G. Dembowski
David Endorf, P.E.
Michael R. Gall, P.E.
Lewis H. Grant, P.E.
Nicholas Grossenbach, P.E.
Bobby G. Hagler, P.E.
James A Hamraie, P.E.
Henry W. Ho, P.E.
Magdi F. Ishac, Ph.D., P.Eng.
Leon Kempner, Jr., Ph.D., P.E.
Massoud Khavari, P.E.
Fred H. Kulhawy, Ph.D., P.E., G.E.

Brian Lacoursiere, P.Eng.
Paul M. Legrand II, P.E.
Otto J. Lynch, P.E.
William L. Magee, P.E., Vice-Chair
Terry C. McAnnally, P.E.
William B. Mills, P.E.
Michael R. Morel, P.E.
George E. Murray Jr., P.E.
David Nahlen, P.E.
Robert E. Nickerson, P.E.
Garold D. Oberlender, Ph.D., P.E.
Robert L. Patterson, P.E.
Ronald E. Randle, P.E., Chair
Pedram Sadr, P.E.
Majed J. Saleh
Randall L. Samson, P.E.
Karnik M. Seferian, P.E.
Kenneth L. Sealless, P.E.
Marlon W. Yoger, P.E., Secretary
Jim Walker, P.E.

This page intentionally left blank

Currently in preview, click buy full version

INTRODUCTION

The Design of Steel Transmission Pole Structures Standard applies to cold-formed single- and multiple-pole tubular steel structures that support overhead electrical transmission lines. Design parameters are applicable to guyed and self-supporting structures using a variety of foundation types, including concrete caissons, steel piling, and direct embedment. The Standard outlines key criteria that must be considered in the structural design, detailing, fabrication, testing, assembly, and erection of these structures. This Standard is a revision of ASCE/SEI 48-05 and provides some revisions to formulas based on other current industry standards. In addition, the Standard includes a detailed commentary and appendices with explanatory and supplementary information designed to provide the user with clarification and reference information.

The information presented has been prepared in accordance with established engineering principles using state-of-the-art information and is intended for general information. Whereas every effort has been made to ensure its accuracy, the information should not be relied upon for any specific application without the consultation of a competent engineer to determine its suitability. Nothing in the Standard shall be construed to alter or subvert the requirements of any existing code or authority having jurisdiction over the facility. Furthermore, alternate methods and materials to those herein indicated may be used, provided that the engineer can demonstrate the suitability to all agencies and authorities.

This page intentionally left blank

CONTENTS

		Page
1	Scope	1
2	Applicable Documents	3
3	Definitions	5
4	Loading, Geometry, and Analysis	7
4.1	Introduction	7
4.2	Loading	7
4.2.1	Factored Design Loads	7
4.2.2	Loading Considerations	7
4.2.3	Load Expression	7
4.3	Geometric Configurations	7
4.3.1	Configuration Considerations	7
4.3.2	Structure Types	7
4.4	Methods of Analysis	7
4.4.1	Structural Analysis Methods	7
4.4.2	Analysis of Connections	7
4.5	Additional Considerations	7
4.5.1	Structural Support	7
4.5.2	Design Restrictions	7
4.5.3	Climbing and Maintenance Provisions	7
4.5.4	Pre-engineered Steel Poles (“Wood Pole Equivalents”)	7
5	Design of Members	9
5.1	Introduction	9
5.2	Members	9
5.2.1	Materials	9
5.2.1.1	Specifications	9
5.2.1.2	Material Properties	9
5.2.1.3	Energy-Impact Properties	9
5.2.2	Tension	9
5.2.3	Compression	9
5.2.3.1	Truss Members	9
5.2.3.2	Beam Members	10
5.2.4	Shear	10
5.2.5	Bending	11
5.2.6	Combined Stresses	11
5.3	Guys	11
5.3.1	Material Properties	11
5.3.2	Tension	11
5.4	Test Verification	11
6	Design of Connections	13
6.1	Introduction	13
6.2	Bolted and Pinned Connections	13
6.2.1	Materials	13
6.2.2	Shear Stress in Bearing Connections	13
6.2.3	Bolts Subject to Tension	13
6.2.4	Bolts Subject to Combined Shear and Tension	13
6.2.5	Bearing Stress in Bolted Connections	13
6.2.6	Minimum Edge Distances and Bolt Spacing for Bolted Connections	14
6.2.7	Bearing Stress in Pinned Connections	14

	6.2.8	Minimum Edge Distances for Pinned Connections	14
	6.2.9	Connection Elements and Members	14
6.3		Welded Connections	14
	6.3.1	Material Properties	14
	6.3.2	Effective Area	14
	6.3.3	Design Stresses	15
	6.3.3.1	Through-Thickness Stress	15
	6.3.4	Circumferential Welded Splices.	15
	6.3.5	Flange and Base Plate to Pole Shaft Welds.	15
	6.3.6	T-Joints	15
6.4		Field Connections of Members	15
	6.4.1	Slip Joints	15
	6.4.2	Base and Flange Plate Connections	16
6.5		Test Verification	16
7		Detailing and Fabrication	17
	7.1	Detailing	17
	7.1.1	Drawings	17
	7.1.2	Drawing Review.	17
	7.1.3	Erection Drawings.	17
	7.1.4	Shop Detail Drawings.	17
	7.1.4.1	Material.	17
	7.1.4.2	Dimensions and Tolerances	17
	7.1.4.3	Welding.	17
	7.1.4.4	Corrosion and Finish Considerations	17
	7.1.4.5	Other Requirements	17
	7.2	Fabrication	17
	7.2.1	Material	17
	7.2.2	Material Preparation.	17
	7.2.2.1	Cutting	17
	7.2.2.2	Forming.	17
	7.2.2.3	Holes	17
	7.2.2.4	Identification	17
	7.2.3	Welding	17
8		Testing	19
	8.1	Introduction	19
	8.2	Foundations	19
	8.3	Material	19
	8.4	Fabrication	19
	8.5	Strain Measurements	19
	8.6	Assembly and Erection	19
	8.7	Test Loads	19
	8.8	Load Application	19
	8.9	Loading Procedure.	19
	8.10	Load Measurement	19
	8.11	Deflections	19
	8.12	Failures.	19
	8.13	Post-Test Inspection	19
	8.14	Disposition of Prototype.	19
	8.15	Report	19
9		Structural Members and Connections Used in Foundations	21
	9.1	Introduction	21
	9.2	General Considerations	21
	9.3	Anchor Bolts.	21
	9.3.1	Bolts Subject to Tension	21
	9.3.2	Shear Stress	21
	9.3.3	Combined Shear and Tension.	21
	9.3.4	Development Length	21
	9.4	Direct-Embedded Poles	21

9.5	Embedded Casings	22
9.6	Test Verification	22
10	Quality Assurance/Quality Control	23
10.1	Introduction	23
10.2	Quality Assurance	23
10.2.1	Design and Drawings	23
10.2.2	Materials	23
10.2.3	Welding	23
10.2.4	Nondestructive Testing	23
10.2.5	Tolerances	23
10.2.6	Surface Coatings	23
10.2.7	Shipping	23
10.3	Quality Control	23
10.3.1	Materials	23
10.3.2	Visual Inspection	23
10.3.3	Dimensional Inspection	23
10.3.4	Surface Coating Inspection	23
10.3.5	Weld Inspection	23
10.3.6	Shipment and Storage	24
11	Assembly and Erection	25
11.1	Introduction	25
11.2	Handling	25
11.3	Single-Pole Structures	25
11.3.1	Slip Joints	25
11.3.2	Bolted Flange Joints	25
11.3.3	Attachments to Pole Sections	25
11.3.4	Erection of Assembled Structures	25
11.4	Frame-Type Structures	25
11.4.1	Slip Joints in Frames	25
11.4.2	Erection	25
11.4.3	Bolted Frame Connections	25
11.5	Installation on Foundation	25
11.5.1	Anchor Bolt and Base Plate Installation	25
11.5.2	Direct-Embedded Poles	25
11.6	Guying	25
11.6.1	Guy Anchor Location	25
11.6.2	Guy Installation	25
11.7	Posterection Procedures	25
11.7.1	Inspection	25
11.7.2	Grounding	25
11.7.3	Coating Repair	25
11.7.4	Unloaded Arms	26
11.7.5	Hardware Installation	26
	COMMENTARY	27
C4	Loading, Geometry, and Analysis	29
C4.2	Loading	29
C4.2.1	Factored Design Loads	29
C4.2.2	Loading Considerations	29
C4.2.3	Load Expression	29
C4.3	Geometric Configurations	30
C4.3.1	Configuration Considerations	30
C4.3.2	Structure Types	30
C4.4	Methods of Analysis	30
C4.4.1	Structural Analysis Methods	30
C4.5	Additional Considerations	31
C4.5.1	Structural Support	31

	C4.5.2	Design Restrictions	31
	C4.5.3	Climbing and Maintenance Provisions	31
	C4.5.4	Pre-engineered Steel Poles (“Wood Pole Equivalents”)	31
C5		Design of Members	33
	C5.1	Introduction	33
	C5.2	Members	33
		C5.2.1 Materials	33
		C5.2.1.1 Specifications	33
		C5.2.1.2 Material Properties	33
		C5.2.1.3 Energy-Impact Properties	33
	C5.2.2	Tension	33
	C5.2.3	Compression	33
		C5.2.3.1 Truss Members	33
		C5.2.3.2 Beam Members	34
	C5.2.4	Shear	36
	C5.2.5	Bending	36
	C5.2.6	Combined Stresses	36
	C5.3	Guys	36
		C5.3.1 Material Properties	36
		C5.3.2 Tension	36
		References	36
C6		Design of Connections	39
	C6.1	Introduction	39
	C6.2	Bolted and Pinned Connections	39
		C6.2.1 Materials	39
		C6.2.2 Shear Stress in Bearing Connections	39
		C6.2.3 Bolts Subject to Tension	39
		C6.2.5 Bearing Stress in Bolted Connections	39
		C6.2.6 Minimum Edge Distances and Bolt Spacing for Bolted Connections	39
		C6.2.7 Bearing Stress in Pinned Connections	39
		C6.2.8 Minimum Edge Distances for Pinned Connections	40
		C6.2.9 Connection Elements and Members	40
	C6.3	Welded Connections	40
		C6.3.3 Design Stresses	40
		C6.3.3.1 Through-Thickness Stress	40
	C6.4	Field Connections of Members	40
		C6.4.1 Slip Joints	40
		C6.4.2 Base and Flange Plate Connections	41
	C6.5	Test Verification	41
C7		Detailing and Fabrication	43
	C7.1	Detailing	43
		C7.1.1 Drawings	43
		C7.1.2 Drawing Review	43
		C7.1.3 Erection Drawings	43
		C7.1.4 Shop Detail Drawings	43
		C7.1.4.2 Dimensions and Tolerances	43
		C7.1.4.4 Corrosion and Finish Considerations	43
		C7.1.4.5 Other Requirements	43
	C7.2	Fabrication	43
		C7.2.1 Material	43
		C7.2.2 Material Preparation	43
		C7.2.2.1 Cutting	43
		C7.2.2.2 Forming	43
		C7.2.2.3 Holes	44
		C7.2.2.4 Identification	44
	C7.2.3	Welding	44

C8	Testing	45
C8.1	Introduction	45
C8.2	Foundations	45
C8.3	Material	45
C8.4	Fabrication	45
C8.5	Strain Measurements	45
C8.6	Assembly and Erection	45
C8.7	Test Loads	46
C8.8	Load Application	46
C8.9	Loading Procedure.	46
C8.10	Load Measurement	46
C8.11	Deflections.	46
C8.12	Failures.	46
C8.13	Post-Test Inspection	46
C8.14	Disposition of Prototype.	46
C8.15	Report	46
C9	Structural Members and Connections Used in Foundations	47
C9.1	Introduction	47
C9.2	General Considerations	47
C9.3	Anchor Bolts.	48
	C9.3.3 Combined Shear and Tension.	48
	C9.3.4 Development Length	48
C9.4	Direct-Embedded Poles	49
C9.5	Embedded Casings.	49
C10	Quality Assurance/Quality Control	51
C10.1	Introduction	51
C10.2	Quality Assurance	51
	C10.2.1 Design and Drawings	51
	C10.2.4 Nondestructive Testing	51
	C10.2.5 Tolerances	51
	C10.2.6 Surface Coatings	51
	C10.2.7 Shipping	51
C10.3	Quality Control	51
	C10.3.1 Materials.	51
	C10.3.3 Dimensional Inspection	51
	C10.3.4 Surface Coating Inspection	51
	C10.3.5 Weld Inspection	51
	C10.3.6 Shipment and Storage.	52
C11	Assembly and Erection	53
C11.1	Introduction	53
C11.2	Handling	53
C11.3	Single-Pole Structures.	53
	C11.3.1 Slip Joints	53
	C11.3.2 Bolted Flange Joints.	53
	C11.3.3 Attachments to Pole Sections.	54
	C11.3.4 Erection of Assembled Structures.	54
C11.4	Frame-Type Structures.	54
	C11.4.1 Slip Joints in Frames	54
	C11.4.2 Erection	54
C11.5	Installation on Foundation.	54
	C11.5.1 Anchor Bolt and Base Plate Installation	54
	C11.5.2 Direct-Embedded Poles	54
C11.6	Guying	54
	C11.6.1 Guy Anchor Location	54
	C11.6.2 Guy Installation	54
C11.7	Posterection Procedures	55
	C11.7.1 Inspection	55
	C11.7.2 Grounding	55
	C11.7.3 Coating Repair	55
	C11.7.4 Unloaded Arms	55
	C11.7.5 Hardware Installation	55

Appendix I Notations	57
Appendix II Properties of Various Tubular Sections	59
Notation for Appendix II	59
Appendix III Horizontal Testing	63
Test Equipment.	63
Test Procedure for Pole Test.	63
Appendix IV Headed Anchor Bolts	65
Development Length.	65
Background	65
Appendix V Assembly and Erection.	67
Introduction	67
Helicopter Erection	67
In-Service Structure Maintenance and Inspection.	67
Wind-Induced Vibration	67
Appendix VI Shaft-to-Foundation Connection	69
Base Plates—Analysis Considerations	69
Calculation of Anchor Bolt Load	71
Appendix VII Corrosion Protection and Finish Considerations.	73
Introduction	73
Corrosion Mechanisms.	73
Corrosion Protection and Finish Options	73
Paint and Coating Systems	73
Above-Grade Protection.	74
Below-Grade Protection.	74
Surface Preparation	74
Application	74
Inspection	74
Paint or Coating Over Galvanizing	74
Galvanizing	74
Protection Provided	74
Appearance	75
Special Design Considerations	75
Application	76
Repair	76
Weathering Steel	77
Metalizing	78
References	78
Appendix VIII Arm-to-Shaft Connection Analysis Considerations	81
General Load, Dimension, and Material Specifications.	81
INDEX	83

Chapter 1

SCOPE

Design of Steel Transmission Pole Structures specifies requirements for the design, fabrication, testing, assembly, and erection of cold-formed tubular members and connections for steel electrical transmission pole structures. Structure components (members, connections, guys) are selected to resist factored design loads at stresses approaching yielding, buckling, fracture, or any other limiting condition specified in this standard. Distribution, substation, communication, and railroad electric traction structures are not included within the scope of this standard.

Before the initial publication of this standard in 2005, most electric transmission design professionals used ASCE's Engineering Manual and Report on Engineering Practice No. 72 titled

Design of Steel Transmission Pole Structures as their primary reference for providing a uniform basis for designing, fabricating, testing, assembling, and erecting steel transmission pole structures. The second edition of Manual 72 served as the primary resource document for the development of the original version of this standard, ASCE 48-05. This document is the first revision to this standard and is intended to replace ASCE 48-05 in its entirety.

Units of measurement herein are expressed first in English units followed by the Systems International (SI) units in parentheses. Formulae are based on English units, and, thus, some formulae require a conversion factor to use SI units. The appropriate conversion factor is given after each formula.