

CONTENTS

FOREWORD	9
1 PURPOSE	11
2 SCOPE	11
3 DEFINITIONS	11
3.1 Terms Adopted from International Standards	11
3.2 Terms Defined for this Standard	12
3.3 Abbreviations and Acronyms Used in this Standard	17
4 BACnet PROTOCOL ARCHITECTURE	21
4.1 The BACnet Collapsed Architecture	22
4.2 BACnet Network Topology	24
4.3 Security	24
5 THE APPLICATION LAYER	26
5.1 The Application Layer Model	26
5.2 Segmentation of BACnet Messages	30
5.3 Transmission of BACnet APDUs	31
5.4 Application Protocol State Machines	35
5.5 Application Protocol Time Sequence Diagrams	52
5.6 Application Layer Service Conventions	60
6 THE NETWORK LAYER	61
6.1 Network Layer Service Specification	61
6.2 Network Layer PDU Structure	63
6.3 Messages for Multiple Recipients	69
6.4 Network Layer Protocol Messages	69
6.5 Network Layer Procedures	72
6.6 BACnet Routers	75
6.7 Point-To-Point Half-Routers	80
7 DATA LINK/PHYSICAL LAYERS: Ethernet (ISO 8802-3) LAN	84
7.1 The Use of ISO 8802-2 Logical Link Control (LLC)	84
7.2 Parameters Required by the LLC Primitives	84
7.3 Parameters Required by the MAC Primitives	84
7.4 Physical Media	84
8 DATA LINK/PHYSICAL LAYERS: ARCNET (ANSI X3.178.1) LAN	85
8.1 The Use of ISO 8802-2 Logical Link Control (LLC)	85
8.2 Parameters Required by the LLC Primitives	85
8.3 Mapping the LLC Services to the ARCNET MAC Layer	85
8.4 Parameters Required by the MAC Primitives	85
8.5 Physical Media	85
9 DATA LINK/PHYSICAL LAYERS: MASTER-SLAVE/TOKEN-PASSING (MS/TP) LAN	87
9.1 Service Specification	87
9.2 Physical Layer	89
9.3 MS/TP Frame Format	100
9.4 Overview of the MS/TP Network	102
9.5 MS/TP Medium Access Control	102
9.6 Cyclic Redundancy Check (CRC)	121
9.7 Interfacing MS/TP LANs with Other BACnet LANs	123
9.8 Responding BACnet User Processing of Messages from MS/TP	123
9.9 Repeaters	123
9.10 COB (Consistent Overhead Byte Stuffing) Encoding	125
9.11 Documenting MS/TP Device Design Choices	128
10 DATA LINK/PHYSICAL LAYERS: POINT-TO-POINT (PTP)	130
10.1 Overview	130
10.2 Service Specification	130
10.3 Point-to-Point Frame Format	134
10.4 PTP Medium Access Control Protocol	137
11 DATA LINK/PHYSICAL LAYERS: LonTalk (ISO/IEC 14908.1) LAN	158

11.1	The Use of ISO 8802-2 Logical Link Control (LLC)	158
11.2	Parameters Required by the LLC Primitives.....	158
11.3	Mapping the LLC Services to the LonTalk Application Layer.....	158
11.4	Parameters Required by the Application Layer Primitives	158
11.5	Physical Media	159
12	MODELING CONTROL DEVICES AS A COLLECTION OF OBJECTS.....	160
12.1	Object Characteristics and Requirements.....	160
12.2	Analog Input Object Type.....	166
12.3	Analog Output Object Type	177
12.4	Analog Value Object Type.....	179
12.5	Averaging Object Type	186
12.6	Binary Input Object Type.....	190
12.7	Binary Output Object Type	197
12.8	Binary Value Object Type.....	205
12.9	Calendar Object Type.....	213
12.10	Command Object Type	215
12.11	Device Object Type.....	221
12.12	Event Enrollment Object Type.....	232
12.13	File Object Type.....	240
12.14	Group Object Type.....	243
12.15	Life Safety Point Object Type.....	245
12.16	Life Safety Zone Object Type.....	252
12.17	Loop Object Type.....	259
12.18	Multi-state Input Object Type	268
12.19	Multi-state Output Object Type	274
12.20	Multi-state Value Object Type	281
12.21	Notification Class Object Type	288
12.22	Program Object Type	294
12.23	Pulse Converter Object Type	301
12.24	Schedule Object Type	308
12.25	Trend Log Object Type	315
12.26	Access Door Object Type.....	325
12.27	Event Log Object Type	334
12.28	Load Control Object Type.....	341
12.29	Structured View Object Type.....	351
12.30	Trend Log Multiple Object Type	356
12.31	Access Point Object Type	365
12.32	Access Zone Object Type.....	382
12.33	Access User Object Type	390
12.34	Access Rights Object Type	394
12.35	Access Credential Object Type	400
12.36	Credential Data Input Object Type.....	409
12.37	CharacterString Value Object Type	415
12.38	DateTime Value Object Type.....	422
12.39	Large Analog Value Object Type.....	428
12.40	BitString Value Object Type.....	435
12.41	OctetString Value Object Type	441
12.42	Time Value Object Type	445
12.43	Integer Value Object Type	451
12.44	Positive Integer Value Object Type	458
12.45	State Value Object Type.....	465
12.46	DateTime Pattern Value Object Type	471
12.47	Time Pattern Value Object Type.....	477
12.48	Date Pattern Value Object Type.....	483
12.49	Deleted Clause	489
12.50	Global Group Object Type.....	490

12.51	Notification Forwarder Object Type	497
12.52	Alert Enrollment Object Type	504
12.53	Channel Object Type	508
12.54	Lighting Output Object Type	518
12.55	Binary Lighting Output Object Type	532
12.56	Network Port Object Type	542
12.57	Timer Object Type	566
12.58	Elevator Group Object Type	578
12.59	Lift Object Type	587
12.60	Escalator Object Type	594
12.61	Accumulator Object Type	611
12.62	Staging Object Type	610
12.63	Audit Reporter Object Type	619
12.64	Audit Log Object Type	624
13	ALARM AND EVENT SERVICES	631
13.1	Change of Value Reporting	631
13.2	Event Reporting	636
13.3	Event Algorithms	647
13.4	Fault Algorithms	676
13.5	AcknowledgeAlarm Service	683
13.6	ConfirmedCOVNotification Service	685
13.7	UnconfirmedCOVNotification Service	687
13.8	ConfirmedEventNotification Service	688
13.9	UnconfirmedEventNotification Service	691
13.10	GetAlarmSummary Service	694
13.11	GetEnrollmentSummary Service	696
13.12	GetEventInformation Service	699
13.13	LifeSafetyOperation Service	701
13.14	SubscribeCOV Service	703
13.15	SubscribeCOVProperty Service	706
13.16	SubscribeCOVPropertyMultiple Service	709
13.17	ConfirmedCOVNotificationMultiple Service	714
13.18	UnconfirmedCOVNotificationMultiple Service	717
13.19	AuditLogQuery	719
13.20	ConfirmedAuditNotification	723
13.21	UnconfirmedAuditNotification	724
14	FILE ACCESS SERVICES	725
14.1	AtomicReadFile Service	725
14.2	AtomicWriteFile Service	728
15	OBJECT ACCESS SERVICES	731
15.1	AddListElement Service	731
15.2	RemoveListElement Service	733
15.3	CreateObject Service	735
15.4	DeleteObject Service	738
15.5	ReadProperty Service	739
15.6	DeletedCause	741
15.7	ReadPropertyMultiple Service	742
15.8	ReadRange Service	745
15.9	WriteProperty Service	752
15.10	WritePropertyMultiple Service	754
15.11	WriteGroup Service	757
16	REMOTE DEVICE MANAGEMENT SERVICES	759
16.1	DeviceCommunicationControl Service	759
16.2	ConfirmedPrivateTransfer Service	761
16.3	UnconfirmedPrivateTransfer Service	763
16.4	ReinitializeDevice Service	764

16.5	ConfirmedTextMessage Service	766
16.6	UnconfirmedTextMessage Service	768
16.7	TimeSynchronization Service	769
16.8	UTCTimeSynchronization Service	770
16.9	Who-Has and I-Have Services	771
16.10	Who-Is and I-Am Services	773
16.11	Who-Am-I and You-Are Services	775
17	VIRTUAL TERMINAL SERVICES	777
17.1	Virtual Terminal Model	777
17.2	VT-Open Service	781
17.3	VT-Close Service	783
17.4	VT-Data Service	784
17.5	Default Terminal Characteristics	786
18	ERROR, REJECT, and ABORT CODES	790
18.1	Error Class - DEVICE	790
18.2	Error Class - OBJECT	790
18.3	Error Class - PROPERTY	791
18.4	Error Class - RESOURCES	792
18.5	Error Class - SECURITY	793
18.6	Error Class - SERVICES	794
18.7	Error Class - COMMUNICATION	795
18.8	Error Class - VT	799
18.9	Reject Reason	800
18.10	Abort Reason	800
18.11	Confirmed Service Common Errors	801
19	BACnet PROCEDURES	802
19.1	Backup and Restore	802
19.2	Command Prioritization	807
19.3	Device Restart Procedure	812
19.4	Determining Maximum Conveyable APDU	813
19.5	Value Source Mechanism	815
19.6	Audit Logging	817
19.7	Unconfigured Device Discovery and Address Assignment	827
20	ENCODING BACnet PROTOCOL DATA UNITS	828
20.1	Encoding the Fixed Part of BACnet APDUs	829
20.2	Encoding the Variable Part of BACnet APDUs	840
21	FORMAL DESCRIPTION OF APPLICATION PROTOCOL DATA UNITS	855
21.1	APDU Definitions	855
21.2	Confirmed Service Productions	857
21.3	Unconfirmed Service Productions	867
21.4	Error Productions	871
21.5	Application Types	881
21.6	Base Types	882
22	CONFORMANCE AND INTEROPERABILITY	952
22.1	Conformance to BACnet	952
22.2	BACnet Interoperability	953
23	EXTENDING BACnet TO ACCOMMODATE VENDOR PROPRIETARY INFORMATION	955
23.1	Extending Enumeration Values	955
23.2	Using the PrivateTransfer Services to Invoke Non-Standardized Services	956
23.3	Adding Proprietary Properties to a Standardized Object	956
23.4	Adding Proprietary Object Types to BACnet	957
23.5	Restrictions on Extending BACnet	957
24	DELETED CLAUSE	958
25	REFERENCES	959
	ANNEX A - PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (NORMATIVE)	964
	ANNEX B - GUIDE TO SPECIFYING BACnet DEVICES (INFORMATIVE)	967

ANNEX C - Removed	968
ANNEX D - Removed	969
ANNEX E - EXAMPLES OF BACnet APPLICATION SERVICES (INFORMATIVE).....	970
E.1 Alarm and Event Services	970
E.2 File Access Services	974
E.3 Object Access Services.....	976
E.4 Remote Device Management Services	982
E.5 Virtual Terminal Services.....	986
ANNEX F - EXAMPLES OF APDU ENCODING (INFORMATIVE)	988
F.1 Example Encodings for Alarm and Event Services	988
F.2 Example Encodings for File Access Services.....	999
F.3 Example Encodings for Object Access Services	1001
F.4 Example Encodings for Remote Device Management Services.....	1011
F.5 Example Encodings for Virtual Terminal Services	1017
ANNEX G - CALCULATION OF CRC (INFORMATIVE).....	1020
G.1 Calculation of the Header CRC	1020
G.2 Calculation of the Data CRC	1026
G.3 Calculation of the Encoded CRC-32K.....	1030
ANNEX H - COMBINING BACnet NETWORKS WITH NON-BACnet NETWORKS (NORMATIVE)	1034
H.1 BACnet Gateways.....	1034
H.2 Requirements and Best Practices for BACnet Gateway Implementations.....	1034
H.3 Using BACnet with the DARPA Internet Protocols	1036
H.4 Using BACnet with the IPX Protocol.....	1038
H.5 Using BACnet with EIB/KNX.....	1039
H.6 Using BACnet with the Former BACnet/WS Web Services Interface Definition by Annex N.....	1048
H.7 Virtual MAC Addressing.....	1050
ANNEX I - COMMANDABLE PROPERTIES WITH MINIMUM ON AND OFF TIMES (INFORMATIVE).....	1052
ANNEX J - BACnet/IP (NORMATIVE)	1054
J.1 General.....	1054
J.2 BACnet Virtual Link Layer.....	1054
J.3 BACnet/IP Directed Messages.....	1058
J.4 BACnet/IP Broadcast Messages.....	1058
J.5 Addition of Foreign B/IP Devices to an Existing BACnet Network.....	1060
J.6 Routing Between B/IP and non-B/IP BACnet Networks.....	1061
J.7 Routing Between Two B/IP BACnet Networks	1062
J.8 Use of IP Multicast within BACnet/IP.....	1067
ANNEX K - BACnet INTEROPERABILITY BUILDING BLOCKS (BIBBs) (NORMATIVE).....	1069
K.1 Data Sharing BIBBs.....	1069
K.2 Alarm and Event Management BIBBs.....	1087
K.3 Scheduling BIBBs.....	1099
K.4 Trending BIBBs.....	1103
K.5 Device Management BIBBs.....	1106
K.6 Network Management BIBBs.....	1112
K.7 Gateway BIBBs.....	1115
K.8 Audit Reporting BIBBs.....	1115
ANNEX L - DESCRIPTIONS AND PROFILES OF STANDARDIZED BACnet DEVICES (NORMATIVE).....	1118
L.1 Operator Interface Profiles	1118
L.2 Life Safety Operator Interface Profiles	1120
L.3 Access Control Operator Interface Profiles.....	1123
L.4 Controller Profiles.....	1125
L.5 Life Safety Controller Profiles	1128
L.6 Access Control Controller Profiles.....	1129
L.7 Miscellaneous Profiles	1131
L.8 BACnet General (B-GENERAL) Profile	1134
L.9 Lighting Operator Interface Profiles.....	1135
L.10 Lighting Control Station Profiles	1136

L.11 Lighting Controller Profiles	1137
L.12 Elevator Operator Interface Profiles.....	1139
L.13 Elevator Controller Profiles.....	1141
ANNEX M - GUIDE TO EVENT NOTIFICATION PRIORITY ASSIGNMENTS (INFORMATIVE).....	1144
M.1 Life Safety Message Group (0 - 31).....	1144
M.2 Property Safety Message Group (32 - 63).....	1145
M.3 Supervisory Message Group (64 - 95).....	1145
M.4 Trouble Message Group (96 - 127).....	1146
M.5 Miscellaneous Higher Priority Message Group (128 - 191).....	1146
M.6 Miscellaneous Lower Priority Message Group (192 - 255).....	1147
ANNEX N - FORMER BACnet/WS WEB SERVICES INTERFACE (INFORMATIVE)	1148
N.1 Data Model	1148
N.2 Paths.....	1149
N.3 Normalized Points.....	1149
N.4 Reference Nodes	1150
N.5 Localization	1150
N.6 Security	1150
N.7 Sessions.....	1151
N.8 Attributes	1151
N.9 Standard Nodes	1156
N.10 Encodings.....	1156
N.11 Service Options.....	1157
N.12 Services.....	1160
N.13 Errors	1176
N.14 Extending BACnet/WS	1177
ANNEX O - BACnet OVER ZigBee AS A DATA LINK LAYER (NORMATIVE).....	1178
O.1 General.....	1178
O.2 ZigBee Overview	1178
O.3 Definitions	1179
O.4 Unicast Addressing	1179
O.5 Broadcast Addressing	1179
O.6 BACnet/ZigBee Data Link Layer (BZLL).....	1179
O.7 Maximum Payload Size	1182
O.8 Vendor Specific Commands	1182
ANNEX P - BACnet ENCODING OF STANDARD AUTHENTICATION FACTOR FORMATS (NORMATIVE)	1183
ANNEX Q - XML DATA FORMATS (NORMATIVE)	1188
Q.1 Introduction.....	1188
Q.2 XML Document Structure	1191
Q.3 Expressing Data	1195
Q.5 Expressing Values.....	1196
Q.6 Binary Encoding and Access Rules	1197
Q.7 Extensibility	1198
Q.8 BACnet URI Scheme.....	1198
ANNEX R - MAPPING NETWORK LAYER ERRORS (NORMATIVE)	1200
ANNEX S - Removed	1201
ANNEX T - COBS (CONSISTENT OVERHEAD BYTE STUFFING) FUNCTIONS (INFORMATIVE).....	1202
T.1 Preparing a COBS-Encoded MS/TP Frame for Transmission	1202
T.2 Decoding an Extended MS/TP Frame upon Reception.....	1204
T.3 Example COBS-Encoded Frame - Who-Has Service.....	1206
ANNEX U - BACnet/IPv6 (NORMATIVE).....	1208
U.1 General.....	1208
U.2 BACnet/IPv6 BACnet Virtual Link Layer.....	1209
U.3 BACnet/IPv6 Directed Messages.....	1213
U.4 BACnet/IPv6 Broadcast Messages	1213
U.5 BACnet /IPv6 VMAc Table Management.....	1218
ANNEX V - MIGRATION FROM SOAP SERVICES (INFORMATIVE)	1219

V.1 Services.....	1219
V.2 Service Options.....	1221
ANNEX W - BACnet/WS RESTful WEB SERVICES INTERFACE (NORMATIVE).....	1222
W.1 Data Model.....	1222
W.2 Paths.....	1222
W.3 Security.....	1223
W.4 Sessions.....	1232
W.5 Standard Data Items.....	1232
W.6 Metadata.....	1236
W.7 Functions.....	1236
W.8 Query Parameters.....	1238
W.9 Representation of Data.....	1240
W.10 Representation of Metadata.....	1241
W.11 Representation of Logs.....	1241
W.12 Filtering Items.....	1246
W.13 Limiting Number of Items.....	1248
W.14 Selecting Children.....	1248
W.15 Controlling Content of Data Representations.....	1249
W.16 Specifying Ranges.....	1252
W.17 Localized Values.....	1254
W.18 Accessing Individual Tags and Bits.....	1254
W.19 Semantics.....	1255
W.20 Links and Relationships.....	1255
W.21 Foreign XML and Other Media Types.....	1255
W.22 Logical Modeling.....	1256
W.23 Mapped Modeling.....	1256
W.24 Commandability.....	1256
W.25 Writability and Visibility.....	1257
W.26 Working with Optional Data.....	1258
W.27 Working with Optional Metadata.....	1259
W.28 Creating Data.....	1259
W.29 Setting Data.....	1260
W.30 Deleting Data.....	1262
W.31 Parentally Inherited Values.....	1262
W.32 Concurrency Control.....	1262
W.33 Server Support for Data Definitions.....	1263
W.34 Server Support for Metadata.....	1263
W.35 Client Implementation Guidelines.....	1264
W.36 Subscriptions.....	1264
W.37 Reading Multiple Resources.....	1266
W.38 Writing Multiple Resources.....	1267
W.39 Mapping of BACnet Systems.....	1268
W.40 Errors.....	1271
W.41 Examples.....	1273
ANNEX X - EXTENDED DISCOVERY OF DEVICES, PROFILES, AND VIEWS (NORMATIVE).....	1301
X.1 Profiles.....	1301
X.2 xdd Files.....	1302
X.3 Example of Definition of Objects, Properties, and Datatypes.....	1303
X.4 Views.....	1305
X.5 ACS Declarations.....	1310
ANNEX Y - ABSTRACT DATA MODEL (NORMATIVE).....	1311
Y.1 Model Components.....	1311
Y.2 Trees.....	1313
Y.3 Base Types.....	1315
Y.4 Common Metadata.....	1315
Y.5 Named Values.....	1328

Y.6 Named Bits	1331
Y.7 Primitive Values	1332
Y.8 Range Restrictions	1334
Y.9 Engineering Units	1336
Y.10 Length Restrictions	1337
Y.11 Collections	1338
Y.12 Primitive Data	1341
Y.13 Constructed Data	1344
Y.14 Data of Undefined Type	1345
Y.15 Logical Modeling	1346
Y.16 Links	1348
Y.17 Change Indications	1350
Y.18 Definitions, Types, Instances, and Inheritance	1350
Y.19 Data Revisions	1356
Y.20 BACnet-Specific Base Types	1359
Y.21 BACnet-Specific Metadata	1360
ANNEX Z - JSON DATA FORMATS (NORMATIVE)	1363
Z.1 Introduction	1363
Z.2 JSON Document Structure	1366
Z.3 Expressing Data	1369
Z.4 Expressing Metadata	1369
Z.5 Expressing Values	1370
Z.6 Extensibility	1372
ANNEX AA – TIME SERIES DATA EXCHANGE FILE FORMAT (NORMATIVE)	1374
AA.1 File Format	1374
AA.2 Representation of Data	1374
AA.3 File Generation	1375
AA.4 Example Files	1375
ANNEX AB – BACnet Secure Connect (NORMATIVE)	1377
AB.1 BACnet Secure Connect Data link	1377
AB.2 BACnet/SC Virtual Link Layer Messages	1383
AB.3 BACnet/SC Node Operation	1393
AB.4 Node Switch and Direct Connections	1395
AB.5 Hub Function and Hub Connector	1397
AB.6 BACnet/SC Connections	1401
AB.7 Application of WebSockets in BACnet/SC	1405
HISTORY OF REVISIONS	1411

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2020 ASHRAE

180 Technology Parkway NW · Peachtree Corners, GA 30092 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ANSI is a registered trademark of the American National Standards Institute.

BACnet is a registered trademark in the U.S. Patent & Trademark Office, owned by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc.

FOREWORD

BACnet, the ASHRAE building automation and control networking protocol, has been designed specifically to meet the communication needs of building automation and control systems for applications such as heating, ventilating, and air-conditioning control, lighting control, access control, and fire detection systems. The BACnet protocol provides mechanisms by which computerized equipment of arbitrary function may exchange information, regardless of the particular building service it performs. As a result, the BACnet protocol may be used by head-end computers, general-purpose direct digital controllers, and application specific or unitary controllers with equal effect.

The motivation for this Standard was the widespread desire of building owners and operators for "interoperability," the ability to integrate equipment from different vendors into a coherent automation and control system - and to do so competitively. To accomplish this, the Standard Project Committee (SPC) solicited and received input from dozens of interested firms and individuals; reviewed all relevant national and international data communications standards, whether de facto or the result of committee activity; and spent countless hours in debate and discussion of the pros and cons of each element of the protocol.

What has emerged from the committee deliberations is a network protocol model with these principal characteristics:

(a) All network devices (except MS/TP slaves) are peers, but certain peers may have greater privilege and responsibilities than others.

(b) Each network device is modeled as a collection of network-accessible, named entities called "objects." Each object is characterized by a set of attributes or "properties." While this Standard prescribes the most widely applicable object types and their properties, implementors are free to create additional object types if desired. Because the object model can be easily extended, it provides a way for BACnet to evolve in a backward compatible manner as the technology and building needs change.

(c) Communication is accomplished by reading and writing the properties of particular objects and by the mutually acceptable execution of other protocol "services." While this Standard prescribes a comprehensive set of services, mechanisms are also provided for implementors to create additional services if desired.

(d) Because of this Standard's adherence to the ISO concept of a "layered" communication architecture, the same messages may be exchanged using various network access methods and physical media. This means that BACnet networks may be configured to meet a range of speed and throughput requirements with commensurately varying cost. Multiple BACnet networks can be interconnected within the same system forming an internetwork of arbitrarily large size. This flexibility also provides a way for BACnet to embrace new networking technologies as they are developed.

BACnet was designed to gracefully improve and adapt to both computer technology and demands of building automation systems change. Upon its original publication in 1995, a Standing Standards Project Committee was formed to deliberate enhancements to the protocol under ASHRAE rules for "continuous maintenance." Much has happened since the BACnet standard was first promulgated. BACnet has been translated into Chinese, Japanese, and Korean, and embraced across the globe. BACnet devices have been designed, built and deployed on all seven continents. Suggestions for enhancements and improvements have been continually received, deliberated, and ultimately, subjected to the same consensus process that produced the original standard. This publication is the result of those deliberations and brings together all of the corrections, refinements, and improvements that have been adopted.

Among the features that have been added to BACnet are: increased capabilities to interconnect systems across wide area networks using Internet Protocols, new objects and services to support fire detection, other life safety applications, lighting, physical access control, and elevator monitoring, capabilities to backup and restore devices, standard ways to collect trend data, new tools to make specifying BACnet systems easier, a mechanism for making interoperable extensions to the standard visible, and many others. The successful addition of these features demonstrates that the concept of a protocol deliberately crafted to permit extension of its capabilities over time as technology and needs change is viable and sound.

The latest update to this standard includes many new capabilities and several clarifications. These new capabilities include lighting and elevator device profiles that provide a standardized description for these types of devices along with audit reporting and logging to capture auditable actions. BACnet Secure Connect, a BACnet datalink layer, was also added. This datalink is fully compatible with all existing BACnet datalinks and provides an interoperable secure path for BACnet communications.

All communication protocols are, in the end, a collection of arbitrary solutions to the problems of information exchange and all are subject to change as time and technology advance. BACnet is no exception. Still, it is the hope of those who have contributed their time, energies, and talents to this work that BACnet will help to fulfill, in the area of building automation and control, the promise of the information age for the public good!

Currently in preview, click buy full versi

1 PURPOSE

The purpose of this standard is to define data communication services and protocols for computer equipment used for monitoring and control of HVAC&R and other building systems and to define, in addition, an abstract, object-oriented representation of information communicated between such equipment, thereby facilitating the application and use of digital control technology in buildings.

2 SCOPE

2.1 This protocol provides a comprehensive set of messages for conveying encoded binary, analog, and alphanumeric data between devices including, but not limited to:

- (a) hardware binary input and output values,
- (b) hardware analog input and output values,
- (c) software binary and analog values,
- (d) text string values,
- (e) schedule information,
- (f) alarm and event information,
- (g) files, and
- (h) control logic.

2.2 This protocol models each building automation and control computer as a collection of data structures called "objects," the properties of which represent various aspects of the hardware, software, and operation of the device. These objects provide a means of identifying and accessing information without requiring knowledge of the details of the device's internal design or configuration.

3 DEFINITIONS

3.1 Terms Adopted from International Standards

The following terms used in this standard are defined by international standards or draft standards for open system interconnection (OSI). The definitions are repeated here and a reference to the appropriate standard is provided. Clause 25 contains the titles of all national and international standards referenced in this clause and elsewhere in this standard. Words or phrases in italics refer to terms defined elsewhere in this clause.

abstract syntax: the specification of application layer data or application-protocol-control-information by using notation rules which are independent of the encoding technique used to represent them (ISO 8822).

application: a set of a USER's information processing requirements (ISO 8649).

application-entity: the aspects of an application-process pertinent to OSI (ISO 7498).

application-process: an element within a real open system which performs the information processing for a particular application (ISO 7498).

application-protocol-control-information: information exchanged between application-entities, using presentation services, to coordinate their joint operation (ISO 9545).

application-protocol-data-unit: a unit of data specified in an application protocol and consisting of application-protocol-control-information and possibly application-user-data (ISO 9545).

application-service-element: that part of an application-entity which provides an OSI environment capability, using underlying services when appropriate (ISO 7498).

concrete syntax: those aspects of the rules used in the formal specification of data which embody a specific representation of that data (ISO 7498).