

CONTENTS
ANSI/ASHRAE Standard 154-2022
Ventilation for Commercial Cooking Operations

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions	2
4 Exhaust Hoods	6
5 Exhaust Systems	11
6 Replacement Air	14
7 System Controls	15
8 Administration and Compliance	15
9 References	15
Informative Appendix A: Examples of Air Balancing	17
Informative Appendix B: Alternative Airflow Calculation Method	20
Informative Appendix C: Hood Energy Savings Calculation	22
Informative Appendix D: Using ASHRAE Standard 154 to Determine Hood Overhangs and Exhaust Airflows	24
Informative Appendix E: Examples of Fan Types Used in Type 1 Exhaust Applications	27
Informative Appendix F: Pollution Control Unit Used in Type 1 Exhaust Applications	31
Informative Appendix G: Informative References and Bibliography	32
Informative Appendix H: Addenda Description	33

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2022 ASHRAE

180 Technology Parkway · Peachtree Corners, GA 30092 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ASHRAE Standard 154 provides design criteria for acceptable performance in commercial cooking ventilation systems and is intended to serve as a template for standardization, harmonization, and ongoing revision of related model and adopted codes and to bring consistency to design requirements and applications of commercial kitchen ventilation systems.

The 2022 revision includes numerous changes to harmonize the standard with the International Mechanical Code® (IMC), 2019 ASHRAE Handbook—HVAC Applications, and NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations. For a complete description of these and other changes, see Informative Appendix H.

1. PURPOSE

The purpose of this standard is to provide design criteria for acceptable performance in commercial cooking ventilation systems.

2. SCOPE

2.1 This standard covers

- a. kitchen hoods,
- b. exhaust systems, and
- c. replacement air systems.

2.2 This standard shall not be used to circumvent any safety, health, or environmental requirements.

3. DEFINITIONS

appliance: a cooking device or apparatus used in a kitchen that consumes energy provided by gas, electricity, solid fuel, steam, or another fuel source.

appliance duty level: an appliance rating category based on the exhaust airflow required to capture, contain, and remove the cooking effluent and products of combustion under typical operating conditions with a non-engineered wall-mounted canopy hood (based on ASHRAE RP-1362¹). This is different from the historical approach in which duty levels were based on the temperature of the cooking surface. The following appliance duty classifications are used in this standard:

- a. **light:** a cooking process requiring an exhaust airflow rate of less than 200 cfm/ft (310 L/s/m) for capture, containment, and removal of the cooking effluent and products of combustion.
- b. **medium:** a cooking process requiring an exhaust airflow rate of 200 to 300 cfm/ft (310 to 460 L/s/m) for capture, containment, and removal of the cooking effluent and products of combustion.
- c. **heavy:** a cooking process requiring an exhaust airflow rate of 300 to 400 cfm/ft (460 to 620 L/s/m) for capture, containment, and removal of the cooking effluent and products of combustion.
- d. **extra-heavy:** a cooking process requiring an exhaust airflow rate greater than 400 cfm/ft (620 L/s/m) for capture, containment, and removal of the cooking effluent and products of combustion.

approved: acceptable to the authority having jurisdiction.

balancing damper: a mechanical device located in a duct that is intended to regulate airflow.

capture area: area within an exhaust hood that contains cooking effluent until it is exhausted.

capture and containment: an exhaust hood's ability to capture and contain the cooking effluent and heat generated during cooking operations.

centrifugal fan: see *exhaust fan*.

certified: see *listed*.

commercial cooking appliance: an appliance specifically designed to be used in a food service establishment kitchen, such as a restaurant or cafeteria kitchen. Appliances designed for residential use shall be treated as commercial appliances when installed in commercial food service establishments.