

CONTENTS
ANSI/ASHRAE Standard 22-2023
Methods of Testing for Rating Liquid-Cooled Refrigerant Condensers

SECTION	PAGE
Foreword	2
1 Purpose.....	2
2 Scope.....	2
3 Definitions	2
4 Required Test Results.....	2
5 Test Methods	3
6 Instruments and Test Apparatus.....	6
7 test Procedure.....	7
8 References.....	8
Informative Appendix A: Uncertainty Analysis.....	10
Informative Appendix B: Method to Compute the Enthalpy Difference of a Liquid Stream When an EoS-based Function Is not Available	15
Informative Appendix C: Method for Determining the Presence of Noncondensable Gases in Liquid-Cooled Refrigerant Condensers	20
Online Supporting Files: www.ashrae.org/XXXX	

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2023 ASHRAE

180 Technology Parkway · Peachtree Corners, GA 30092 · www.ashrae.org · All rights reserved.
ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ASHRAE Standard 22 prescribes methods for testing liquid-cooled refrigerant condensers. To attain this objective, the standard lists and defines the terms for rating liquid-cooled refrigerant condensers and establishes testing methods that are to be used as a basis for obtaining ratings of liquid-cooled refrigerant condensers.

This standard was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry.

The uncertainty analysis methodology discussed in Informative Appendix A has been incorporated into a Microsoft Excel[®] workbook that can be downloaded online at www.ashrae.org/XXXX.

1. PURPOSE

This standard prescribes methods of testing the thermal performance and liquid-side pressure drop of liquid-cooled refrigerant condensers.

2. SCOPE

This standard applies to the methods of testing for thermodynamic performance rating of liquid-cooled refrigerant condensers that operate at subcritical pressures of the refrigerant.

3. DEFINITIONS

condensing heat rejection (q_c): the portion of the total heat rejection of a condenser that is used for desuperheating and condensing the entering refrigerant vapor to a saturated liquid. This is the product of the mass rate of refrigerant flow (w_r) and the difference between the enthalpy of the entering refrigerant vapor and that of the saturated refrigerant liquid at the leaving pressure.

liquid-cooled refrigerant condenser: a factory-made assembly of elements by which the flows of refrigerant vapor and cooling liquid are maintained in such a heat transfer relationship that the refrigerant vapor is condensed into a liquid.

subcooling: the difference between the bubble-point temperature of the refrigerant corresponding to the pressure of the refrigerant leaving the condenser and the measured refrigerant temperature leaving the condenser.

subcooling heat rejection (q_s): the total heat rejection minus the condensing heat rejection. This is the product of the mass rate of refrigerant flow (w_r) and the difference between the enthalpy of a saturated refrigerant liquid at the pressure of the leaving refrigerant and that of the refrigerant liquid at the actual leaving temperature.

superheat: the difference between the measured refrigerant temperature entering the condenser and the dew-point temperature of the refrigerant corresponding to the pressure of the refrigerant entering the condenser.

total heat rejection (q_t): the total useful capacity of a liquid-cooled refrigerant condenser for removing heat from the refrigerant circulated through it. This is the product of the mass rate of refrigerant flow (w_r) and the difference of enthalpy of the entering and leaving refrigerant fluid.

uncertainty: an estimated value for the error in a measurement, which may be the result of both systematic and random error.

4. REQUIRED TEST RESULTS

4.1 In expressing test results, the following parameters shall be stated:

- a. Condensing heat rejection (q_c), kW (Btu/h)
- b. Subcooling heat rejection (q_s), kW (Btu/h)
- c. Total heat rejection (q_t), kW (Btu/h)
- d. Dew-point temperature (T_c) of entering refrigerant vapor, °C (°F)
- e. Temperature of entering refrigerant vapor, °C (°F)
- f. Temperature of leaving refrigerant liquid, °C (°F)