

CONTENTS
ANSI/ASHRAE Standard 41.11-2020
Standard Methods for Power Measurement

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions	2
4 Classifications	4
5 Requirements	5
6 Instruments	8
7 Test Methods	9
8 Uncertainty Calculations	16
9 Test Report	17
10 References	18
Informative Appendix A: Informative References and Bibliography	19
Informative Appendix B: Power Measurement Basics	20
Informative Appendix C: An Uncertainty Analysis Example for the Input and Output Power of a Variable-Frequency Drive	23

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2020 ASHRAE

180 Technology Parkway NW · Peachtree Corners, GA 30092 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Whether electrical power measurements are to be taken in a laboratory or in the field, selecting the appropriate instruments and components should be based on the required measurement accuracy. Once an instrument has been selected, the user may need to consult with the instrument manufacturer regarding installation specifics, operating range limits, calibration limits, and other similar performance specifics in order to obtain the expected measurement accuracy.

Working with electricity can be hazardous. Users of this standard are cautioned to obtain appropriate electrical safety training and equipment at the outset. For example, NFPA 70E-2009, Standard for Electrical Safety in the Workplace, and OSHA 29 CFR 1910, Subpart S describe all of the safety equipment required to perform energized equipment measurements, including arc-flash protection, approach boundaries, and other personal protective equipment.

The 2020 revision of Standard 41.11 incorporates minor changes and complies with ASHRAE's mandatory language requirements.

1. PURPOSE

This standard prescribes methods for power measurements.

2. SCOPE

This standard applies to power measurements under laboratory and field conditions when testing heating, ventilating, air-conditioning, and refrigerating systems and components.

3. DEFINITIONS

accuracy: the degree of conformity of an indicated value to the corresponding true value.

active power: see *power, active*.

apparent power: see *power, apparent*.

constant-speed drive (CSD): a device fitted between a rotating power source and the rotating load to achieve constant rotational speed regardless of the power source rotational speed. Compare to *variable-speed drive*.

crest factor: the ratio of peak value to root-mean-square (RMS) value of a waveform.

current shunt: a low-resistance device used to measure current in a circuit. Measure the voltage and apply Ohm's Law to calculate the current.

current transducer: a current transducer (sensor) is a device that detects electrical current (AC or DC) in a conductor and generates a signal proportional to it. The combinations of sensed current and the output signal are as follows:

- a. Alternating current (AC) input with
 1. analog output that duplicates the wave shape of the sensed current.
 2. bipolar output that duplicates the wave shape of the sensed current.
 3. unipolar output that is proportional to the average or RMS value of the sensed current.
- b. Direct current (DC) input with
 1. unipolar output that duplicates the wave shape of the sensed current.
 2. digital output that switches where the sensed current exceeds a certain threshold.

current transformer (CT): an instrument transformer intended to have its primary winding connected in series with a circuit carrying the current to be measured or controlled; the current is measured across the secondary winding.

energy: capability to do work, J (ft·lb_f). Forms include chemical, electrical, mechanical, and thermal. Energy may be either stored or transient and can be transformed from one form into another. Compare to *power*.

error: difference between the test result and its corresponding true value.