CONTENTS

ANSI/ASHRAE Standard 41.9-2021
Standard Methods for Refrigerant Mass Flow Measurements Using Calorimeters

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This revision of Standard 41.9 is a comprehensive update and meets ASHRAE's mandatory language requirements. The most significant changes are to steady-state criteria and the lubricant circulation rate measurement methods.

1. PURPOSE

This standard prescribes methods for measuring mass flow rates for refrigerants and refrigerant/lubricant mixtures using calorimeters.

2. SCOPE

2.1 This standard applies to measuring mass flow rates for refrigerants and refrigerant/lubricant mixtures using calorimeters in laboratories.

2.2 This standard applies where the entire flow stream of the refrigerant or the refrigerant/lubricant mixture enters the calorimeter as a subcooled liquid and leaves as a superheated vapor (evaporator type).

2.3 This standard applies where the entire flow stream of the refrigerant or the refrigerant/lubricant mixture enters the calorimeter as a superheated vapor and leaves as a subcooled liquid (condenser type).

3. DEFINITIONS

The following definitions apply to the terms used in this standard.

accuracy: the degree of conformity of an indicated value to the corresponding true value.

calorimeter: a thermally insulated apparatus containing a heat exchanger that determines refrigerant mass flow rate by measuring the heat input/output that will result in a known enthalpy change for the refrigerant.

error: the difference between the test result and its corresponding true value.

lubricant circulation rate: the ratio of the mass of lubricant circulating through a refrigerant system to the total mass of refrigerant and lubricant flowing through the system at a specified set of operating conditions.

measurement system: the instruments, signal conditioning systems (if any), and data acquisition system (if any).

operating tolerance limit: the upper or lower value of an operating tolerance that is associated with a test point or a targeted set point.

random error: the portion of the total error that varies randomly in repeated measurements of the true value throughout a test process.

refrigerant mass flow rate: the mass flow rate of refrigerant potentially mixed with lubricant.

secondary fluid: a fluid of known properties that is used as a heating medium.

secondary refrigerant: a refrigerant of known properties that is used as a heating medium.

subcooling: at a defined pressure, the difference between a given liquid temperature and the bubble-point temperature.

superheat: at a defined pressure, the difference between a given vapor temperature and the dew-point temperature.

systematic error: the portion of the total error that remains constant in repeated measurements of the true value throughout a test process.

targeted set point: a specific set of test conditions where the required refrigerant mass flow rate is known and has an associated operating tolerance.