

**CONTENTS**  
**ANSI/ASHRAE Standard 63.2-2024**  
**Method of Testing Liquid-Line Filter Drier Filtration Capability**

<b>SECTION</b>	<b>PAGE</b>
Foreword .....	2
1 Purpose .....	2
2 Scope .....	2
3 Definitions .....	2
4 Materials and Apparatus .....	3
5 Test to Determine Accuracy of Test System .....	4
6 Procedure .....	5
7 Calculation of Results .....	5
Informative Appendix A: Sample Calculation .....	7
Informative Appendix B: Bibliography .....	8

**NOTE**

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at [www.ashrae.org/technology](http://www.ashrae.org/technology).

© 2024 ASHRAE

180 Technology Parkway · Peachtree Corners, GA 30092 · [www.ashrae.org](http://www.ashrae.org) · All rights reserved.  
ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.  
ANSI is a registered trademark of the American National Standards Institute.

**(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)**

## FOREWORD

*ANSI/ASHRAE Standard 63.2 prescribes a method for measuring the filtration capability of liquid-line filters and filter driers for use in refrigerant systems.*

*It is recognized that the test contaminant, test fluid, test equipment, and method in the prescribed test do not fully represent the conditions that can exist in the liquid line of a refrigerant system. The specified test contaminant was chosen as the most nearly representative controlled-particle-size test contaminant commercially available. The wide range of controlled particle sizes used provides a satisfactory degree of repeatability of test results. However, it is recognized that seldom, if ever, will the composition, particle size, and mix of the test contaminant be duplicated in an actual system. Therefore, the filtration capability of a filter determined by this test does not necessarily predict its exact capability in actual service in a refrigerant liquid line. This test, however, serves as a useful means of comparing filter capabilities and implementing quality control to maintain uniformity of products.*

*The 2024 edition of Standard 63.2 includes updates to Informative Appendix B, "Bibliography." This standard was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform standards throughout the industry.*

## 1. PURPOSE

The purpose of this standard is to prescribe a laboratory test method for evaluating the filtration capability of filters and filter driers used in liquid lines of refrigeration systems.

## 2. SCOPE

**2.1** This laboratory test method evaluates the capability of liquid-line filters and filter driers only for removing and retaining solid particles of a standard test contaminant.

**2.2** The test method may be applied to all hermetic refrigerant liquid-line filters and filter driers.

**2.3** The technique employed in this standard is the one-pass test method. In this test, a clean-up filter is installed downstream of the test sample and is designed to retain and prevent recirculation of the majority of the contaminant particles that are not collected by the test sample in the first pass.

**2.4** Filter driers have the added capability of removing and retaining certain dissolved contaminants. This standard does not provide measurement of this capability.

## 3. DEFINITIONS

**clean-up filter loading ( $M_{cp}$ ):** mass in grams of test contaminant that is retained on the clean-up filter.

**contaminant capacity ( $M_c$ ):** mass in grams of test contaminant that is retained by the filter under test.

**contaminant loading ( $M_t$ ):** total mass in grams of test contaminant that is added to the test apparatus.

**contaminant loading end point ( $M_e$ ):** total mass in grams of test contaminant added that achieved the target end-point pressure drop

**end-point pressure drop:** the filter pressure drop across the filter under test at the concluding point of the testing.

**filter efficiency ( $E_f$ ):** contaminant capacity divided by contaminant loading, expressed as a percent.

**filter pressure drop ( $\Delta P$ ):** the difference in pressure between the filter inlet and filter outlet, including fitting, expressed in kilopascals.

**filter under test:** liquid-line filter or liquid-line filter drier that is under evaluation.

**liquid-line filter:** a device for removing and retaining solid contaminants from the liquid line of a refrigeration system.

**liquid-line filter drier:** a filter containing a desiccant capable of removing moisture and other dissolved contaminants in the refrigerant stream.

**test flow rate:** the flow of clean test fluid, expressed in kilograms per second, that is specified for the filter under test.