

ASME A112.4.3-1999

PLASTIC FITTINGS FOR CONNECTING WATER CLOSETS TO THE SANITARY DRAINAGE SYSTEM

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers

Intentionally left blank



The American Society of
Mechanical Engineers

A N A M E R I C A N N A T I O N A L S T A N D A R D

PLASTIC FITTINGS FOR CONNECTING WATER CLOSETS TO THE SANITARY DRAINAGE SYSTEM

ASME A112.4.3-1999

Date of Issuance: September 30, 1999

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda or written interpretations of the requirements of this Standard issued to this edition.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable Letters Patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations issued in accordance with governing ASME procedures and policies which precludes the issuance of interpretations by individual volunteers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 1999 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All Rights Reserved
Printed in U.S.A.

FOREWORD

The axiom “a chain is only as strong as its weakest link” can be applied to the sanitary drainage system. Modern manufacturing practices, along with material, dimensional, and performance standards, have resulted in sanitary drainage systems that safely convey sanitary waste to the collection system. While major improvements have been made in the systems, materials, and connections methods, however, a “weak link” still exists: the connection between the water closet and the sanitary drainage system.

Historically, the connection has been made with “plumbers putty” and, in more recent years, a pre-formed wax-type mastic. The joint connection is on the sewer side of the water closet trap where the material and performance standards of the soil, waste, and vent system apply. However, no existing standard addresses the water closet to drain connection. Since any leak in this connection would allow sewer gas and micro-organisms to enter a building, and any leaking waste would contaminate the surrounding area and damage floors and ceilings, there is a need for requirements to cover this joint connection.

This Standard establishes the performance criteria necessary to insure a safe water and air-tight connection between the water closet and sanitary drainage system, consistent with present day plumbing material and performance standards.

Suggestions for improvement of this Standard will be welcomed. They should be sent to The American Society of Mechanical Engineers; Secretary, A112 Main Committee; Three Park Avenue; New York, NY 10016-5990.

This revision was approved as an American National Standard on January 28, 1999.

Intentionally left blank

ASME A112 COMMITTEE

Standardization of Plumbing Materials and Equipment

(The following is the roster of the Committee at the time of approval of this Standard.)

OFFICERS

P. J. Higgins, *Chair*
S. A. Remedios, *Vice Chair*
C. J. Gomez, *Secretary*

COMMITTEE PERSONNEL

R. H. Ackroyd, Consultant
J. A. Bellanco, JB Engineering & Code Consulting
S. L. Cavanaugh, United Association
A. Cohen, Copper Development Association, Inc.
P. V. DeMarco, American Standard, Inc.
G. S. Duren, Code Compliance, Inc.
R. Emmerson, Chicago Faucets Co.
F. C. Evans, Zin-Plas Corp.
L. S. Galowin, National Institute of Standards and Technology
C. J. Gomez, The American Society of Mechanical Engineers
R. I. Greenwald, Sunroc Corp.
P. J. Higgins, P. J. Higgins & Associates, Inc.
D. E. Holloway, United States Testing Co., Inc.
M. Klimboff, Consultant
R. M. Martin, California Energy Commission
S. Moinian, Moen, Inc.
R. E. Pamplona, U.S. Naval Construction Battalion Center
S. Rawalpindiwala, Kohler Co.
S. A. Remedios, Delta Faucet Co.
W. M. Smith, Jay R. Smith Manufacturing Co.
D. W. Viola, BOCA International
R. E. White, Consultant
W. C. Whitehead, PMI

PROJECT TEAM 4.3 — CLOSET SEALS

C. R. Adorjan, *Project Team Leader*, PREDCO
R. H. Ackroyd, Consultant
P. V. DeMarco, American Standard, Inc.
P. J. Higgins, P. J. Higgins & Associates
S. Rawalpindiwala, Kohler Co.
J. A. Sargent, Consultant

Intentionally left blank

CONTENTS

Foreword	iii
Standards Committee Roster	v
1 General	1
1.1 Scope	1
1.2 Units of Measurement	1
1.3 References	1
2 Physical Requirements	1
2.1 Size	1
2.2 Materials	2
3 Performance Requirements	2
3.1 Test Setup and Preparation	2
3.2 Joint Tightness	2
3.3 Perpendicular Misalignment (Variation)	3
4 Marking and Identification	3
Figures	
1 Test Stand	3
2 Test Fixture 1	4
3 Test Fixture 2	5
4 Test Fixture 3	6
5 Test Fixture 4	7
6 Test Fixture 5	8

Intentionally left blank

PLASTIC FITTINGS FOR CONNECTING WATER CLOSETS TO THE SANITARY DRAINAGE SYSTEM

1 GENERAL

1.1 Scope

This Standard establishes physical, performance, and testing requirements applicable to the joint that connects a water closet to the sanitary drain piping of a plumbing system.

The use of alternate materials or methods are permitted, provided the proposed material and method complies with the performance requirements and intent of this Standard.

1.2 Units of Measurement

Values are stated in U.S. Customary units, followed in parentheses by values stated in the International System of Units (SI). The U.S. Customary units shall be considered as the standard.

1.3 References

The following is a list of publications referenced in this Standard.

ASME A112.19.2M, Vitreous China Plumbing Fixtures

Publisher: The American Society of Mechanical Engineers (ASME), Three Park Avenue, New York, NY 10016-5990; Order Department: 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300

ASTM A 53-97, Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless

ASTM A 888-96, Specification for Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drain, Waste, and Vent Piping Applications

ASTM B 302-97, Specification for Threadless Copper Pipe

ASTM D 1784-97, Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds

ASTM D 1785-96b, Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120

ASTM D 2949-97, Specification for 3.25-in. Outside Diameter Poly(Vinyl Chloride) (PVC) Plastic Drain, Waste, and Vent Pipe and Fittings

ASTM D 3965-94, Specification for Rigid Acrylonitrile-Butadiene-Styrene (ABS) Compounds for Pipe and Fittings

ASTM D 5926-96, Specification for Poly(Vinyl Chloride) (PVC) Gaskets for Drain, Waste, and Vent (DWV) Sewer, Sanitary, and Storm Plumbing Systems

Publisher: American Society for Testing and Materials (ASTM), 100 Barr Harbor Drive, West Conshohocken, PA 19428

CISPI 310, Specification for Couplings Used to Connect Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drain, Waste, and Vent Piping Applications

Publisher: Cast Iron Soil Pipe Institute (CISPI), 5959 Shallowford Road, Chattanooga, TN 37421

CSA B70, Cast Iron Soil Pipe, Fittings, and Means of Joining

CSA B181.1, ABS Drain, Waste, and Vent Pipe and Pipe Fittings

CSA B181.2, PVC Drain, Waste, and Vent Pipe and Pipe Fittings

CSA B602, Mechanical Couplings for Drain, Waste, and Vent Pipe and Sewer Pipe

Publisher: Canadian Standards Association (CSA), 178 Rexdale Boulevard, Etobicoke (Toronto), Ontario, Canada MW 1R3

2 PHYSICAL REQUIREMENTS

2.1 Size

The joint (connection method, device, or fitting) shall accommodate all water closets that comply with the