

ASME B16.1-2020
(Revision of ASME B16.1-2015)

Gray Iron Pipe Flanges and Flanged Fittings

Classes 25, 125, and 250

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME B16.1-2020
(Revision of ASME B16.1-2015)

Gray Iron Pipe Flanges and Flanged Fittings

Classes 25, 125, and 250

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: November 9, 2020

The next edition of this Standard is scheduled for publication in 2025.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME B16 Committee may be published as Cases. Cases and interpretations are published on the ASME website under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME website under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be based on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures agreed to as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" an item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2020 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	i
Committee Roster	vi
Correspondence With the B16 Committee	vii
Summary of Changes	ix
List of Changes in Record Number Order	x
1 Scope	1
2 General	1
3 Pressure–Temperature Ratings	2
4 Size	2
5 Marking	2
6 Materials	3
7 Fitting Dimensions and Tolerances	3
8 Bolt, Nut, and Gasket Dimensions	5
9 Hydrostatic Tests	5
10 Certifications	5
 Mandatory Appendix	
I References	36
 Nonmandatory Appendix	
A Quality System Program	37
 Figures	
4.2-1 Method of Designating Outlets of Reducing Fittings in Specifications	7
7.9.1-1 Drain Connection	34
7.9.2-1 Method of Designating Location of Tapped Holes for Drains When Specified	35
 Tables	
3.1-1 Pressure–Temperature Ratings	6
7.3.2-1 Dimensions of Class 25 Gray Iron Flanged Fittings	8
7.3.2-2 Dimensions of Class 125 Gray Iron Flanged Fittings	12
7.3.2-3 Dimensions of Class 250 Gray Iron Flanged Fittings	18
7.3.2-4 Dimensions of Anchorage Bases for Straight and Reducing Class 125 Tees	23
7.3.2-5 Dimensions of Anchorage Bases for Straight and Reducing Class 250 Tees	27
7.6.1-1 Class 25 Flange and Bolting Dimensions	29
7.6.1-2 Class 125 Flange and Bolting Dimensions	30
7.6.1-3 Class 250 Flange and Bolting Dimensions	32
7.9.1-1 Minimum Thread Length	34

FOREWORD

In 1894, the American Society of Mechanical Engineers (ASME) adopted a standard flange template ("ASME Standard") for low-pressure service. A "Manufacturers Standard" for pressures up to 250 psi followed in 1901. Around 1910, a group of fittings manufacturers formed an organization that was the forerunner of the present Manufacturers Standardization Society of the Valve and Fittings Industry (MSS) and undertook the design of a line of flanged fittings. A document covering this work was published in 1912.

During the years 1912 through 1914, a Joint Committee of the ASME and the Manufacturers Committee formulated compromise standard dimensions for pipe flanges and flanged fittings for use under saturated steam pressures of 12.5 psi and 250 psi pressure ranges. The Joint Committee's report was accepted at a conference attended by representatives of ASME, the Manufacturers Committee, the U.S. government, and the National Association of Master Steam and Hot Water Fitters. ASME published this report as the "American Standard for Pipe Flanges, Fittings and Their Bolting" in 1914. In 1918, work was started on standards for 50-lb steam flanges and for 800-lb, 1,200-lb, and 3,000-lb hydraulic flanges, which were subsequently approved by this group.

In 1921, the American Engineering Standards Committee, later known as the American Standards Association (ASA), United States of America Standards Institute (USAS), and more recently, the American National Standards Institute (ANSI), organized Sectional Committee B16 to unify and further develop national standards for pipe flanges and fittings (and later for valves and gaskets). Cosponsors of the B16 Committee were ASME, MSS, and the Heating and Piping Contractors Association [now the Mechanical Contractors Association of America (MCAA)]. Work already in progress on flanges and flanged fittings was assigned to Subcommittee 1 (now Subcommittee A). Following approval by the Subcommittee, the B16 Committee, the cosponsors, and ASA, the standards were published in 1928.

In later work, Subcommittee 1 developed the 25-lb Flange and Flanged Fitting Standard (approved in 1931 as ASA B16b2), which replaced the 50-lb standard that had been originally approved in 1918. Work on the 800-lb Hydraulic Flange Standard was published as ASA B16b1 in 1931. Revision of thicknesses, tolerances, and service pressure ratings of the 125-lb and 250-lb flanges and flanged fittings led to approval and publication of ASA B16a-1939.

An American war standard entitled "Pressure Ratings for Cast Iron Flanges and Flanged Fittings, 125 lb" (ASA B16a1) was published in 1943. A complete review of the 125-lb and 250-lb standards resulted in new editions of each: ASA B16.1-1948 and ASA B16.2-1948. In 1960, editions of B16.1 and B16.2 were issued in which ratings were presented in graphic form and special requirements were added for testing flanges.

A review of all gray iron flange and flanged fittings standards initiated in 1962 resulted in the withdrawal of B16.16, "300 lb Refrigerant Flanges and Flanged Fittings," and the combining of the remaining standard into a single document, with B16.1 and B16.2 coming together as "ASA B16.1-1967. In this edition, the presentation of ratings was restored to tabular form.

The increasing use of higher grades of gray iron necessitated the establishment of a second set of ratings for the smaller sizes. A revised edition published as ANSI B16.1-1975 incorporated these new ratings along with metric (SI) equivalents for dimensions and minor corrections to the 1967 edition text.

In 1982, American National Standards Committee B16 was recognized as an ASME Committee operating under procedures accredited by ANSI. Following approval by the ASME B16 Subcommittee A and B16 Committee, ANSI approved ASME/ANSI B16.1-1989 on March 8, 1989. Changes included revised marking requirements, revised bolt length increments ($\frac{1}{2}$ in. rather than $\frac{3}{4}$ in.), elimination of metric equivalents, a correction of the Class 800 flange raised-face height to 0.25 in. from the 0.00 in. shown previously, and editorial changes to the text.

In the 1998 edition of ASME B16.1, Reference Standards were updated, a Quality System Program Annex was added, Class 800 was deleted, and several editorial revisions were made. Following approval by ASME B16 Subcommittee B and B16 Main Committee, ANSI approved ASME B16.1-1998 on November 20, 1998.

Work was started in 1999 to revise the standard to include metric units as the primary reference units while maintaining U.S. Customary units in either parenthetical or separate forms. Following approval of the Standard Committee and ASME approval as an American National Standard was given by ANSI on July 8, 2005, with the new designation ASME B16.1-2005.

In the 2010 edition of ASME B16.1, the Scope was separated into its own paragraph with all following paragraphs renumbered accordingly, references were updated, and several editorial revisions were made. Following approval of the B16 Standards Committee, approval as an American National Standard was given by ANSI on November 17, 2010.

In the 2015 Edition, provisions were made to provide bolt hole tolerances that are appropriate to this Standard. Following the approval by the ASME B16 Standards Committee, approval as an American National Standard was given by ANSI on July 29, 2015.

In ASME B16.1-2020, the U.S. Customary tables in former Mandatory Appendix I have been merged with the SI tables in the main text. The tables and figures have been redesignated, former Mandatory Appendix I has been deleted, and the subsequent Mandatory Appendix has been redesignated. Cross-references have been updated accordingly. Also in this edition, entries for NPS 66, 78, and 90 have been added to Table 7.6.1-2 (formerly Tables 9 and I-9), and the references in Mandatory Appendix I (formerly Mandatory Appendix II) have been updated. Following the approval by the ASME B16 Standards Committee, this revision to the 2015 edition was approved as an American National Standard by ANSI on July 24, 2020, with the new designation ASME B16.1-2020.

ASME B16 COMMITTEE

Standardization of Valves, Flanges, Fittings, Gaskets, and Valve Actuators

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

C. E. Davila, *Chair*
R. Bojarczuk, *Vice Chair*
C. Ramcharran, *Secretary*

STANDARDS COMMITTEE PERSONNEL

A. Appleton , Alloy Stainless Products Co., Inc.	E. J. Lain , Exelon Nuclear
J. Barker , Dezurik, Inc.	T. A. McMahon , Emerson Process Management
R. W. Barnes , Anric Enterprises, Inc.	R. C. Merrick , Fluor Enterprises
D. C. Bayreuther , Metso Automation	W. H. Patrick , The Dow Chemical Co.
W. B. Bedesem , Consultant	D. W. Raho , CCM
R. Bojarczuk , ExxonMobil Research and Engineering Co.	C. Ramcharran , The American Society of Mechanical Engineers
A. M. Cheta , Qatar Shell GTL	D. Reid , VSP Technologies
M. A. Clark , Consultant	R. A. Schmitt , Shell Oil
G. A. Cuccio , Capitol Manufacturing Co.	J. Seke , U.S. Group
J. D'Avanzo , Fluoroseal Valves	J. P. Tacke , Flowserve
C. E. Davila , Crane ChemPharma and Energy	F. F. Volstadt , Volstadt and Associates, Inc.
K. S. Felder , Valero Energy	J. D. ... , <i>Alternate</i> , DeZURIK APCO Hilton
D. R. Frikken , Becht Engineering Co.	P. V. Craig , <i>Contributing Member</i> , Jomar Group
J. R. Holstrom , Val-Matic Valve and Manufacturing Corp.	B. G. Fabian , <i>Contributing Member</i> , Pennsylvania Machine Works
D. Hunt, Jr. , Fastenal	A. C. Kireta, Jr. , <i>Contributing Member</i> , Copper Development Association, Inc.
G. A. Jolly , Samshin, Ltd.	

SUBCOMMITTEE B — THREADED FITTINGS (EXCEPT STEEL), FLANGES, AND FLANGED FITTINGS (B16)

D. Hunt, Jr. , <i>Chair</i> , Fastenal	M. A. Clark , Consultant
J. R. Holstrom , <i>Vice Chair</i> , Val-Matic Valve and Manufacturing Corp.	M. C. Coffey , Ward Manufacturing, LLC
R. Rahaman , <i>Secretary</i> , The American Society of Mechanical Engineers	R. Kelsey , Nibco, Inc.
J. Atkinson , Mueller Industries	W. H. LeVan , Cast Iron Soil Pipe Institute
W. Bliss , Tyler Pipe Co.	G. L. Simmons , Charlotte Pipe and Foundry
	G. T. Walden , Ferguson

CORRESPONDENCE WITH THE B16 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions or a case, and attending Committee meetings. Correspondence should be addressed to:

Secretary, B16 Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued to provide alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard and the paragraph, figure, or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

Interpretations. Upon request, the B16 Standards Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the B16 Standards Committee.

Requests for interpretation should preferably be submitted through the online Interpretation Submittal Form. The form is accessible at <http://go.asme.org/interpretationRequest>. Upon submittal of the form, the Inquirer will receive an automatic e-mail confirming receipt.

If the Inquirer is unable to use the online form, he/she may e-mail the request to the Secretary of the B16 Standards Committee at SecretaryB16@asme.org, or mail it to the above address. The request for an interpretation should be clear and unambiguous. It is further recommended that the Inquirer submit his/her request in the following format:

Subject: Cite the applicable paragraph number(s) and the topic of the inquiry in one or two words.
Edition: Cite the applicable edition of the Standard for which the interpretation is being requested.
Question: Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. Please provide a condensed and precise question, composed in such a way that a "yes" or "no" reply is acceptable.
Proposed Reply(ies): Provide a proposed reply(ies) in the form of "Yes" or "No," with explanation as needed. If entering replies to more than one question, please number the questions and replies.
Background Information: Provide the Committee with any background information that will assist the Committee in understanding the inquiry. The Inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in the format described above may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

Moreover, ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the inquiry information submitted, it is the opinion of the Committee that the Inquirer should seek assistance, the inquiry will be returned with the recommendation that such assistance be obtained.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

Attending Committee Meetings. The B16 Standards Committee regularly holds meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the B16 Standards Committee.

ASME B16.1-2020

SUMMARY OF CHANGES

Following approval by the ASME B16 Standards Committee and ASME, and after public review, ASME B16.1-2020 was approved by the American National Standards Institute on July 24, 2020.

In ASME B16.1-2020, the U.S. Customary tables in former Mandatory Appendix I have been merged with the SI tables in the main text. The tables and figures have been redesignated, former Mandatory Appendix I has been deleted, and the subsequent Mandatory Appendix has been redesignated. Cross-references have been updated accordingly. In addition, this edition includes the following changes identified by a margin note, **(20)**. The Record Numbers listed below are explained in more detail in the “List of Changes in Record Number Order” following this Summary of Changes.

<i>Page</i>	<i>Location</i>	<i>Change (Record Number)</i>
30	Table 7.6.1-2	NPS 66, 78, and 90 added (17-54)
36	Mandatory Appendix I	Former Mandatory Appendix I updated (20-863)

LIST OF CHANGES IN RECORD NUMBER ORDER

Record Number	Change
17-547	Former Tables 9 and I-9 were merged and redesignated as Table 7.6.1-2 and revised to include NPS 66, 78, and 90 for Class 125 flange and bolt dimensions.
20-863	Former Mandatory Appendix II references were updated.

GRAY IRON PIPE FLANGES AND FLANGED FITTINGS CLASSES 25, 125, AND 250

1 SCOPE

This Standard covers Classes 25, 125, and 250 Gray Iron Pipe Flanges and Flanged Fittings. It includes

- (a) pressure-temperature ratings
- (b) sizes and method of designating openings of reducing fittings
- (c) marking
- (d) materials
- (e) dimensions and tolerances
- (f) bolting and gaskets
- (g) pressure testing

2 GENERAL

2.1 References

Standards and specifications adopted by reference in this Standard are shown in [Mandatory Appendix I](#), which is part of this Standard. It is not considered practical to identify the specific edition of each referenced standard and specification in the text, when referenced. Instead, the specific editions of the referenced standards and specifications are listed in [Mandatory Appendix I](#).

2.2 Quality Systems

Requirements relating to the product manufacturer's Quality System Programs are described in [Nonmandatory Appendix A](#).

2.3 Relevant Units

This Standard states values in both SI and U.S. Customary units. As an exception, diameter of bolts and flange bolt holes are expressed in inch units only. These systems of units are to be regarded separately as standard. Within the text, the U.S. Customary units are shown in parentheses. The values stated in each system are not exact equivalents; therefore, it is required that each system of units be used independently of the other. Except for diameter of bolts and flange bolt holes, combining values from the two systems constitutes nonconformance with the Standard.

2.4 Service Conditions

Criteria for selection of materials suitable for particular fluid service are not within the scope of this Standard.

2.5 Convention

For determining conformance with this Standard, the convention for fixing significant digits where limits (maximum and minimum values) are specified shall be as defined in ASTM E29. This requires that an observed or calculated value be rounded off to the nearest unit in the last right-hand digit used for expressing the limit. Decimal values and tolerances do not imply a particular method of measurement.

2.6 Denotation

2.6.1 Pressure Rating Designation. Class, followed by a dimensionless number, is the designation for pressure-temperature ratings as follows:

Class	25	125	250
-------	----	-----	-----

2.6.2 Size. NPS, followed by a dimensionless number, is the designation for nominal flange or flange fitting size. NPS is related to the reference nominal diameter, DN, used in international standards. The relationship is, typically, as follows:

NPS	DN
1	25
1 ¹ / ₄	32
1 ¹ / ₂	40
2	50
2 ¹ / ₂	65
3	80
3 ¹ / ₂	...
4	100

GENERAL NOTE: For NPS ≥ 4, the related DN = 25 × (NPS).