

ASME B16.15-2018
(Revision of ASME B16.15-2013)

Cast Copper Alloy Threaded Fittings

Classes 125 and 250

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME B16.15-2018
(Revision of ASME B16.15-2013)

Cast Copper Alloy Threaded Fittings

Classes 125 and 250

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: October 12, 2018

The next edition of this Standard is scheduled for publication in 2023.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME B16 Committee may be published as Cases. Cases and interpretations are published on the ASME website under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME website under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be based on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures agreed to as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" an item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2018 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	v
Committee Roster	vii
Correspondence With the B16 Committee	viii
Summary of Changes	x
List of Changes in Record Number Order	xi
1 Scope	1
2 General	1
3 Pressure–Temperature Ratings	1
4 Size	2
5 Marking	2
6 Material	2
7 Threads	2
8 Ribs	2
9 Surface Finish	3
10 Fitting Dimensions	3
11 Tolerances	3
12 Pressure Test	3
 Mandatory Appendix	
I References	17
 Nonmandatory Appendix	
A Quality System Program	18
 Figure	
4.2-1 Identification of Reducing Fittings	4
 Tables	
3.1-1 Pressure–Temperature Ratings	3
7.1.3-1 Dimensions of 90-deg Elbows, Tees, Crosses, 45-deg Elbows, and Couplings (Straight Sizes) — Class 125	5
7.1.3-2 Dimensions of Caps — Class 125	6
7.1.3-3 Dimensions of Outside Head, Inside Head, and Face Bushings — Class 250	7
10.1.2-1 Dimensions of 90-deg Elbows (Reducing Sizes) — Class 125	9
10.1.2-2 Dimensions of Tees (Reducing Sizes) — Class 125	10
10.1.2-3 Dimensions of 90-deg Elbows (Reducing Sizes) — Class 250	11
10.1.2-4 Dimensions of Tees (Reducing Sizes) — Class 250	12
10.1.2-5 Dimensions of Square Head and Square Socket Plugs	13

10.1.2-6	Dimensions of Reducers, Closed and Open Pattern Return Bends, and 45-deg Y Branches (Straight Sizes) — Class 125	14
10.1.2-7	Dimensions of 90-deg and 45-deg Street Elbows — Class 125	15
10.1.2-8	Dimensions of 90-deg Elbows, Tees, Crosses, 45-deg Elbows, and Couplings (Straight Sizes) — Class 250	16
11.3-1	Inspection Tolerances, Center-to-End and Center-to-Center	16

Currently in preview, click buy full version

FOREWORD

As early as the spring of 1921, the consolidation and further development of threaded and flanged fittings standards in force in the United States seemed desirable. To meet this need, the American Standards Association (ASA) [now the American National Standards Institute (ANSI)] authorized the organization of a Sectional Committee on the Standardization of Pipe Flanges and Flanged Fittings (B16), with the Heating, Piping, and Air Conditioning Contractors' National Association (now known as the Mechanical Contractors Association of America), the Manufacturers Standardization Society of the Valve and Fittings Industry (MSS), and The American Society of Mechanical Engineers (ASME) acting as joint sponsors.

In June 1927, the MSS appointed a committee on Nonferrous Screw Fittings for the purpose of developing standards for products commonly designated as threaded pipe fittings of brass, bronze, and other nonferrous materials. At the time, brass threaded fittings were furnished from a number of different patterns with wide variations in dimensions and weights.

MSS SP-10 for 125-lb bronze screwed fittings and MSS SP-11 for 250-lb bronze screwed fittings were developed and adopted by the MSS in September 1930. The lighter fittings were patterned after malleable iron threaded fittings, then standardized in ASA B16c, while the heavier products were patterned after the cast iron threaded fittings covered by ASA B16d. Thus, a practice was standardized that had been found satisfactory in the valve and fittings industry for many years.

Following the publication of revised editions in 1941 and 1943, SP-10 was submitted to Subcommittee No. 2 of ASA Sectional Committee B16 for adoption as an American Standard. Final approval of that edition was granted on January 23, 1947, with the designation ASA B16.15. A reaffirmation of the Standard was granted in 1952, and a complete revision updating the Standard was approved by ASA on March 25, 1956.

After revision in 1944, SP-11 was submitted to Subcommittee No. 2 in August 1947, and ASA granted the approval of B16.17 on April 6, 1949.

In 1961, Subcommittee No. 2 reviewed the two Standards and noted that the historical reason for their separate existence no longer applied. Accordingly, the two were combined into ASA B16.15 with final ASA approval granted on February 6, 1964.

In 1969, the document was reviewed by Subcommittee No. 2, and minor changes were proposed. Final ANSI approval was granted on April 14, 1971.

In 1977, the MSS submitted a proposed revision to Subcommittee B (formerly No. 2) for B16 review and approval. Changes included the addition of metric (SI) units and editorial updating. ANSI granted final approval on December 4, 1978.

In 1982, American National Standards Committee B16 was reorganized as the ASME B16 Committee, operating under procedures accredited by ANSI. A revision, following regular 5-yr review by Subcommittee B, involved rationalization of metric equivalent dimensions and updating of reference standards. Following approval within ASME, ANSI approval was granted on July 30, 1985, with the designation ANSI/ASME B16.15-1985.

In 1994, and again in 2000, the document was reaffirmed.

In 2005, Subcommittee B of the ASME B16 Committee changed the title to Cast Copper Alloy Threaded Fittings, a section on leakage capacity was added, and nominal size (DN) according to ISO 6078 was addressed as SI values were positioned in the main text and U.S. Customary values were positioned in Mandatory Appendix I. The reference for gaging internal fitting threads was made clearer by using the wording from ASME B1.20.1, Pipe Threads, General Purpose (Inch). Many clarifying and editorial revisions were made to improve the text. After approval by ASME, ANSI approval was granted on August 25, 2006, with the designation ASME B16.15-2006.

In 2011, references to ASME standards were revised to no longer list specific edition years; the latest edition of ASME publications applies unless stated otherwise. Materials manufactured to other editions of the referenced ASTM standards have been permitted to be used to manufacture fittings meeting the requirements of this Standard as long as the fitting manufacturer verifies the material meets the requirements of the referenced edition. Following approval by the ASME B16 Standards Committee, the revision to the 2006 edition was approved as an American National Standard by ANSI on August 9, 2011, with the designation ASME B16.15-2011.

In the 2013 edition, section 7 was revised to require threads and gaging practices to be as per and identical with ASME B1.20.1 and other B16 standards. Following approval by the ASME B16 Standards Committee, approval as an American National Standard was given by ANSI on July 29, 2013, with the designation ASME B16.15-2013.

In this 2018 edition, the U.S. Customary tables formerly in Mandatory Appendix I have been merged with the SI tables in the main text; the tables and figure have been redesignated, Mandatory Appendix I has been deleted, and the cross-references have been updated accordingly. In addition, section 10 has been revised to add clarification to the wall thickness requirements in the transitional area of a reducing fitting in which there is a change from one size of end connection to another, and all reference standards in what was formerly Mandatory Appendix II have been updated. Following approval by the ASME B16 Standards Committee, approval as an American National Standard was given by ANSI on August 3, 2018, with the new designation ASME B16.15-2018.

Currently in preview, click buy full version

ASME B16 COMMITTEE

Standardization of Valves, Flanges, Fittings, and Gaskets

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

R. Bojarczuk, *Chair*
C. Davila, *Vice Chair*
C. R. Ramcharran, *Secretary*

STANDARDS COMMITTEE PERSONNEL

A. Appleton, Alloy Stainless Products Co., Inc.
J. E. Barker, Dezurik Water Controls
K. Barron, Ward Manufacturing, LLC
D. C. Bayreuther, Metso Automation
W. Bedesem, Consultant
R. Bojarczuk, ExxonMobil Research and Engineering Co.
A. Cheta, Qatar Shell GTL
M. Clark, Consultant
G. A. Cuccio, Capitol Manufacturing Co.
J. D'Avanzo, Fluoroseal Valves
C. Davila, Crane Energy
K. S. Felder, Valero Energy
D. Frikken, Becht Engineering Co.
D. Hunt, Jr., Fastenal
G. Jolly, Samshin Ltd.
E. J. Lain, Exelon Nuclear
T. A. McMahon, Emerson Process Management

R. C. Merrick, Fluor Enterprise
M. Nayyar, NICE
W. H. Patrick, The Dow Chemical Co.
D. Rahoji, Consultant
C. R. Ramcharran, The American Society of Mechanical Engineers
D. F. Reid, VSP Technologies
R. Schmidt, Shell
J. Tucker, Flowserve
F. Volgstadt, Volgstadt & Associates, Inc.
F. Feng Li, China Productivity Center for Machinery National Technical Committee
R. Barnes, *Contributing Member*, Anric Enterprises, Inc.
P. V. Craig, *Contributing Member*, Jomar Group
G. G. Fabian, *Contributing Member*, Pennsylvania Machine Works
A. G. Kireta, Jr., *Contributing Member*, Copper Development Association, Inc.

SUBCOMMITTEE B — THREADED FITTINGS (EXCEPT STEEL), FLANGES, AND FLANGED FITTINGS

D. Hunt, Jr., *Chair*, Fastenal
K. Barron, *Vice Chair*, Ward Manufacturing, LLC
J. Oh, *Secretary*, The American Society of Mechanical Engineers
W. Bliss, Tyler Pipe Company
M. Clark, Consultant
M. C. Coffey, Ward Manufacturing, LLC

J. R. Holstrom, Val-Matic Valve & Manufacturing Corporation
W. LeVan, Cast Iron Soil Pipe Institute
G. L. Simmons, Charlotte Pipe & Foundry
G. T. Walden, Wolseley
A. A. Knapp, *Contributing Member*, A. Knapp & Associates

CORRESPONDENCE WITH THE B16 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions or a case, and attending Committee meetings. Correspondence should be addressed to:

Secretary, B16 Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued to provide alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee web page.

Requests for Cases shall provide a Statement of Need and Background information. The request should identify the Standard and the paragraph, figure, or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

Interpretations. Upon request, the B16 Standards Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the B16 Standards Committee.

Requests for interpretation should preferably be submitted through the online Interpretation Submittal Form. The form is accessible at <http://go.asme.org/InterpretationRequest>. Upon submittal of the form, the Inquirer will receive an automatic e-mail confirming receipt.

If the Inquirer is unable to use the online form, he/she may e-mail the request to the Secretary of the B16 Standards Committee at SecretaryB16@asme.org or mail it to the above address. The request for an interpretation should be clear and unambiguous. It is further recommended that the Inquirer submit his/her request in the following format:

Subject: Cite the applicable paragraph number(s) and the topic of the inquiry in one or two words.
Edition: Cite the applicable edition of the Standard for which the interpretation is being requested.
Question: Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. Please provide a condensed and precise question, composed in such a way that a "yes" or "no" reply is acceptable.
Proposed Reply(ies): Provide a proposed reply(ies) in the form of "Yes" or "No," with explanation as needed. If entering replies to more than one question, please number the questions and replies.
Background Information: Provide the Committee with any background information that will assist the Committee in understanding the inquiry. The Inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in the format described above may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

Moreover, ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the inquiry information submitted, it is the opinion of the Committee that the Inquirer should seek assistance, the inquiry will be returned with the recommendation that such assistance be obtained.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

Attending Committee Meetings. The B16 Standards Committee regularly holds meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the B16 Standards Committee.

ASME B16.15-2018

SUMMARY OF CHANGES

Following approval by the ASME B16 Committee and ASME, and after public review, ASME B16.15-2018 was approved by the American National Standards Institute on August 3, 2018.

In ASME B16.15-2018, the U.S. Customary tables formerly in Mandatory Appendix I have been merged with the SI tables in the main text; the tables and figure have been redesignated, Mandatory Appendix I has been deleted, and the cross-references have been updated accordingly. In addition, this edition includes the following changes identified by a margin note, **(18)**. The Record Numbers listed below are explained in more detail in the “List of Changes in Record Number Order” following this Summary of Changes.

<i>Page</i>	<i>Location</i>	<i>Change</i>
2	4.1	Revised editorially
2	7.2	Revised editorially
3	10	Revised in its entirety (12-581)
3	11.2	Second sentence revised editorially
3	12	Revised editorially
17	Mandatory Appendix I	Formerly Mandatory Appendix II, updated (18-942)

LIST OF CHANGES IN RECORD NUMBER ORDER

<u>Record Number</u>	<u>Change</u>
12-581	Revised section 10 in its entirety to clarify the wall thickness requirements in the transitional area of a reducing fitting in which there is a change from one size of end connection to another.
18-942	Updated references in Mandatory Appendix I, formerly Mandatory Appendix II.

CAST COPPER ALLOY THREADED FITTINGS

Classes 125 and 250

1 SCOPE

This Standard covers cast Classes 125 and 250 copper alloy threaded pipe fittings with provisions for substituting wrought copper alloys for plugs, bushings, caps, and couplings in small sizes. This Standard includes the following:

- (a) pressure–temperature ratings
- (b) size and method of designating openings of reducing pipe fittings
- (c) marking requirements
- (d) minimum requirements for casting quality and materials
- (e) dimensions and tolerances in SI (metric) and U.S. Customary units
- (f) threading requirements
- (g) pressure test requirements

2 GENERAL

2.1 Relevant Units

This Standard states values in both SI (metric) and U.S. Customary units. These systems of units are to be regarded separately as standard. Within the text, the U.S. Customary units are shown in parentheses. The values stated in each system are not exact equivalents; therefore, it is required that each system of units be used independently of the other. Combining values from the two systems constitutes nonconformance with the Standard.

2.2 References

Standards and specifications containing provisions to the extent referenced herein constitute requirements of this Standard. These referenced documents are listed in [Mandatory Appendix I](#).

2.3 Quality Systems

Requirements relating to the product manufacturer's Quality System Programs are described in [Nonmandatory Appendix A](#).

2.4 Denotation

2.4.1 Pressure Rating Designation. Class followed by a dimensionless number is the designation for pressure–temperature ratings, e.g., Class 125 and Class 250.

2.4.2 Size. NPS followed by a dimensionless number is the designation for nominal fittings size, e.g., NPS 2.

2.5 Time of Purchase, Manufacture, or Installation

The pressure–temperature ratings in this Standard are applicable upon its publication to all fittings within its scope that otherwise meet its requirements. For unused fittings maintained in inventory, the manufacturer of the fittings may certify conformance to this edition provided it can be demonstrated that all requirements of this edition have been met. Where such components were installed in accordance with the pressure–temperature ratings of an earlier edition of this Standard, those ratings are applicable except as may be governed by the applicable code or regulation.

2.6 User Accountability

This Standard cites responsibilities that are to be assumed by the fitting user in the areas of the temperature at which the pressure rating is taken.

2.7 Service Conditions

Criteria for selection of materials suitable for particular fluid service are not within the scope of this Standard.

3 PRESSURE–TEMPERATURE RATINGS

3.1 General

Pressure–temperature ratings for these pipe fittings are shown in [Table 3.1-1](#). All pressures are gage.

3.2 Rating

Pressure–temperature ratings are independent of the contained fluid and are the maximum allowable pressures at the tabulated temperatures. Intermediate ratings may be obtained by linear interpolation between the temperatures shown.

The temperature shown for the corresponding pressure rating shall be the material temperature of the pressure-retaining structure. It may be assumed that the material temperature is the same as the fluid temperature. Use of a pressure rating at a material temperature other than that of the contained fluid is the responsibility of the user and subject to the requirements of any applicable codes and regulations.