

ASME B16.5-2025
(Revision of ASME B16.5-2020)

Pipe Flanges and Flanged Fittings

NPS ½ Through NPS 24
Metric/Inch Standard

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers

ASME B16.5-2025
(Revision of ASME B16.5-2020)

Pipe Flanges and Flanged Fittings

NPS $\frac{1}{2}$ Through NPS 24
Metric/Inch Standard

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: May 30, 2025

The next edition of this Standard is scheduled for publication in 2028.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark

All rights reserved. “ASME” and the above ASME symbol are registered trademarks of The American Society of Mechanical Engineers. No part of this document may be copied, modified, distributed, published, displayed, or otherwise reproduced in any form or by any means, electronic, digital, or mechanical, now known or hereafter invented, without the express written permission of ASME. No works derived from this document or any content therein may be created without the express written permission of ASME. Using this document or any content therein to train, create, or improve any artificial intelligence and/or machine learning platform, system, application, model, or algorithm is strictly prohibited.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2025 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
Printed in U.S.A.

CONTENTS

| | | |
|--|--|-----------|
| Foreword | vii | vii |
| Committee Roster | xi | xi |
| Correspondence With the B16 Committee | xii | xii |
| Summary of Changes | xiv | xiv |
| List of Changes in Record Number Order | xix | xix |
| | | |
| 1 | General | 1 |
| 2 | Pressure–Temperature Ratings | 2 |
| 3 | Component Size | 3 |
| 4 | Marking | 4 |
| 5 | Materials | 4 |
| 6 | Dimensions | 10 |
| 7 | Tolerances | 13 |
| 8 | Pressure Testing | 15 |
| | | |
| Mandatory Appendices | | |
| I | Threading of Pipe for American National Standard Threaded Flanges | 201 |
| II | References | 203 |
| | | |
| Nonmandatory Appendices | | |
| A | Method Used for Establishing Pressure–Temperature Ratings | 206 |
| B | Limiting Dimensions of Gaskets Other Than Ring Joint Gaskets | 211 |
| C | Method for Calculating Bolt Lengths | 213 |
| D | Quality System Program | 216 |
| E | Dimensions of Classes 40, 600, 900, 1500, and 2500 Flanged Fittings in U.S. Customary Units | 217 |
| F | Method Used to Establish SI Unit Values | 245 |
| G | Low Temperature Applications | 247 |
| | | |
| Figures | | |
| 1 | Bevel for Outside Thickness | 15 |
| 2 | Bevel for Inside Thickness | 15 |
| 3 | Bevel for Combined Thickness | 16 |
| 4 | Straight Hub Welding Flanges | 16 |
| 5 | Method of Designating Outlets of Reducing Fittings in Specifications (Flanged Fittings) | 17 |
| 6 | End Flange Facings and Their Relationship to Flange Thickness and Center-to-End and End-to-End Dimensions | 18 |
| 7 | Welding Neck Flange Hub and Welding End Profiles for Wall Thicknesses t From 5 mm (0.19 in.) to 22 mm (0.88 in.) | 20 |

| | | |
|-----|---|-----|
| 8 | Welding Neck Flange Hub and Welding End Profiles for Wall Thicknesses t Greater Than 22 mm (0.88 in.) | 21 |
| 9 | Inside Contour for Use With Rectangular Backing Ring | 22 |
| 10 | Inside Contour for Use With Taper Backing Ring | 22 |
| 11 | Thread Length for Connection Tapping | 23 |
| 12 | Socket Welding for Connections | 23 |
| 13 | Bosses for Connections | 23 |
| 14 | Butt Welding for Connections | 23 |
| 15 | Method of Designating Location of Auxiliary Connections When Specified (Flanged Fittings) | 24 |
| C-1 | Specified Machine Bolt Length | 214 |
| C-2 | Specified Stud Bolt Length | 214 |

Tables

| | | |
|---------|--|----|
| 1.1-1 | List of Material Specifications | 5 |
| 1.1-2 | List of Bolting Specifications: Applicable ASTM Specifications | 9 |
| 1.1-3 | Flange Bolting Dimensional Recommendations | 13 |
| 2-1.1 | Pressure–Temperature Ratings for Group 1.1 Materials — SI Units | 25 |
| 2-1.1C | Pressure–Temperature Ratings for Group 1.1 Materials — U.S. Customary Units | 26 |
| 2-1.2 | Pressure–Temperature Ratings for Group 1.2 Materials — SI Units | 27 |
| 2-1.2C | Pressure–Temperature Ratings for Group 1.2 Materials — U.S. Customary Units | 28 |
| 2-1.3 | Pressure–Temperature Ratings for Group 1.3 Materials — SI Units | 29 |
| 2-1.3C | Pressure–Temperature Ratings for Group 1.3 Materials — U.S. Customary Units | 30 |
| 2-1.4 | Pressure–Temperature Ratings for Group 1.4 Materials — SI Units | 31 |
| 2-1.4C | Pressure–Temperature Ratings for Group 1.4 Materials — U.S. Customary Units | 32 |
| 2-1.5 | Pressure–Temperature Ratings for Group 1.5 Materials — SI Units | 33 |
| 2-1.5C | Pressure–Temperature Ratings for Group 1.5 Materials — U.S. Customary Units | 34 |
| 2-1.7 | Pressure–Temperature Ratings for Group 1.7 Materials — SI Units | 35 |
| 2-1.7C | Pressure–Temperature Ratings for Group 1.7 Materials — U.S. Customary Units | 36 |
| 2-1.9 | Pressure–Temperature Ratings for Group 1.9 Materials — SI Units | 37 |
| 2-1.9C | Pressure–Temperature Ratings for Group 1.9 Materials — U.S. Customary Units | 38 |
| 2-1.10 | Pressure–Temperature Ratings for Group 1.10 Materials — SI Units | 39 |
| 2-1.10C | Pressure–Temperature Ratings for Group 1.10 Materials — U.S. Customary Units | 40 |
| 2-1.11 | Pressure–Temperature Ratings for Group 1.11 Materials — SI Units | 41 |
| 2-1.11C | Pressure–Temperature Ratings for Group 1.11 Materials — U.S. Customary Units | 42 |
| 2-1.13 | Pressure–Temperature Ratings for Group 1.13 Materials — SI Units | 43 |
| 2-1.13C | Pressure–Temperature Ratings for Group 1.13 Materials — U.S. Customary Units | 44 |
| 2-1.14 | Pressure–Temperature Ratings for Group 1.14 Materials — SI Units | 45 |
| 2-1.14C | Pressure–Temperature Ratings for Group 1.14 Materials — U.S. Customary Units | 46 |
| 2-1.15 | Pressure–Temperature Ratings for Group 1.15 Materials — SI Units | 47 |
| 2-1.15C | Pressure–Temperature Ratings for Group 1.15 Materials — U.S. Customary Units | 48 |
| 2-1.17 | Pressure–Temperature Ratings for Group 1.17 Materials — SI Units | 49 |
| 2-1.17C | Pressure–Temperature Ratings for Group 1.17 Materials — U.S. Customary Units | 50 |
| 2-1.18 | Pressure–Temperature Ratings for Group 1.18 Materials — SI Units | 51 |
| 2-1.18C | Pressure–Temperature Ratings for Group 1.18 Materials — U.S. Customary Units | 52 |
| 2-2.1 | Pressure–Temperature Ratings for Group 2.1 Materials — SI Units | 53 |

| | | |
|---------|--|----|
| 2-2.1C | Pressure–Temperature Ratings for Group 2.1 Materials — U.S. Customary Units | 54 |
| 2-2.2 | Pressure–Temperature Ratings for Group 2.2 Materials — SI Units | 55 |
| 2-2.2C | Pressure–Temperature Ratings for Group 2.2 Materials — U.S. Customary Units | 56 |
| 2-2.3 | Pressure–Temperature Ratings for Group 2.3 Materials — SI Units | 57 |
| 2-2.3C | Pressure–Temperature Ratings for Group 2.3 Materials — U.S. Customary Units | 58 |
| 2-2.4 | Pressure–Temperature Ratings for Group 2.4 Materials — SI Units | 59 |
| 2-2.4C | Pressure–Temperature Ratings for Group 2.4 Materials — U.S. Customary Units | 60 |
| 2-2.5 | Pressure–Temperature Ratings for Group 2.5 Materials — SI Units | 61 |
| 2-2.5C | Pressure–Temperature Ratings for Group 2.5 Materials — U.S. Customary Units | 62 |
| 2-2.6 | Pressure–Temperature Ratings for Group 2.6 Materials — SI Units | 63 |
| 2-2.6C | Pressure–Temperature Ratings for Group 2.6 Materials — U.S. Customary Units | 64 |
| 2-2.7 | Pressure–Temperature Ratings for Group 2.7 Materials — SI Units | 65 |
| 2-2.7C | Pressure–Temperature Ratings for Group 2.7 Materials — U.S. Customary Units | 66 |
| 2-2.8 | Pressure–Temperature Ratings for Group 2.8 Materials — SI Units | 67 |
| 2-2.8C | Pressure–Temperature Ratings for Group 2.8 Materials — U.S. Customary Units | 67 |
| 2-2.9 | Pressure–Temperature Ratings for Group 2.9 Materials — SI Units | 68 |
| 2-2.9C | Pressure–Temperature Ratings for Group 2.9 Materials — U.S. Customary Units | 69 |
| 2-2.10 | Pressure–Temperature Ratings for Group 2.10 Materials — SI Units | 70 |
| 2-2.10C | Pressure–Temperature Ratings for Group 2.10 Materials — U.S. Customary Units | 71 |
| 2-2.11 | Pressure–Temperature Ratings for Group 2.11 Materials — SI Units | 72 |
| 2-2.11C | Pressure–Temperature Ratings for Group 2.11 Materials — U.S. Customary Units | 73 |
| 2-2.12 | Pressure–Temperature Ratings for Group 2.12 Materials — SI Units | 74 |
| 2-2.12C | Pressure–Temperature Ratings for Group 2.12 Materials — U.S. Customary Units | 75 |
| 2-2.13 | Pressure–Temperature Ratings for Group 2.13 Materials — SI Units | 76 |
| 2-2.13C | Pressure–Temperature Ratings for Group 2.13 Materials — U.S. Customary Units | 77 |
| 2-3.1 | Pressure–Temperature Ratings for Group 3.1 Materials — SI Units | 78 |
| 2-3.1C | Pressure–Temperature Ratings for Group 3.1 Materials — U.S. Customary Units | 78 |
| 2-3.2 | Pressure–Temperature Ratings for Group 3.2 Materials — SI Units | 79 |
| 2-3.2C | Pressure–Temperature Ratings for Group 3.2 Materials — U.S. Customary Units | 79 |
| 2-3.3 | Pressure–Temperature Ratings for Group 3.3 Materials — SI Units | 80 |
| 2-3.3C | Pressure–Temperature Ratings for Group 3.3 Materials — U.S. Customary Units | 81 |
| 2-3.4 | Pressure–Temperature Ratings for Group 3.4 Materials — SI Units | 82 |
| 2-3.4C | Pressure–Temperature Ratings for Group 3.4 Materials — U.S. Customary Units | 83 |
| 2-3.5 | Pressure–Temperature Ratings for Group 3.5 Materials — SI Units | 84 |
| 2-3.5C | Pressure–Temperature Ratings for Group 3.5 Materials — U.S. Customary Units | 85 |
| 2-3.6 | Pressure–Temperature Ratings for Group 3.6 Materials — SI Units | 86 |
| 2-3.6C | Pressure–Temperature Ratings for Group 3.6 Materials — U.S. Customary Units | 87 |
| 2-3.7 | Pressure–Temperature Ratings for Group 3.7 Materials — SI Units | 88 |
| 2-3.7C | Pressure–Temperature Ratings for Group 3.7 Materials — U.S. Customary Units | 88 |
| 2-3.8 | Pressure–Temperature Ratings for Group 3.8 Materials — SI Units | 89 |
| 2-3.8C | Pressure–Temperature Ratings for Group 3.8 Materials — U.S. Customary Units | 90 |
| 2-3.9 | Pressure–Temperature Ratings for Group 3.9 Materials — SI Units | 91 |
| 2-3.9C | Pressure–Temperature Ratings for Group 3.9 Materials — U.S. Customary Units | 92 |
| 2-3.10 | Pressure–Temperature Ratings for Group 3.10 Materials — SI Units | 93 |
| 2-3.10C | Pressure–Temperature Ratings for Group 3.10 Materials — U.S. Customary Units | 93 |

| | | |
|---------|--|-----|
| 2-3.11 | Pressure–Temperature Ratings for Group 3.11 Materials — SI Units | 94 |
| 2-3.11C | Pressure–Temperature Ratings for Group 3.11 Materials — U.S. Customary Units | 94 |
| 2-3.12 | Pressure–Temperature Ratings for Group 3.12 Materials — SI Units | 95 |
| 2-3.12C | Pressure–Temperature Ratings for Group 3.12 Materials — U.S. Customary Units | 96 |
| 2-3.13 | Pressure–Temperature Ratings for Group 3.13 Materials — SI Units | 97 |
| 2-3.13C | Pressure–Temperature Ratings for Group 3.13 Materials — U.S. Customary Units | 97 |
| 2-3.14 | Pressure–Temperature Ratings for Group 3.14 Materials — SI Units | 98 |
| 2-3.14C | Pressure–Temperature Ratings for Group 3.14 Materials — U.S. Customary Units | 99 |
| 2-3.15 | Pressure–Temperature Ratings for Group 3.15 Materials — SI Units | 100 |
| 2-3.15C | Pressure–Temperature Ratings for Group 3.15 Materials — U.S. Customary Units | 101 |
| 2-3.16 | Pressure–Temperature Ratings for Group 3.16 Materials — SI Units | 102 |
| 2-3.16C | Pressure–Temperature Ratings for Group 3.16 Materials — U.S. Customary Units | 103 |
| 2-3.17 | Pressure–Temperature Ratings for Group 3.17 Materials — SI Units | 104 |
| 2-3.17C | Pressure–Temperature Ratings for Group 3.17 Materials — U.S. Customary Units | 104 |
| 2-3.19 | Pressure–Temperature Ratings for Group 3.19 Materials — SI Units | 105 |
| 2-3.19C | Pressure–Temperature Ratings for Group 3.19 Materials — U.S. Customary Units | 106 |
| 3 | Permissible Imperfections in Flange Facing Finish for Raised Face and Large Male and Female Flanges — SI Units | 107 |
| 3C | Permissible Imperfections in Flange Facing Finish for Raised Face and Large Male and Female Flanges — U.S. Customary Units | 108 |
| 4 | Dimensions of Facings (Other Than Ring Joints, All Pressure Rating Classes) — SI Units | 109 |
| 4C | Dimensions of Facings (Other Than Ring Joints, All Pressure Rating Classes) — U.S. Customary Units | 111 |
| 5 | Dimensions of Ring Joint Facings (All Pressure Rating Classes) — SI Units | 114 |
| 5C | Dimensions of Ring Joint Facings (All Pressure Rating Classes) — U.S. Customary Units | 122 |
| 6 | Reducing Threaded and Slip-On Pipe Flanges for Classes 150 Through 2500 Pipe Flanges — SI Units | 129 |
| 6C | Reducing Threaded and Slip-On Pipe Flanges for Classes 150 Through 2500 Pipe Flanges — U.S. Customary Units | 130 |
| 7 | Templates for Drilling Class 150 Pipe Flanges and Flanged Fittings — SI Units | 131 |
| 7C | Templates for Drilling Class 150 Pipe Flanges and Flanged Fittings — U.S. Customary Units | 132 |
| 8 | Dimensions of Class 150 Flanges — SI Units | 133 |
| 8C | Dimensions of Class 150 Flanges — U.S. Customary Units | 136 |
| 9 | Dimensions of Class 150 Flanged Fittings — SI Units | 140 |
| 9C | Dimensions of Class 150 Flanged Fittings — U.S. Customary Units | 146 |
| 10 | Templates for Drilling Class 300 Pipe Flanges and Flanged Fittings — SI Units | 151 |
| 10C | Templates for Drilling Class 300 Pipe Flanges and Flanged Fittings — U.S. Customary Units | 152 |
| 11 | Dimensions of Class 300 Flanges — SI Units | 153 |
| 11C | Dimensions of Class 300 Flanges — U.S. Customary Units | 156 |
| 12 | Dimensions of Class 300 Flanged Fittings — SI Units | 160 |
| 12C | Dimensions of Class 300 Flanged Fittings — U.S. Customary Units | 164 |
| 13 | Templates for Drilling Class 400 Pipe Flanges — SI Units | 167 |
| 13C | Templates for Drilling Class 400 Pipe Flanges — U.S. Customary Units | 168 |
| 14 | Dimensions of Class 400 Flanges — SI Units | 169 |
| 14C | Dimensions of Class 400 Flanges — U.S. Customary Units | 171 |
| 15 | Templates for Drilling Class 600 Pipe Flanges and Flanged Fittings — SI Units | 173 |

| | | |
|-----|---|-----|
| 15C | Templates for Drilling Class 600 Pipe Flanges and Flanged Fittings — U.S. Customary Units | 174 |
| 16 | Dimensions of Class 600 Flanges — SI Units | 175 |
| 16C | Dimensions of Class 600 Flanges — U.S. Customary Units | 178 |
| 17 | Templates for Drilling Class 900 Pipe Flanges and Flanged Fittings — SI Units | 181 |
| 17C | Templates for Drilling Class 900 Pipe Flanges and Flanged Fittings — U.S. Customary Units | 182 |
| 18 | Dimensions of Class 900 Flanges — SI Units | 183 |
| 18C | Dimensions of Class 900 Flanges — U.S. Customary Units | 188 |
| 19 | Templates for Drilling Class 1500 Pipe Flanges — SI Units | 189 |
| 19C | Templates for Drilling Class 1500 Pipe Flanges — U.S. Customary Units | 190 |
| 20 | Dimensions of Class 1500 Flanges — SI Units | 191 |
| 20C | Dimensions of Class 1500 Flanges — U.S. Customary Units | 193 |
| 21 | Templates for Drilling Class 2500 Pipe Flanges — SI Units | 195 |
| 21C | Templates for Drilling Class 2500 Pipe Flanges — U.S. Customary Units | 196 |
| 22 | Dimensions of Class 2500 Flanges — SI Units | 197 |
| 22C | Dimensions of Class 2500 Flanges — U.S. Customary Units | 199 |
| I-1 | Projection of Threaded Pipe End Through a Ring Gage | 202 |
| A-1 | Rating Ceiling Pressure — p_c , bar | 209 |
| A-2 | Rating Ceiling Pressure — p_c , psig | 210 |
| B-1 | Gasket Groups and Typical Materials | 212 |
| C-1 | Thickness for Lapped Joints | 214 |
| C-2 | F Values | 214 |
| C-3 | n Values | 215 |
| E-1 | Dimensions of Class 400 Flanged Fittings | 218 |
| E-2 | Dimensions of Class 600 Flanged Fittings | 224 |
| E-3 | Dimensions of Class 900 Flanged Fittings | 230 |
| E-4 | Dimensions of Class 1500 Flanged Fittings | 236 |
| E-5 | Dimensions of Class 2500 Flanged Fittings | 242 |
| G-1 | Example Minimum Use Temperatures | 248 |

FOREWORD

In 1920, the American Engineering Standards Committee [later the American Standards Association (ASA) and currently the American National Standards Institute (ANSI)] organized Sectional Committee B16 to unify and further develop standards for pipe flanges and fittings (and later for valves and gaskets). Cosponsors of the B16 Committee were The American Society of Mechanical Engineers (ASME), the Heating and Piping Contractors National Association [now Mechanical Contractors Association of America (MCAA)], and the Manufacturers Standardization Society of the Valves and Fittings Industry (MSS). Cosponsors were later designated as cosecretariat organizations.

The Committee soon recognized the need for standardization of steel pipe flanges. In May 1923, Subcommittee 3 was organized to develop such standards for pressures in the 250-psi to 3,200-psi range and for elevated temperatures. Active work began in October, including on steel flanged fittings. The first proposed standard was submitted to the Committee in April 1926 and approved by letter ballot in December. After favorable review by the three sponsor organizations, the Standard was approved as American Tentative Standard B16e in June 1927.

Experience in using the Standard showed the need for hub dimensions of companion flanges and for other changes, including rerating of 250-lb and 1,350-lb flanges and development of flanged fittings with increased wall thicknesses. An investigation was made into the factors determining stiffness of flanges and flange hubs. The revised Standard was approved as ASA B16e-1932.

A revision was initiated in 1936, stimulated by suggestions from Committee members and industrial users. The resulting 1939 edition contained standards for welding neck flanges (completed in March 1937), 1,500-lb flanges in the 14-in. through 24-in. range, 2,500-lb flanges and flanged fittings in the 1/2-in. through 12-in. range, and dimensions for a full line of ring joint flanges developed by the American Petroleum Institute. Pressure-temperature ratings for alloy steel flanges and fittings, developed by Subcommittee 4, were included for the first time.

In August 1942, the War Production Board requested a review of measures to conserve vital materials in piping components. A special War Committee of B16 was appointed and operating under War Standard Procedure, developed revised pressure-temperature ratings for all materials and pressure classes. The ratings were published as American War Standard B16e5-1943. In 1945, under normal procedures, Subcommittees 3 and 4 reviewed the 1939 standard and 1943 ratings and recommended adoption of the wartime ratings. Their report was approved as Supplement No. 1 to B16e-1939 and published as ASA B16e6-1949. In addition to ratings, the supplement updated material specification references and added a table of metal wall thickness for welding end valves.

Subcommittee 3 then began a revision of the entire standard. Technically, the 1949 Supplement was absorbed, new materials were recognized, a general rating method was developed and added as an appendix, and welding end preparations were expanded. Editorially, a new style of presentation was worked out, including tables rearranged for easier use. Approval by Sectional Committee, cosponsors, and ASA resulted in the publication of ASA B16.5-1953 (designation changed from B16e).

Work soon began on further revisions. Class B ratings were deleted, and Class A ratings were clarified as the standard. An appendix defined qualification for gaskets, other than ring joint, which would merit the ratings. Another appendix defined the method for calculating bolt lengths, including the measurement of stud bolt length between thread ends instead of points. Pressure-temperature ratings for several new materials were added, the table of welding end dimensions was expanded, and the temperatures used in determining ratings were redefined. The resulting new edition, after approval, was published as ASA B16.5-1957.

The more modest revision approved as ASA B16.5-1961 changed the text to clarify the intent or to make requirements easier to administer. The next revision began in 1963 with nearly 100 comments and suggestions. No fundamental changes were made, but the text was further clarified, and wall thicknesses less than 1/4 in. for flanged fittings were recognized in the 1968 edition.

A new joint study of ratings between Subcommittees 3 and 4 was initiated before the next revision. Based on the Subcommittee 4 report, the rating procedure was revised, and a rating basis for Class 150 (150-lb) flanges was developed. New product forms, bar and plate, were added for special applications, including fabricated flanged valves and fittings. Reference to welding-end valves was not included, because a separate standard for them was planned. Bolt length calculations based on worst case tolerances led to a revision of tabulated lengths. Testing of valves subsequently published by Subcommittee 15 closure members was added to the test requirements. Following final approval on October 23, the Standard was published as ANSI B16.5-1973.

Subcommittee N (formerly 15) was assigned responsibility for all valve standards in late 1973. Subcommittee C (formerly 3) continued to have responsibility for flange standards. A revision was accordingly initiated to remove all references to valves. At the same time, comments from users and changes in the ASME Boiler and Pressure Vessel Code (BPVC) led to significant revisions in the Class 150 rating basis and in the ratings of stainless steel and certain alloy steel flanges and flanged fittings in all rating classes. Extensive public review comments led to the addition of considerations for bolting and gaskets for flanged joints and of marking requirements. To avoid having to make frequent and confusing changes to the ratings as a result of further changes to the BPVC-allowable stresses, Subcommittees C and N agreed that ratings would be left alone unless the relevant BPVC stress values were changed by more than 10%. After final approval by the Standards Committee, cosponsors, and ANSI, ANSI B16.5-1977, Steel Pipe Flanges and Flanged Fittings, was published on June 16, 1977.

In 1979, work began on another new edition. Materials coverage was expanded by the addition of nickel and nickel alloys. Bolting rules were revised to cover nickel alloy bolts. Bolt hole and bolting were changed to provide interchangeability between inch and metric dimensions. Metric dimensional tables were made informational rather than alternative requirements of the Standard. Final approval was granted for ANSI B16.5-1984, Pipe Flanges and Flanged Fittings, on August 14.

In 1982, American National Standards Committee B16 was reorganized as an ASME Committee operating under procedures accredited by ANSI. The 1988 edition of the Standard extended nickel alloy ratings to higher temperatures, clarifying flat face flange requirements, and included other minor revisions. The Committee determined that any metric standard for flanges would stand alone, with metric bolting and gaskets; hence, metric equivalents were deleted. Following approval by the Standards Committee and ASME, approval as an American National Standard was given by ANSI on April 7, 1988, with the new designation ASME/ANSI B16.5-1988.

The 1996 edition allowed flanges marked with more than one material grade classification, revised flange facing finish requirements, revised pressure-temperature ratings for several material groups, added a nonmandatory quality system annex, and included several other revisions. The 1996 edition was approved by ANSI on October 3, 1996, with the new designation ASME B16.5-1996.

The 2003 edition included metric units as the primary reference unit, while maintaining U.S. Customary units in either parenthetical or separate forms. New materials were added, some materials were shifted from one group to another, and new material groups were established.

All pressure-temperature ratings were recalculated using data from the latest edition of ASME BPVC, Section II, Part D. Annex F was added to cover pressure-temperature ratings and dimensional data for Classes 150 through 2500 flanges and Classes 150 and 300 flanged fittings in U.S. Customary units. Table and figure numbers in Annex F were prefixed by the letter F and corresponded to table and figure numbers in the main text for the metric version, with the exception of some table and figure numbers that were not used in Annex F. Of note, the flange thickness designations for Classes 150 and 300 were revised with reference to their raised face. For these classes, the flange thickness dimensional reference planes were altered; however, required flange thicknesses remained unchanged. The minimum flange thickness designation was changed from C to t_f , and it did not include 2.0 mm (0.06 in.) raised face for Classes 150 and 300 raised face flanges and flanged fittings. Because of diminished interest, flanged end fittings conforming to ASME Class 400 and higher were listed only with U.S. Customary units in Annex G. In addition, straight hub welding flanges were incorporated as a new set of flanges in Classes 150 through 2500. Also, there were numerous requirement clarifications and editorial revisions. The 2003 edition was approved by ANSI on July 9, 2003, with the designation ASME B16.5-2003.

The 2009 edition added new materials, updated some pressure-temperature ratings, and designated the annexes as mandatory and nonmandatory appendices. The mandatory appendices were numbered using roman numerals, and the nonmandatory appendices were referenced using capital letters. The 2009 edition was approved by ANSI on February 19, 2009, with the designation ASME B16.5-2009.

The 2013 edition included a revision to [para. 5.1](#) and the addition of perpendicularity tolerances. Additional errata and clarifying revisions were also applied. Following approval of the Standards Committee and ASME, approval for the 2013 edition was granted by ANSI on February 5, 2013.

The 2017 edition included the use of bar stock for blind flanges without hubs; added requirements for forgings, size NPS 22 and above materials and working pressures.

In the 2020 edition, the U.S. Customary tables in former Mandatory Appendix II were relocated to the main text and redesignated with a "C" suffix (e.g., Table II-2-1.1 became Table 2-1.1C) and U.S. Customary figures were merged with SI figures. Former Mandatory Appendix II was deleted and the subsequent Mandatory Appendix redesignated. Cross-references were updated accordingly. Following approval by the ASME B16 Standards Committee, ASME B16.5-2020 was approved by ANSI as an American National Standard on January 5, 2021.

In the 2025 edition, various ASTM materials; a new appendix for determining minimum temperature limits; and definitions for *may*, *shall*, and *should* were added. After adopting revised ceiling values ([Nonmandatory Appendix A, Tables A-1 and A-2](#)), pressure–temperature ratings were revised. Lastly, various revisions to variables were made.

Following approval by the ASME B16 Standards Committee, ASME B16.5-2025 was approved by ANSI as an American National Standard on April 10, 2025.

ASME B16 COMMITTEE

Standardization of Valves, Flanges, Fittings, and Gaskets

(The following is the roster of the committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

C. E. Davila, *Chair*
R. M. Bojarczuk, *Vice Chair*
S. J. Rossi, *Secretary*

STANDARDS COMMITTEE PERSONNEL

| | |
|---|---|
| A. Appleton , Appleton Quality Concepts, LLC | A. G. Kireta, Jr. , Copper Development Association, Inc. |
| J. E. Barker , DeZURIK, Inc. | E. J. Lain , Constellation |
| R. Barnes , ANRIC Enterprises, Inc. | T. A. McMahon , Emerson Process Management, LLP |
| D. C. Bayreuther , Neles USA, Inc. | R. C. Merrick , Consultant |
| W. Bedesem , Consultant | W. H. Patrick , Dow, Inc. |
| R. M. Bojarczuk , Consultant | D. W. Raho , Consultant |
| A. M. Cheta , Shell Global Solutions (U.S.) | D. F. Reid , VSP Technologies |
| G. A. Cuccio , Capitol Manufacturing Co., LLC | S. J. Rossi , The American Society of Mechanical Engineers |
| C. E. Davila , Crane ChemPharma and Energy | R. A. Schmidt , Canadoil |
| J. G. Dominguez , Welding Outlets, Inc. | J. Sekerak , CSA America Standards, Inc. |
| B. G. Fabian , Pennsylvania Machine Works, LLC | F. Feng , <i>Delegate</i> , China Productivity Center for Machinery National Technical Committee |
| D. R. Frikken , Becht Engineering Co., Inc. | J. D. Grant , <i>Alternate</i> , DeZURIK, Inc. |
| J. R. Holstrom , Val-Matic Valve and Manufacturing Corp. | P. V. Craig , <i>Contributing Member</i> , Jomar Group, Ltd. |
| D. Hunt, Jr. , Fastenal Co. | |
| G. A. Jolly , Samshin, Ltd. | |

SUBCOMMITTEE C — STEEL FLANGES AND FLANGED FITTINGS

| | |
|---|---|
| D. R. Frikken , <i>Chair</i> , Becht Engineering Co., Inc. | J. R. Holstrom , Val-Matic Valve and Manufacturing Corp. |
| A. Carrion , <i>Secretary</i> , The American Society of Mechanical Engineers | G. A. Jolly , Samshin, Ltd. |
| A. Appleton , Appleton Quality Concepts, LLC | R. C. Merrick , Consultant |
| W. Bedesem , Consultant | W. H. Patrick , Dow, Inc. |
| A. Casteel , Fluor Enterprises | D. W. Raho , Consultant |
| A. M. Cheta , Shell Global Solutions (U.S.) | T. V. Ramakrishnan , Forged Components, Inc. |
| C. E. Davila , Crane ChemPharma and Energy | R. A. Schmidt , Canadoil |
| B. Dennis , Kerkau Manufacturing | D. E. Tezzo , Emerson |
| J. G. Dominguez , Welding Outlets, Inc. | J. A. Tubb , JCM Industries, Inc. |
| R. T. Faircloth , Faircloth Consulting Services, LLC | G. T. Walden , Ferguson |
| G. B. Hailegiorgis , Forged Components, Inc. | M. M. Zaidi , Worley |
| M. M. Haynie , Bechtel | |

CORRESPONDENCE WITH THE B16 COMMITTEE

General. ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Standard should be sent to the staff secretary noted on the committee's web page, accessible at <https://go.asme.org/B16committee>.

Revisions and Errata. The committee processes revisions to this Standard on a continuous basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published in the next edition of the Standard.

In addition, the committee may post errata on the committee web page. Errata become effective on the date posted. Users can register on the committee web page to receive email notifications of posted errata.

This Standard is always open for comment, and the committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number, the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

Cases

(a) The most common applications for cases are

(1) to permit early implementation of a revision based on an urgent need

(2) to provide alternative requirements

(3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Standard

(4) to permit the use of a new material or process

(b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Standard.

(c) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:

(1) a statement of need and background information

(2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)

(3) the Standard and the paragraph, figure, or table number

(4) the editions of the Standard to which the proposed case applies

(d) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Approved cases are posted on the committee web page.

Interpretations. Upon request, the committee will issue an interpretation of any requirement of this Standard. An interpretation can be issued only in response to a request submitted through the online Inquiry Submittal Form at <https://go.asme.org/InterpretationRequest>. Upon submitting the form, the inquirer will receive an automatic email confirming receipt.

ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the information submitted, it is the opinion of the committee that the inquirer should seek assistance, the request will be returned with the recommendation that such assistance be obtained. Inquirers can track the status of their requests at <https://go.asme.org/Interpretations>.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Interpretations are published in the ASME Interpretations Database at <https://go.asme.org/Interpretations> as they are issued.

Committee Meetings. The B16 Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the committee. Information on future committee meetings can be found on the committee web page at <https://go.asme.org/B16committee>.

ASME B16.5-2025

SUMMARY OF CHANGES

Following approval by the ASME B16 Standards Committee and ASME, and after public review, ASME B16.5-2025 was approved by the American National Standards Institute on April 10, 2025.

In ASME B16.5-2025, titles of complementary tables have been editorially revised to indicate the applicable system of units. ASME B16.5-2025 also includes the following changes identified by a margin note, **(25)**. The Record Numbers listed below are explained in more detail in the "List of Changes in Record Number Order" following this Summary of Changes.

| <i>Page</i> | <i>Location</i> | <i>Change (Record Number)</i> |
|-------------|-----------------|--|
| 2 | 1.11 | Added (22-2279) |
| 2 | 2.2 | In second sentence, "must" revised to "shall" (22-2279) |
| 2 | 2.4 | Revised (21-1888) |
| 3 | 2.5.3 | Revised (21-1888) |
| 3 | 2.6 | Revised (21-1849) |
| 5 | Table 1.1-1 | (1) Revised (16-1229, 21-1888, 23-2509) (2) For Material Group 3.1, Nominal Composition 35Ni-35Fe-20Cr-Cb, Forgings and Plates specifications corrected by errata (21-1145) (3) For Material Group 3.6, Nominal Composition 33Ni-42Fe-21Cr, second specification under Forgings and Plates added by errata (21-1145) (4) For Material Group 3.12, Nominal Composition 46Fe-24Ni-21Cr-6Mo-Cu-N, first specification under Plates corrected by errata (21-1145) |
| 8 | 5.1.2 | Revised (21-1888) |
| 8 | 5.3.4 | Last sentence deleted (21-1888) |
| 8 | 5.3.5 | In subpara. (a), second sentence revised (22-2279) |
| 9 | Table 1.1-2 | (1) Under Intermediate Strength, Spec. No. A320, Grade L7M added; under Nickel and Special Alloy, Spec Nos. B511, B572, and B637 added (22-651) (2) Notes revised and reordered (21-1888, 21-2211, 22-651) |
| 10 | 6.1.1 | Second sentence revised (22-2279) |
| 14 | 7.3 | Editorially revised |
| 15 | 8.1 | Revised (21-1849) |
| 15 | Figure 1 | General Note (b) revised (22-567) |
| 15 | Figure 2 | General Note (b) revised (22-567) |
| 20 | Figure 7 | Hub height, <i>H</i> , and Note (1) added, and subsequent Note redesignated (22-2183) |
| 21 | Figure 8 | Hub height, <i>H</i> , and Note (1) added, and subsequent Note redesignated (22-2183) |
| 23 | Figure 12 | U.S. Customary values added by errata (21-1122) |
| 25 | Table 2-1.1 | Revised (21-1888, 22-564, 23-2509) |
| 26 | Table 2-1.1C | (1) Under Temp., °F, first entry revised (21-1888) (2) Notes revised and reordered (23-2509) |

| <i>Page</i> | <i>Location</i> | <i>Change (Record Number)</i> |
|-------------|-----------------|--|
| 27 | Table 2-1.2 | Revised (21-1888, 22-564, 23-2509) |
| 28 | Table 2-1.2C | Revised (21-1888, 23-2509) |
| 29 | Table 2-1.3 | Revised (21-1888, 22-564, 23-2509) |
| 30 | Table 2-1.3C | (1) Under Temp., °F, first entry revised (21-1888) (2) Notes revised and reordered (21-1888, 23-2509) |
| 31 | Table 2-1.4 | Revised (21-1888, 22-564, 23-2509) |
| 32 | Table 2-14C | (1) Under Temp., °F, first entry revised (21-1888) (2) Note (2) revised (21-1888, 23-2509) |
| 33 | Table 2-1.5 | Revised (21-1888, 22-564, 23-2509) |
| 34 | Table 2-1.5C | (1) Revised (21-1888, 23-2509) (2) Temperature in Note (1) corrected to Fahrenheit by errata (21-1145) |
| 35 | Table 2-1.7 | Revised (21-1888, 23-2509) |
| 36 | Table 2-1.7C | Revised (21-1888, 23-2509) |
| 37 | Table 2-1.9 | Revised (21-1888, 22-564, 23-2509) |
| 38 | Table 2-1.9C | Revised (21-1888, 23-2509) |
| 39 | Table 2-1.10 | Revised (21-1888, 22-564, 23-2509) |
| 40 | Table 2-1.10C | Revised (21-1888, 23-2509) |
| 41 | Table 2-1.11 | Revised (21-1888, 22-564, 23-2509) |
| 42 | Table 2-1.11C | Revised (21-1888, 23-2509) |
| 43 | Table 2-1.13 | Revised (21-1888, 23-2509) |
| 44 | Table 2-1.13C | Revised (21-1888, 23-2509) |
| 45 | Table 2-1.14 | Revised (21-1888, 23-2509) |
| 46 | Table 2-1.14C | Revised (21-1888, 23-2509) |
| 47 | Table 2-1.15 | Revised (21-1888, 23-2509) |
| 48 | Table 2-1.15C | Revised (21-1888, 23-2509) |
| 49 | Table 2-1.17 | Revised (21-1888, 22-564, 23-2509) |
| 50 | Table 2-1.17C | Revised (21-1888, 23-2509) |
| 51 | Table 2-1.18 | Revised (21-1888, 22-564, 23-2509) |
| 52 | Table 2-1.18C | Revised (21-1888, 23-2509) |
| 53 | Table 2-2.1 | Revised (21-1888, 22-564, 23-2509) |
| 54 | Table 2-2.1C | Revised (21-1888, 23-2509) |
| 55 | Table 2-2.2 | Revised (21-1888, 22-564, 23-2509) |
| 56 | Table 2-2.2C | Revised (21-1888, 23-2509) |
| 57 | Table 2-2.3 | Revised (21-1888, 22-564, 23-2509) |
| 58 | Table 2-2.3C | (1) Under Forgings and Plates, references to Note (1) added (23-2509) (2) Under Temp., °F, first entry revised (21-1888) (3) Note (1) revised and Note (2) added (21-1888, 23-2509) |
| 59 | Table 2-2.4 | Revised (21-1888, 22-564, 23-2509) |
| 60 | Table 2-2.4C | Revised (21-1888, 23-2509) |
| 61 | Table 2-2.5 | Revised (21-1888, 22-564, 23-2509) |
| 62 | Table 2-2.5C | Revised (21-1888, 23-2509) |
| 63 | Table 2-2.6 | Revised (21-1888, 23-2509) |
| 64 | Table 2-2.6C | Revised (21-1888, 23-2509) |
| 65 | Table 2-2.7 | Revised (21-1888, 22-564, 23-2509) |

| <i>Page</i> | <i>Location</i> | <i>Change (Record Number)</i> |
|-------------|-----------------|--|
| 66 | Table 2-2.7C | Revised (21-1888, 23-2509) |
| 67 | Table 2-2.8 | Revised (21-1888, 22-564, 23-2509) |
| 67 | Table 2-2.8C | Revised (21-1888, 23-2509) |
| 68 | Table 2-2.9 | Revised (21-1888, 22-564, 23-2509) |
| 69 | Table 2-2.9C | Revised (21-1888, 23-2509) |
| 70 | Table 2-2.10 | Revised (21-1888, 23-2509) |
| 71 | Table 2-2.10C | (1) Under Temp., °F, first entry revised (21-1888) (2) For 1,000°F, Working Pressure for Classes 400 through 2500 revised (23-2509) (3) Note (2) added (21-1888) |
| 72 | Table 2-2.11 | Revised (21-1888, 23-2509) |
| 73 | Table 2-2.11C | Revised (21-1888, 23-2509) |
| 74 | Table 2-2.12 | Revised (21-1888, 23-2509) |
| 75 | Table 2-2.12C | (1) Under Temp., °F, first entry revised (21-1888) (2) For 1,000°F, Working Pressure for Classes 400 through 2500 revised (23-2509) (3) Note (2) added (21-1888) |
| 76 | Table 2-2.13 | Added (21-1888, 23-2509) |
| 77 | Table 2-2.13C | Added (21-1888, 23-2509) |
| 78 | Table 2-3.1 | Revised (21-1888, 23-2509) |
| 78 | Table 2-3.1C | Revised (21-1888, 23-2509) |
| 79 | Table 2-3.2 | Revised (21-1888, 23-2509) |
| 79 | Table 2-3.2C | Revised (21-1888) |
| 80 | Table 2-3.3 | Revised (21-1888, 23-2509) |
| 81 | Table 2-3.3C | Revised (21-1888, 23-2509) |
| 82 | Table 2-3.4 | Revised (21-1888, 23-2509) |
| 83 | Table 2-3.4C | (1) Castings materials and Note (2) added (21-1888, 23-2509) (2) Under Temp., °F, first entry revised (21-1888) |
| 84 | Table 2-3.5 | Revised (21-1888, 23-2509) |
| 85 | Table 2-3.5C | Revised (21-1888, 23-2509) |
| 86 | Table 2-3.6 | (1) Revised (21-1888, 23-2509) (2) For Nominal Designation 33Ni-42Fe-21Cr, entries for Forgings and Plates corrected by errata (21-1145) |
| 87 | Table 2-3.6C | (1) Revised (21-1888, 23-2509) (2) For Nominal Designation 33Ni-42Fe-21Cr, entries for Forgings and Plates corrected by errata (21-1145) |
| 88 | Table 2-3.7 | Revised (16-1229, 21-1888, 23-2509) |
| 88 | Table 2-3.7C | Revised (21-1888, 23-2509) |
| 89 | Table 2-3.8 | Revised (16-1229, 21-1888, 22-564, 23-2509) |
| 90 | Table 2-3.8C | Revised (21-1888, 23-2509) |
| 91 | Table 2-3.9 | Revised (21-1888, 23-2509) |
| 92 | Table 2-3.9C | (1) Revised (21-1888, 23-2509) (2) Under Forgings, references to Note (2) added by errata (21-1145) |
| 93 | Table 2-3.10 | Revised (21-1888, 23-2509) |
| 93 | Table 2-3.10C | Revised (21-1888) |
| 94 | Table 2-3.11 | Revised (21-1888, 23-2509) |

| <i>Page</i> | <i>Location</i> | <i>Change (Record Number)</i> |
|-------------|-----------------|--|
| 94 | Table 2-3.11C | (1) Under Temp., °F, first entry revised (21-1888) (2) Note (2) revised (21-1888, 23-2509) |
| 95 | Table 2-3.12 | (1) Revised (16-1229, 21-1888, 23-2509) (2) For Nominal Designation 46Fe-24Ni-21Cr-6Mo-Cu-N, entry for Castings corrected by errata (21-1145) |
| 96 | Table 2-3.12C | (1) Revised (21-1888, 23-2509) (2) For Nominal Designation 46Fe-24Ni-21Cr-6Mo-Cu-N, entry for Castings corrected by errata (21-1145) |
| 97 | Table 2-3.13 | Revised (16-1229, 21-1888, 23-2509) |
| 97 | Table 2-3.13C | Revised (21-1888, 23-2509) |
| 98 | Table 2-3.14 | Revised (16-1229, 21-1888, 22-564, 23-2509) |
| 99 | Table 2-3.14C | Revised (21-1888, 23-2509) |
| 100 | Table 2-3.15 | Revised (21-1888, 23-2509) |
| 101 | Table 2-3.15C | Revised (21-1888, 23-2509) |
| 102 | Table 2-3.16 | Revised (21-1888, 23-2509) |
| 103 | Table 2-3.16C | Revised (21-1888, 23-2509) |
| 104 | Table 2-3.17 | Revised (21-1888, 23-2509) |
| 104 | Table 2-3.17C | Revised (21-1888) |
| 105 | Table 2-3.19 | Revised (21-1888, 23-2509) |
| 106 | Table 2-3.19C | Revised (21-1888, 23-2509) |
| 114 | Table 5 | For Class 2500 NPS 2½, groove depth <i>E</i> corrected by errata from 9.522 to 9.53 (21-1372) |
| 122 | Table 5C | Under NPS 24, dimensionless row deleted and table alignment corrected by errata (22-1148) |
| 131 | Table 7 | For NPS 20, outside diameter of flange, <i>O</i> , corrected by errata from 693 to 698 (21-1134) |
| 133 | Table 8 | (1) Figure revised (21-579, 22-2183, 23-628) (2) For NPS 14, outside diameter of flange, <i>O</i> , corrected by errata from 553 to 533 (21-1133) (3) Note (2) added and subsequent Notes redesignated (22-2183) |
| 136 | Table 8C | (1) Figure revised (21-579, 22-2183, 23-628) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 153 | Table 11 | (1) Figure revised (21-579, 22-2183, 23-628) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 156 | Table 11C | (1) Figure revised (21-579, 22-2183, 23-628) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 169 | Table 14 | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 171 | Table 14C | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 175 | Table 16 | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 178 | Table 16C | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 183 | Table 18 | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 186 | Table 18C | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |

| <i>Page</i> | <i>Location</i> | <i>Change (Record Number)</i> |
|-------------|-------------------------|--|
| 191 | Table 20 | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 193 | Table 20C | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 197 | Table 22 | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 199 | Table 22C | (1) Figure revised (21-579, 22-2183) (2) Note (2) added and subsequent Notes redesignated (22-2183) |
| 203 | Mandatory Appendix II | Updated (23-2265) |
| 209 | Table A-1 | Revised (21-1888, 22-2110) |
| 210 | Table A-2 | Revised (21-1888, 22-2110) |
| 247 | Nonmandatory Appendix G | Added (21-1888) |

LIST OF CHANGES IN RECORD NUMBER ORDER

| Record Number | Change |
|---------------|---|
| 16-1229 | Added ASTM B462 and ASTM B564 forging specification materials in Tables 1.1-1, 2-3.7, 2-3.8, 2-3.12, 2-3.13, 2-3.14, II-2-3.7, II-2-3.8, and II-2-3.12 through II-2-3.14. |
| 21-579 | Revised “B” dimension for slip-on, socket welding, welding neck, lapped flange figures in Tables 8, 11, 14, 16, 18, 20, and 22 (Tables 8C, 11C, 14C, 16C, 18C, 20C, and 22C). |
| 21-1133 | Errata correction. See Summary of Changes for details. |
| 21-1134 | Errata correction. See Summary of Changes for details. |
| 21-1145 | Errata corrections. See Summary of Changes for details. |
| 21-1372 | Errata correction. See Summary of Changes for details. |
| 21-1849 | Revised requirements in paras. 2.6 and 8.1 for system hydrostatic testing. |
| 21-1888 | Added guidance in paras. 2.4, 2.5.3, 5.1.2, and 5.3.4; General Notes in Tables 1.1-1 and 1.1-2, Tables 2-1.1 through 2-3.19 (Tables 2-1.1C through 2.3.19C), A-1, and A-2; and Nonmandatory Appendix G for determining minimum temperature for materials. |
| 21-2211 | Revised language to clarify “corresponding material” in Table 1.1-2 Notes (6) and (11). |
| 22-564 | Revised metric temperatures to the nearest degree in notes in Tables 2-1.1 through 2-1.5, 2-1.9 through 2-1.11, 2-1.17, 2-1.18, 2-2.1 through 2-2.5, 2-2.7 through 2-2.9, 2-3.8, and 2-3.14. |
| 22-567 | Revised General Note (b) in Figures 1 and 2. |
| 22-651 | Added ASTM A320 L7M, ASTM B511 N08830, ASTM B572 N06230, ASTM B637 N07740, and ASTM B637 N07718 materials in Table 1.1-2. |
| 22-1148 | Errata correction. See Summary of Changes for details. |
| 22-2110 | Revised ceiling pressures in Tables A-1 and A-2. |
| 22-2183 | Revised method to determine the minimum hub height in Figures 7 and 8 and Tables 8, 11, 14, 16, 18, 20, 22 (Tables 8C, 11C, 14C, 16C, 18C, 20C, and 22C). |
| 22-2279 | Added para. 1.11 to define “may,” “shall,” and “should. Revised paras. 5.3.4 and 6.1.1 to align with the added definitions. |
| 23-628 | Revised Table 8 (Table 8C) Class 150 threaded figure to have the threads continue to the flanged face. Revised Table 11 (Table 11C) Class 300 threaded figures to include a counterbore. |
| 23-2265 | Updated references in Mandatory Appendix II. |
| 23-2509 | Revised pressure–temperature ratings in Tables 2-1.1 through 2-3.19 (Tables 2-1.1C through 2-3.19C). Added Table 2-2.13 (Table 2-2.13C) for group material 2.13 for duplex materials. Revised Table 1.1-1. |

INTENTIONALLY LEFT BLANK

PIPE FLANGES AND FLANGED FITTINGS

NPS ½ Through NPS 24 Metric/Inch Standard

1 GENERAL

1.1 Scope

(a) This Standard covers pressure–temperature ratings, materials, dimensions, tolerances, marking, testing, and methods of designating openings for pipe flanges and flanged fittings. Included are

(1) flanges with rating class designations 150, 300, 400, 600, 900, and 1500 in sizes NPS ½ through NPS 24 and flanges with rating class designation 2500 in sizes NPS ½ through NPS 12, with requirements given in both metric and U.S. Customary units with diameter of bolts and flange bolt holes expressed in inch units

(2) flanged fittings with rating class designation 150 and 300 in sizes NPS ½ through NPS 24, with requirements given in both metric and U.S. Customary units with diameter of bolts and flange bolt holes expressed in inch units

(3) flanged fittings with rating class designation 400, 600, 900, and 1500 in sizes NPS ½ through NPS 24 and flanged fittings with rating class designation 2500 in sizes ½ through NPS 12 that are acknowledged in [Nonmandatory Appendix E](#) in which only U.S. Customary units are provided

(b) This Standard is limited to

(1) flanges and flanged fittings made from cast or forged materials

(2) blind flanges and certain reducing flanges made from cast, forged, or plate materials (see [Tables 1.1-1 through 1.1-3](#))

Also included in this Standard are requirements and recommendations regarding flange bolting, gaskets, and joints.

1.2 References

Codes, standards, and specifications, containing provisions to the extent referenced herein, constitute requirements of this Standard. These reference documents are listed in [Mandatory Appendix II](#).

1.3 Time of Purchase, Manufacture, or Installation

The pressure–temperature ratings in this Standard are applicable upon its publication to all flanges and flanged fittings within its scope, which otherwise meet its requirements. For unused flanges or flanged fittings maintained

in inventory, the manufacturer of the flange or flanged fittings may certify conformance to this edition, provided that it can be demonstrated that all requirements of this edition have been met. Where such components were installed in accordance with the pressure–temperature ratings of an earlier edition of this Standard, those ratings are applicable except as may be governed by the applicable code or regulation.

1.4 User Accountability

This Standard cites duties and responsibilities that are to be assumed by the flange or flanged fitting user in the areas of, for example, application, installation, system hydrostatic testing, operation, and material selection.

1.5 Quality Systems

Requirements relating to the product manufacturer's Quality System Program are described in [Nonmandatory Appendix D](#).

1.6 Relevant Units

This Standard states values in both SI (Metric) and U.S. Customary units. As an exception, diameter of bolts and flange bolt holes are expressed in inch units only. These systems of units are to be regarded separately as standard. Within the text, the U.S. Customary units are shown in parentheses or in separate tables following the SI tables. The values stated in each system are not exact equivalents; therefore, it is required that each system of units be used independently of the other. Except for diameter of bolts and flange bolt holes, combining values from the two systems constitutes nonconformance with the Standard. [Nonmandatory Appendix F](#) describes how the values expressed in SI units were established.

1.7 Selection of Materials

Criteria for selection of materials suitable for particular fluid service are not within the scope of this Standard.

1.8 Convention

For determining conformance with this Standard, the convention for fixing significant digits where limits (maximum and minimum values) are specified shall be as defined in ASTM E29. This requires that an observed