

ASME B31.3-2020
(Revision of ASME B31.3-2018)

Process Piping

ASME Code for Pressure Piping, B31

AN INTERNATIONAL PIPING CODE®



**The American Society of
Mechanical Engineers**

ASME B31.3-2020
(Revision of ASME B31.3-2018)

Process Piping

ASME Code for Pressure Piping, B31

AN INTERNATIONAL PIPING CODE®



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: June 18, 2021

The next edition of this Code is scheduled for publication in 2022. This Code will become effective 6 months after the Date of Issuance.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations are published on the Committee web page and under <http://go.asme.org/InterpsDatabase>. Periodically certain actions of the ASME B31 Committee may be published as Cases. Cases are published on the ASME website under the B31 Committee page at <http://go.asme.org/B31committee> as they are issued.

Errata to codes and standards may be posted on the ASME website under the Committee Pages of the associated codes and standards to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The B31 Committee Page can be found at <http://go.asme.org/B31committee>. The associated B31 Committee Page for each code and standard can be accessed from this main page. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" an item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2021 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	xi
Committee Roster	vi
Introduction	xx
Summary of Changes	xxii
Chapter I	1
Scope and Definitions	1
300 General Statements	1
Chapter II	11
Design	11
Part 1	11
Conditions and Criteria	11
301 Design Conditions	11
302 Design Criteria	13
Part 2	20
Pressure Design of Piping Components	20
303 General	20
304 Pressure Design of Components	20
Part 3	32
Fluid Service Requirements for Piping Components	32
305 Pipe	32
306 Fittings, Bends, Miters, Laps, and Branch Connections	33
307 Valves and Specialty Components	34
308 Flanges, Blanks, Flange Facings, and Gaskets	34
309 Bolting	35
Part 4	36
Fluid Service Requirements for Piping Joints	36
310 General	36
311 Welded Joints	36
312 Flanged Joints	36
313 Expanded Joints	37
314 Threaded Joints	37
315 Tubing Joints	37
316 Caulked Joints	38
317 Soldered and Brazed Joints	38
318 Special Joints	38
Part 5	38
Flexibility and Support	38
319 Piping Flexibility	38
320 Analysis of Sustained Loads	43
321 Piping Support	44
Part 6	46
Systems	46
322 Specific Piping Systems	46
Chapter III	48
Materials	48
323 General Requirements	48
325 Materials — Miscellaneous	58

Chapter IV	Standards for Piping Components	59
326	Dimensions and Ratings of Components	59
Chapter V	Fabrication, Assembly, and Erection	63
327	General	63
328	Welding and Brazing	63
330	Preheating	71
331	Heat Treatment	73
332	Bending and Forming	75
333	Brazing and Soldering	78
335	Assembly and Erection	78
Chapter VI	Inspection, Examination, and Testing	81
340	Inspection	81
341	Examination	81
342	Examination Personnel	88
343	Examination Procedures	88
344	Types of Examination	88
345	Testing	90
346	Records	94
Chapter VII	Nonmetallic Piping and Piping Lined With Nonmetallic	95
A300	General Statements	95
Part 1	Conditions and Criteria	95
A301	Design Conditions	95
A302	Design Criteria	95
Part 2	Pressure Design of Piping Components	97
A303	General	97
A304	Pressure Design of Piping Components	97
Part 3	Fluid Service Requirements for Piping Components	99
A305	Pipe	99
A306	Fittings, Bends, Miters, Laps, and Branch Connections	99
A307	Valves and Specialty Components	99
A308	Flanges, Blanks, Flange Facings, and Gaskets	99
A309	Bolting	100
Part 4	Fluid Service Requirements for Piping Joints	100
A310	General	100
A311	Bonnet Joints in Plastics	100
A312	Flanged joints	100
A313	Expanded Joints	100
A314	Threaded Joints	100
A315	Tubing Joints	101
A316	Caulked Joints	101
A318	Special Joints	101
Part 5	Flexibility and Support	101
A319	Flexibility of Nonmetallic Piping	101
A321	Piping Support	103
Part 6	Systems	103

A322	Specific Piping Systems	103
Part 7	Materials	104
A323	General Requirements	104
A325	Materials — Miscellaneous	105
Part 8	Standards for Piping Components	105
A326	Dimensions and Ratings of Components	105
Part 9	Fabrication, Assembly, and Erection	106
A327	General	106
A328	Bonding of Plastics	107
A329	Fabrication of Piping Lined With Nonmetals	112
A332	Bending and Forming	112
A334	Joining Nonplastic Piping	112
A335	Assembly and Erection	112
Part 10	Inspection, Examination, and Testing	113
A340	Inspection	113
A341	Examination	113
A342	Examination Personnel	114
A343	Examination Procedures	114
A344	Types of Examination	114
A345	Testing	115
A346	Records	115
Chapter VIII	Piping for Category M Fluid Service	116
M300	General Statements	116
Part 1	Conditions and Criteria	116
M301	Design Conditions	116
M302	Design Criteria	116
Part 2	Pressure Design of Metallic Piping Components	116
M303	General	116
M304	Pressure Design of Metallic Components	116
Part 3	Fluid Service Requirements for Metallic Piping Components	116
M305	Pipe	116
M306	Metallic Fittings, Bends, Miters, Laps, and Branch Connections	117
M307	Metallic Valves and Specialty Components	117
M308	Flanges, Blanks, Flange Facings, and Gaskets	117
M309	Coating	118
Part 4	Fluid Service Requirements for Metallic Piping Joints	118
M310	Metallic Piping, General	118
M311	Welded Joints in Metallic Piping	118
M312	Flanged Joints in Metallic Piping	118
M313	Expanded Joints in Metallic Piping	118
M314	Threaded Joints in Metallic Piping	118
M315	Tubing Joints in Metallic Piping	118
M316	Caulked Joints	118
M317	Soldered and Brazed Joints	118
M318	Special Joints in Metallic Piping	118

Part 5	Flexibility and Support of Metallic Piping	118
M319	Flexibility of Metallic Piping	118
M320	Analysis of Sustained Loads	118
M321	Piping Support	118
Part 6	Systems	119
M322	Specific Piping Systems	119
Part 7	Metallic Materials	119
M323	General Requirements	119
M325	Materials — Miscellaneous	119
Part 8	Standards for Piping Components	119
M326	Dimensions and Ratings of Components	119
Part 9	Fabrication, Assembly, and Erection of Metallic Piping	120
M327	General	120
M328	Welding of Metals	120
M330	Preheating of Metals	120
M331	Heat Treatment of Metals	120
M332	Bending and Forming of Metals	120
M335	Assembly and Erection of Metallic Piping	120
Part 10	Inspection, Examination, Testing, and Records of Metallic Piping	120
M340	Inspection	120
M341	Examination	120
M342	Examination Personnel	121
M343	Examination Procedures	121
M344	Types of Examination	121
M345	Testing	121
M346	Records	121
	Parts 11 Through 20, Corresponding to Chapter VII	121
MA300	General Statements	121
Part 11	Conditions and Criteria	121
MA301	Design Conditions	121
MA302	Design Criteria	121
Part 12	Pressure Design of Nonmetallic Piping Components	121
MA303	General	121
MA304	Pressure Design of Nonmetallic Components	121
Part 13	Fluid Service Requirements for Nonmetallic Piping Components	121
MA305	Pipes	121
MA306	Nonmetallic Fittings, Bends, Miters, Laps, and Branch Connections	121
MA307	Valves and Specialty Components	122
MA308	Flanges, Blanks, Flange Facings, and Gaskets	122
MA309	Bolting	122
Part 14	Fluid Service Requirements for Nonmetallic Piping Joints	122
MA310	General	122
MA311	Bonded Joints	122
MA312	Flanged Joints	122
MA313	Expanded Joints	122

MA314	Threaded Joints	122
MA315	Tubing Joints in Nonmetallic Piping	122
MA316	Caulked Joints	122
MA318	Special Joints	122
Part 15	Flexibility and Support of Nonmetallic Piping	122
MA319	Piping Flexibility	122
MA321	Piping Support	122
Part 16	Nonmetallic and Nonmetallic-Lined Systems	122
MA322	Specific Piping Systems	122
Part 17	Nonmetallic Materials	122
MA323	General Requirements	122
Part 18	Standards for Nonmetallic and Nonmetallic-Lined Piping Components	123
MA326	Dimensions and Ratings of Components	123
Part 19	Fabrication, Assembly, and Erection of Nonmetallic and Nonmetallic-Lined Piping	123
MA327	General	123
MA328	Bonding of Plastics	123
MA329	Fabrication of Piping Lined With Nonmetals	123
MA332	Bending and Forming	123
MA334	Joining Nonplastic Piping	123
MA335	Assembly and Erection	123
Part 20	Inspection, Examination, Testing, and Records of nonmetallic and Nonmetallic-Lined Piping	123
MA340	Inspection	123
MA341	Examination	123
MA342	Examination Personnel	123
MA343	Examination Procedures	123
MA344	Types of Examination	123
MA345	Testing	123
MA346	Records	123
Chapter IX	High Pressure Piping	124
K300	General Statement	124
Part 1	Conditions and Criteria	124
K301	Design Conditions	124
K302	Design Criteria	125
Part 2	Pressure Design of Piping Components	127
K303	General	127
K304	Pressure Design of High Pressure Components	127
Part 3	Fluid Service Requirements for Piping Components	130
K305	Pipe	130
K306	Fittings, Bends, and Branch Connections	131
K307	Valves and Specialty Components	131
K308	Flanges, Blanks, Flange Facings, and Gaskets	131
K309	Bolting	132
Part 4	Fluid Service Requirements for Piping Joints	132
K310	General	132

K311	Welded Joints	132
K312	Flanged Joints	132
K313	Expanded Joints	132
K314	Threaded Pipe Joints	132
K315	Tubing Joints	133
K316	Caulked Joints	133
K317	Soldered and Brazed Joints	133
K318	Special Joints	133
Part 5	Flexibility and Support	133
K319	Flexibility	133
K320	Analysis of Sustained Loads	133
K321	Piping Support	134
Part 6	Systems	134
K322	Specific Piping Systems	134
Part 7	Materials	134
K323	General Requirements	134
K325	Miscellaneous Materials	138
Part 8	Standards for Piping Components	138
K326	Requirements for Components	138
Part 9	Fabrication, Assembly, and Erection	139
K327	General	139
K328	Welding	140
K330	Preheating	141
K331	Heat Treatment	141
K332	Bending and Forming	142
K333	Brazing and Soldering	143
K335	Assembly and Erection	144
Part 10	Inspection, Examination, and Testing	144
K340	Inspection	144
K341	Examination	144
K342	Examination Personnel	147
K343	Examination Procedures	147
K344	Types of Examination	147
K345	Leak Testing	148
K346	Records	149
Chapter X	High-Purity Piping	150
U300	General Statements	150
Part 1	Conditions and Criteria	150
U301	Design Conditions	150
Part 2	Pressure Design of Piping Components	150
Part 3	Fluid Service Requirements for Piping Components	150
U306	Fittings, Bends, Miters, Laps, and Branch Connections	150
U307	Valves and Specialty Components	150
U308	Flanges, Blanks, Flange Facings, and Gaskets	150
Part 4	Fluid Service Requirements for Piping Joints	151

U311	Welded Joints	151
U314	Threaded Joints	151
U315	Tubing Joints	151
Part 5	Flexibility and Support	151
U319	Piping Flexibility	151
Part 6	Systems	151
Part 7	Metallic Materials	151
Part 8	Standards for Piping Components	152
Part 9	Fabrication, Assembly, and Erection	152
U327	General	152
U328	Welding	152
U330	Preheating	152
U331	Heat Treatment	152
U332	Bending and Forming	153
U333	Brazing and Soldering	153
U335	Assembly and Erection	153
Part 10	Inspection, Examination, and Testing	153
U340	Inspection	153
U341	Examination	153
U342	Examination Personnel	154
U343	Examination Procedures	154
U344	Types of Examination	155
U345	Testing	156
U346	Records	156
Part 11	High Purity Piping in Category M Fluid Service	156
UM300	General Statements	156
UM307	Metallic Valves and Specialty Components	156
UM322	Specific Piping Systems	156
UM328	Welding of Materials	157
UM335	Assembly and Erection of Metallic Piping	157
UM341	Examination	157
UM345	Testing	157
Appendices		
A	Allowable Stresses and Quality Factors for Metallic Piping and Bolting Materials	158
B	Stress Tables and Allowable Pressure Tables for Nonmetals	384
C	Physical Properties of Piping Materials	391
D	Flexibility and Stress Intensification Factors	412
E	Reference Standards	413
F	Guidance and Precautionary Considerations	419
G	Safeguarding	426
H	Sample Calculations for Branch Reinforcement	428
J	Nomenclature	437
K	Allowable Stresses for High Pressure Piping	453
L	Aluminum Alloy Pipe Flanges	470

M	Guide to Classifying Fluid Services	473
N	Application of ASME B31.3 Internationally	475
Q	Quality System Program	476
R	Use of Alternative Ultrasonic Acceptance Criteria	477
S	Piping System Stress Analysis Examples	480
V	Allowable Variations in Elevated Temperature Service	494
W	High-Cycle Fatigue Assessment of Piping Systems	497
X	Metallic Bellows Expansion Joints	502
Z	Preparation of Technical Inquiries	506

Index	507
--------------	-----------	-----

Figures

300.1.1	Diagram Illustrating Application of B31.3 Piping at Equipment	3
302.3.5	Stress Range Factor, f	19
304.2.1	Nomenclature for Pipe Bends	23
304.2.3	Nomenclature for Miter Bends	24
304.3.3	Branch Connection Nomenclature	27
304.3.4	Extruded Outlet Header Nomenclature	29
304.5.3	Blanks	31
319.4.4A	Moments in Bends	42
319.4.4B	Moments in Branch Connections	42
323.2.2A	Minimum Temperatures Without Impact Testing for Carbon Steel Materials	51
323.2.2B	Reduction in Lowest Exemption Temperature for Steels Without Impact Testing	53
328.3.2	Typical Backing Rings and Consumable Inserts	65
328.4.2	Typical Butt Weld End Preparation	65
328.4.3	Trimming and Permitted Misalignment	66
328.4.4	Preparation for Branch Connections	67
328.5.2A	Fillet and Socket Weld Sizes	67
328.5.2B	Minimum Attachment Weld Dimensions for Double-Welded Slip-On and Socket Welding Flanges	67
328.5.2C	Minimum Attachment Weld Dimensions for Socket Welding Components Other Than Flanges	68
328.5.4A, B, C	Typical Welded Branch Connections	68
328.5.4D	Acceptable Details for Branch Attachment Welds	69
328.5.4E	Acceptable Details for Branch Attachments Suitable for 100% Radiography	69
328.5.4F	Acceptable Details for Integrally Reinforced Branch Connections	70
328.5.5	Typical Fabricated Laps	71
335.3.3	Typical Threaded Joints Using Straight Threads	80
341.3.2	Typical Weld Imperfections	83
A328.5.3	Thermoplastic Solvent Cemented Joint	110
A328.5.4	Thermoplastic Heat Fusion Joints	111
A328.5.5	Thermoplastic Electrofusion Joints	111
A328.5.6	Fully Tapered Thermosetting Adhesive Joint	111
A328.5.7	Thermosetting Wrapped Joints	112

K323.3.3	Example of an Acceptable Impact Test Specimen	137
K328.4.3	Pipe Bored for Alignment: Trimming and Permitted Misalignment	141
K328.5.4	Some Acceptable Welded Branch Connections Suitable for 100% Radiography	142
U304.5.3	Blanks	151
U328.4.2	Modified Pipe End Preparations	153
U335.7.1	Face Seal Joints	154
U335.8A	Hygienic Clamp Joint Assembly	154
U335.8B	Hygienic Clamp Types	155
U335.8C	Hygienic Ferrules	155
H301	Illustrations for SI Units Examples in Appendix H	430
H311	Illustrations for U.S. Customary Units Examples in Appendix H	434
M300	Guide to Classifying Fluid Services	474
R307	Surface and Subsurface Flaws	478
S301.1	Simple Code-Compliant Model	480
S302.1	Lift-Off Model	485
S303.1	Moment Reversal Model	488
 Tables		
300.4	Status of Appendices in B31.3	10
302.3.3C	Increased Casting Quality Factors, E_c	16
302.3.3D	Acceptance Levels for Castings	17
302.3.4	Longitudinal Weld Joint Quality Factor, E_j	18
302.3.5	Weld Joint Strength Reduction Factor, W	21
304.1.1	Values of Coefficient Y for $t < D/6$	23
304.4.1	ASME BPVC References for Closures	30
308.2.1	Permissible Sizes/Rating Classes for Slip-On Flanges Used as Lapped Flanges	35
314.2.1	Minimum Schedule of Components With External Threads	37
323.2.2	Requirements for Low Temperature Toughness Tests for Metals	49
323.2.2A	Tabular Values for Minimum Temperatures Without Impact Testing for Carbon Steel Materials	52
323.2.2B	Tabular Values for Reduction in Lowest Exemption Temperature for Steels Without Impact Testing	54
323.3.1	Impact Testing Requirements for Metals	56
323.3.4	Charpy Impact Test Temperature Reduction	57
323.3.5	Minimum Required Charpy V-Notch Impact Values	58
326.1	Component Standards	60
330.1.1	Preheat Temperatures	72
331.1.1	Postweld Heat Treatment	74
331.1.2	Alternate Postweld Heat Treatment Requirements for Carbon and Low Alloy Steels, P-Nos. 1 and 3	75
331.1.3	Exemptions to Mandatory Postweld Heat Treatment	76
341.3.2	Acceptance Criteria for Welds — Visual and Radiographic Examination	84
A323.2.2	Requirements for Low Temperature Toughness Tests for Nonmetals	105
A323.4.2C	Recommended Temperature Limits for Reinforced Thermosetting Resin Pipe	105
A323.4.3	Recommended Temperature Limits for Thermoplastics Used as Linings	105
A326.1	Component Standards	107

A341.3.2	Acceptance Criteria for Bonds	114
K302.3.3D	Acceptable Severity Levels for Steel Castings	127
K305.1.2	Required Ultrasonic or Eddy Current Examination of Pipe and Tubing for Longitudinal Defects	131
K323.3.1	Impact Testing Requirements	136
K323.3.5	Minimum Required Charpy V-Notch Impact Values	137
K326.1	Component Standards	139
K341.3.2	Acceptance Criteria for Welds	145
	Criterion Value Notes for Table K341.3.2	146
	Specification Index for Appendix A	159
A-1	Basic Allowable Stresses in Tension for Metals	167
A-1M	Basic Allowable Stresses in Tension for Metals (SI Units)	242
A-1A	Basic Casting Quality Factors, E_c	348
A-1B	Basic Quality Factors for Longitudinal Weld Joints in Pipes and Tubes, E_j	349
A-2	Design Stress Values for Bolting Materials	354
A-2M	Design Stress Values for Bolting Materials (SI Units)	364
	Specification Index for Appendix B	385
B-1	Hydrostatic Design Stresses (HDS) and Recommended Temperature Limits for Thermoplastic Pipe	386
B-1M	Hydrostatic Design Stresses (HDS) and Recommended Temperature Limits for Thermoplastic Pipe (SI Units)	388
B-2	Listed Specifications for Laminated Reinforced Thermosetting Resin Pipe	389
B-3	Listed Specifications for Filament Wound and Centrifugally Cast Reinforced Thermosetting Resin and Reinforced Plastic Mortar Pipe	389
B-4	Allowable Pressures and Recommended Temperature Limits for Concrete Pipe	390
B-5	Allowable Pressures and Recommended Temperature Limits for Borosilicate Glass Pipe	390
B-6	Allowable Pressures and Recommended Temperature Limits for PEX-AL-PEX and PE-AL-PE Pipe	390
C-1	Thermal Expansion Data	392
C-1M	Thermal Expansion Data (SI Units)	396
C-5	Thermal Expansion Coefficients, Nonmetals	401
C-6	Moduli of Elasticity for Metals	403
C-6M	Moduli of Elasticity for Metals (SI Units)	407
C-8	Modulus of Elasticity, Nonmetals	411
	Specification Index for Appendix K	454
K-1	Allowable Stresses in Tension for Metals for Chapter IX	456
L301.2M	Pressure–Temperature Ratings (SI Units)	471
L301.2U	Pressure–Temperature Ratings (U.S. Customary Units)	471
L303.2	Aluminum Bolting Materials	472
R308.1	Acceptance Criteria for Surface Flaws	479
R308.2	Acceptance Criteria for Subsurface Flaws	479
S301.1	Pressure–Temperature Combinations	481
S301.3.1	Generic Pipe Stress Model Input	481
S301.3.2	Element Connectivity, Type, and Lengths	482
S301.5.1	Operating Load Case Results: Internal Loads and Deflections	482

S301.5.2	Operating Load Case Results: Reaction Loads on Supports and Anchors	483
S301.6	Sustained Forces, Moments, and Stresses [Allowable $S_h = 130.8$ MPa (19.0 ksi)]	483
S301.7	Displacement Stress Range [Allowable, Eq. (1a), $S_A = 205.2$ MPa (29.75 ksi)]	484
S302.2	Pressure–Temperature Combinations	485
S302.3	Generic Pipe Stress Model Input: Component Connectivity, Type, and Lengths	486
S302.5	Results for Operating Case: Reactions on Support and Anchors	486
S302.6.2	Sustained Load Condition Listing	487
S302.6.3	Sustained Forces, Moments, and Stresses for Sustained Condition 3 With Node 50’s Y+ Support Inactive [Allowable $S_h = 127$ MPa (18.4 ksi): Fails]	487
S303.1	Pressure–Temperature Combinations	489
S303.3	Generic Pipe Stress Model Input: Component Connectivity, Type, and Lengths	490
S303.7.1	Operating Case 1: Displacement Stress Range [Eq. (1b) Allowable $S_A = 364$ MPa (52.7 ksi): Passes]	491
S303.7.2	Operating Case 2: Displacement Stress Range [Eq. (1b) Allowable $S_A = 364$ MPa (52.7 ksi): Passes]	492
S303.7.3	Moment Reversal Load Combination Considering Operating Cases 1 and 2, Total Strain Based: Displacement Stress Range [Eq. (1b) Allowable $S_A = 364$ MPa (52.7 ksi): Fails]	493
W301-1	Gamma Function Evaluation	498
W302.1-1	Fatigue Material Coefficients (-3σ)	499
W302.1-2	Fatigue Material Coefficients (-2σ)	499
W302.1-3	Optional Fatigue Material Coefficients When $N_{ti} > 10^7$	499
W302.1-4	Environmental Fatigue Factors for Carbon Steel Piping, $T \leq 93^\circ\text{C}$ (200°F)	500

FOREWORD

Responding to evident need and at the request of The American Society of Mechanical Engineers (ASME), the American Standards Association initiated Project B31 in March 1926, with ASME as sole administrative sponsor. The breadth of the field involved required that membership of the Sectional Committee be drawn from some 40 engineering societies, industries, government bureaus, institutes, and trade associations.

Initial publication in 1935 was as the American Tentative Standard Code for Pressure Piping. Revisions from 1942 through 1955 were published as American Standard Code for Pressure Piping, ASA B31.1. It was then decided to publish as separate documents the various industry Sections, beginning with ASA B31.8-1955, Gas Transmission and Distribution Piping Systems. The first Petroleum Refinery Piping Code Section was designated ASA B31.3-1959. ASA B31.3 revisions were published in 1962 and 1966.

In 1967–1969, the American Standards Association became first the United States of America Standards Institute, then the American National Standards Institute (ANSI). The Sectional Committee became American National Standards Committee B31 and the Code was renamed the American National Standard Code for Pressure Piping. The next B31.3 revision was designated ANSI B31.3-1973. Addenda were published through 1975.

A draft Code Section for Chemical Plant Piping, prepared by Section Committee B31.6, was ready for approval in 1974. It was decided, rather than have two closely related Code Sections, to merge the Section Committees and develop a joint Code Section, titled Chemical Plant and Petroleum Refinery Piping. The first edition was published as ANSI B31.3-1976.

In this Code, responsibility for piping design was conceptually integrated with that for the overall processing facility, with safeguarding recognized as an effective safety measure. Three categories of Fluid Service were identified, with a separate Chapter for Category M Fluid Service. Coverage for nonmetallic piping was introduced. New concepts were better defined in five Addenda, the fourth of which added Appendix M, a graphic aid to selection of the proper Fluid Service category.

The Standards Committee was reorganized in 1978 as a Committee operating under ASME procedures with ANSI accreditation. It is now the ASME Code for Pressure Piping, B31 Committee. Section committee structure remains essentially unchanged.

The second edition of Chemical Plant and Petroleum Refinery Piping was compiled from the 1976 Edition and its five Addenda, with nonmetal requirements editorially relocated to a separate Chapter. Its new designation was ANSI/ASME B31.3-1980.

Section Committee B31.10 had a draft Code for Cryogenic Piping ready for approval in 1981. Again, it was decided to merge the two Section Committees and develop a more inclusive Code with the same title. The work of consolidation was partially completed in the ANSI/ASME B31.3-1984 Edition.

Significant changes were made in Addenda to the 1984 Edition: integration of cryogenic requirements was completed; a new stand-alone Chapter on high-pressure piping was added; and coverage of fabrication, inspection, testing, and allowable stresses was reorganized. The new Edition was designated as ASME/ANSI B31.3-1987 Edition.

Addenda to the subsequent five Editions, published at 3-year intervals, were primarily used to keep the Code up to date. New Appendices were added, however, on requirements for bellows expansion joints, estimating service life, submittal of Inquiries, aluminum flanges, and quality control in the 1990, 1993, 1999, and 2002 Editions, all designated as ASME B31.3.

In a program to clarify the application of all Sections of the Code for Pressure Piping, changes were made in the Introduction and Scope statements of the 1996 Edition, and its title was changed to Process Piping.

Under direction of ASME Codes and Standards management, SI (metric) units of measurement were emphasized. With certain exceptions, SI units were listed first in the 1996 Edition and were designated as the standard. Instructions for conversion were given where SI units data were not available. U.S. Customary units also were given. By agreement, either system may have been used.

Beginning with the 2004 Edition, the publication cycle of ASME B31.3 was changed to biennial. Other changes made in the 2004 Edition included the introduction of the weld joint strength reduction factor, W , and the additions of Appendix P, Alternative Rules for Evaluating Stress Range, and Appendix S, Piping System Stress Analysis Examples.

Changes that were made to the 2006 and 2008 Editions of ASME B31.3 included the requirement that valves have blowout-proof stems and the addition of a definition for elevated temperature fluid service, respectively. The most significant change that was made to the 2010 Edition of ASME B31.3 was the addition of Chapter X, High Purity

Piping. In the 2012 Edition, Tables A-1M and A-2M were added to Appendix A that give allowable design values in SI units, and Appendix N, Application of ASME B31.3 Internationally, was also added.

For the 2016 Edition, the allowable design values in SI units as shown in Tables A-1M and A-2M were changed from for information only to values that may be used to meet the requirements of the Code.

In this Edition, SI units are given first, with U.S. Customary units in parentheses. Table K-1 in Appendix K is an exception, containing only U.S. Customary units. The allowable design values in Tables A-1 and A-2 are given in U.S. Customary units, and the SI values are given in Tables A-1M and A-2M. Either the U.S. Customary units or the SI units for these allowable design values may be used. Except for Tables A-1, A-1M, A-2, A-2M, C-1, C-1M, C-6, C-6M, and K-1, values in SI units are to be regarded as the standard, unless otherwise agreed between the contracting parties. Instructions are given in Table K-1 for converting tabular data in U.S. Customary units to appropriate SI units.

Interpretations, Code Cases, and errata to the B31.3 Code on Process Piping are published on the following ASME web page: <https://cstools.asme.org/csconnect/CommitteePages.cfm?Committee=N10020400>.

ASME B31.3-2020 was approved by the American National Standards Institute on September 29, 2020.

ASME B31 COMMITTEE

Code for Pressure Piping

(The following is the roster of the Committee at the time of approval of this Code.)

STANDARDS COMMITTEE OFFICERS

C. H. Eskridge, Jr., *Chair*
K. A. Vilminot, *Vice Chair*
J. Oh, *Secretary*

STANDARDS COMMITTEE PERSONNEL

R. J. T. Appleby , Consultant	R. W. Haupt , Pressure Piping Engineering Associates, Inc.
K. C. Bodenhamer , TRC Pipeline Services	G. A. Jolly , Samshin Ltd.
R. M. Bojarczuk , ExxonMobil Research and Engineering Co.	K. Kaplan , Consultant
M. R. Braz , MRBraz & Associates, PLLC	C. Kolovich , Quest Integrity
M. Burkhart , The Burkhart Group, Inc.	W. J. Mauro , Retired
R. D. Campbell , Bechtel	J. E. Meyer , CDM Smith — Industrial Division
J. S. Chin , TC Energy	T. Monday , Team Industries, Inc.
D. D. Christian , Victaulic	M. L. Nayyar , NICE
R. P. Deubler , Becht Engineering Co., Inc.	J. Oh , The American Society of Mechanical Engineers
D. W. Diehl , Hexagon PPM	D. W. Raho , CCM 2000
M. Engelkemier , Cargill	R. K. Reamey , Turner Industries Group, LLC
C. H. Eskridge, Jr. , Worley ECR	M. J. Rosenfeld , RSI Pipeline Solutions, LLC
D. J. Fetzner , Retired	J. T. Schmitz , Southwest Gas Corp.
P. D. Flenner , Flenner Engineering Services	S. K. Sinha , Lucius Pitkin, Inc.
J. W. Frey , Joe W. Frey Engineering Services, LLC	W. J. Sperko , Sperko Engineering Services, Inc.
D. R. Frikken , Becht Engineering Co.	F. W. Tatar , FM Global
R. A. Grichuk , S&B Engineers and Constructors, Ltd.	K. A. Vilminot , Commonwealth Associates, Inc.

B31.3 PROCESS PIPING SECTION COMMITTEE

D. W. Diehl , <i>Chair</i> , Hexagon PPM	B. K. Henon , Arc Machines, Inc., Retired
C. H. Eskridge, Jr. , <i>Vice Chair</i> , Worley ECR	W. M. Huitt , W. M. Huitt Co.
R. Mohamed , <i>Secretary</i> , The American Society of Mechanical Engineers	D. L. Ianiro , Mainthia Technologies, Inc.
B. L. Agee , GE Energy	J. Kalnins , Plastic-Lined Pipe Solutions
D. Arnett , ExxonMobil Research and Engineering Co.	C. Larsen , Team Industrial Services
C. Becht IV , Becht Engineering Co.	R. A. Leishear , Leishear Engineering, LLC
R. M. Bojarczuk , ExxonMobil Research and Engineering Co.	M. McDaniel , The Dow, Inc.
B. T. Bounds , Bechtel Corp.	C. J. Melo , S&B Engineers and Constructors, Ltd.
R. D. Campbell , Bechtel	J. E. Meyer , CDM Smith — Industrial Division
D. D. Christian , Victaulic	V. B. Molina III , Air Products and Chemicals, Inc.
S. S. Cimorelli , DuPont Advanced Printing	C. A. Moore , NOV Fiberglass Systems
C. E. Davila , Crane ChemPharma & Energy	A. D. Nalbandian , Thielsch Engineering, Inc.
J. Davio , EllisDon Industrial	K. A. Nisly-Nagele , Archer Daniels Midland Co.
D. R. Edwards , Retired	K. Pham , Fluor Federal Petroleum Operation
I. El Jaouhari , Bechtel Corp.	D. W. Raho , CCM 2000
D. J. Fetzner , Retired	R. K. Reamey , Turner Industries Group, LLC
P. D. Flenner , Flenner Engineering Services	G. C. Reinhardt II , Team Industries, Inc.
D. R. Fraser , NASA Ames Research Center	T. C. Scrivner , ExxonMobil Research and Engineering Co.
D. R. Frikken , Becht Engineering Co.	K. S. Shipley , The Equity Engineering Group, Inc.
B. S. Gordon , Under Pressure Code Consulting and Training	C. Y. Shyu , Atkins
O. R. Greulich , Consultant	R. J. Silvia , Process Engineers & Constructors, Inc.
R. A. Grichuk , S&B Engineers and Constructors, Ltd.	J. P. Swezy, Jr. , Boiler Code Tech, LLC
R. W. Haupt , Pressure Piping Engineering Associates, Inc.	F. W. Tatar , FM Global
L. Henderson, Jr. , Kiewit Engineering Group, Inc.	S. J. Tonkins , BP Americas
	B. K. Walker , Consolidated Nuclear Security, LLC

W. L. Weeks, Lummus Technology
T. D. Wills, Jr., Praxair, Inc.
G. E. Woods, GCS Consulting Services, Inc.
S. Biyuan, *Delegate*, PetroChina Pipeline Co.

D. C. Glover, *Contributing Member*, KBR
R. A. McLeod, *Contributing Member*, General Electric Co.
S. Vail, *Contributing Member*, Bechtel National, Inc.

B31.3 INTERNATIONAL REVIEW GROUP

M. DeLong, *Chair*, IHI E&C International Corp.
S. Abu, Samsung C&T Corp.
A. Bhattacharya, KBR UK, Ltd.
P. Burt, Fluor
D. Dutta, Pensar Group, Inc.
S. Eikeland, Aker Solutions
A. Esmaeili, APA Group
G. Evans, BP Exploration
S. B. Feder, MC Quality Thailand
M. Ghosh, Aramco Overseas Company B.V.
R. Gopalakrishnan, Worley ECR
P. Govindaraj, Dow Benelux B.V.
Z. Gu, Technip Norge AS
M. Guidara, Engineering Procurement & Project Management, S.A.

J. M. Hamedi, Julian Hamedi Consultancy
J. W. Horn, Sasol
H. W. Lange, Liseqa SE
J. Langeland, My Piping AS
T. J. Naughton, Jacobs Engineering
C. Park, GS Engineering & Construction
G. Renna, Saipem SPA
A. Rokhsativand, Pars Oil and Gas Co.
W. Y. Sam, Shell Sarawak Berhad — Deepwater Engineering
R. Sils, Terra Nimbus Pty, Ltd.
T. Syahdilan, Pertamina Hulu Mahakam
S. V. Merwe, Sasol
H. E. Velten, Zeton B.V.
R. Versteegen, Dow Benelux B.V.

B31.3 SUBGROUP ON DESIGN

K. S. Shipley, *Chair*, The Equity Engineering Group, Inc.
T. C. Scrivner, *Vice Chair*, ExxonMobil Research and Engineering Co.
F. A. Abd Dzubir, PETRONAS
D. Arnett, ExxonMobil Research and Engineering Co.
C. Chang, Bechtel National, Inc.
D. W. Diehl, Hexagon PPM
D. R. Edwards, Retired
I. El Jaouhari, Bechtel Corp.
W. Faultersack, Pacific Northwest National Laboratory
R. W. Haupt, Pressure Piping Engineering Associates, Inc.
D. L. Ianiro, Mainthia Technologies, Inc.
J. M. Krance, Swagelok Co.
R. A. Leishear, Leishear Engineering, LLC
R. Maxwell, L-3 Combat Propulsion Systems
J. C. Mielcarek, NASA
P. D. Moore, Burns & McDonnell

K. A. Nisly-Nagele, Archer Daniels Midland Co.
P. Parker, Bayer U.S. — Crop Science
H. Rojas, Chevron
S. Stelmar, Elf Engineers
M. J. Stewart, AECOM
B. Swartz, Los Alamos National Laboratory
B. K. Walker, Consolidated Nuclear Security, LLC
G. E. Woods, GCS Consulting Services, Inc.
R. P. S. Bindra, *Contributing Member*, CB&I Lummus Private, Ltd.
J. P. Ellenberger, *Contributing Member*, Retired
M. Engelkemier, *Contributing Member*, Cargill
A. Esmaeili, *Contributing Member*, APA Group
S. LaForge, *Contributing Member*, Total France
H. W. Lange, *Contributing Member*, Liseqa SE
J. M. Mendez Franco, *Contributing Member*, Stressman Engineering
C. Park, *Contributing Member*, GS Engineering & Construction

B31.3 SUBGROUP ON EDIT

D. J. Fetzner, *Chair*, Retired
C. Becht IV, Becht Engineering Co.
R. M. Bojarczuk, ExxonMobil Research and Engineering Co.
D. R. Frikken, Becht Engineering Co.

J. E. Meyer, CDM Smith — Industrial Division
R. J. Silvia, Process Engineers & Constructors, Inc.
J. P. Swezy, Jr., Boiler Code Tech, LLC

B31.3 SUBGROUP ON FABRICATION, EXAMINATION, AND TESTING

R. D. Campbell, *Chair*, Bechtel
J. Davio, *Vice Chair*, EllisDon Industrial
C. Larsen, *Vice Chair*, Team Industrial Services
D. A. Bingham, Los Alamos National Laboratory
B. Boseo, Burns & McDonnell
K. J. Chizen, NDE Level III
M. G. Collins, ConocoPhillips
J. Cosentino, Shell Oil
T. Dang, Chevron
M. DeLong, IHI E&C International Corp.
C. H. Eskridge, Jr., Worley ECR
P. D. Flenner, Flenner Engineering Services

D. Gillespie, Bowen Engineering Corp.
R. S. Gleave, PCL Industrial Management, Inc.
B. S. Gordon, Under Pressure Code Consulting and Training
P. T. Hayes, Sinewave Solutions
S. Hilliker, Steven Hilliker Consulting, LLC
J. R. Lindlof, Kiewit Engineering Group, Inc.
V. B. Molina III, Air Products and Chemicals, Inc.
A. D. Nalbandian, Thielsch Engineering, Inc.
A. C. Ramirez, Bechtel Corp.
R. K. Reamey, Turner Industries Group, LLC
G. C. Reinhardt II, Team Industries, Inc.
L. G. Richardson, XCEL NDT, LLC

J. Shepherd, North Iron Engineering
W. J. Sperko, Sperko Engineering Services, Inc.
R. Taylor, ExxonMobil
S. W. Vail, Bechtel National, Inc.

R. G. Valdez, ARB, Inc.
R. A. McLeod, *Contributing Member*, General Electric Co.
A. Rokhsativand, *Contributing Member*, Pars Oil and Gas Co.

B31.3 SUBGROUP ON GENERAL REQUIREMENTS

C. J. Melo, *Chair*, S&B Engineers and Constructors, Ltd.
C. E. Davila, *Vice Chair*, Crane ChemPharma & Energy
D. D. Christian, Victaulic
S. B. DeLeon, Shell
G. Evans, BP Exploration
K. Landreth, T. D. Williamson
C. Linnick, Black and Veatch
C. Y. Shyu, Atkins

T. A. Thomas, DuPont
G. B. Trinker, Victaulic Co.
T. D. Wills, Jr., Praxair, Inc.
A. Ali, *Contributing Member*, Arabian Co. and Sasakura for Water & Power
S. S. Cimorelli, *Contributing Member*, DuPont Advanced Printing
J. Langeland, *Contributing Member*, My Piping AS
P. S. Shriwal, *Contributing Member*, Shriwal Enterprises

B31.3 SUBGROUP ON HIGH PRESSURE PIPING

B. T. Bounds, *Chair*, Bechtel Corp.
D. R. Fraser, NASA Ames Research Center
O. R. Greulich, Consultant
A. P. Rangus, Bechtel
F. W. Tatar, FM Global

H. Tiwari, TechnipFMC
M. C. Warren, St. Paul Pipefitters
W. L. Weeks, Lummus Technology
A. Jettley, *Contributing Member*, Bechtel India Private, Ltd.

B31.3 SUBGROUP ON HIGH PURITY SYSTEMS

W. M. Huitt, *Chair*, W. M. Huitt Co.
W. F. Daprile, *Vice Chair*, Eli Lilly and Co.
R. Foster, Hose Master, LLC
B. K. Henon, Arc Machines, Inc., Retired

R. McGregor, Titan Research Group
N. T. Ulsvik, Aker Solutions
T. J. Naughton, *Contributing Member*, Jacobs Engineering

B31.3 SUBGROUP ON MATERIALS

B. L. Agee, *Chair*, GE Energy
S. J. Tonkins, *Vice Chair*, BP Americas
D. E. Brown, SSP
R. A. Grichuk, S&B Engineers and Constructors, Ltd.
L. Henderson, Jr., Kiewit Engineering Group, Inc.
L. K. Hovey, Retired
K. Pham, Fluor Federal Petroleum Operation
D. W. Raho, CCM 2000
A. Raza, Northern Crescent, Inc.
M. Sindelar, Lokring Technology

S. Tang, Swagelok Co.
D. K. Verma, Bechtel Oil, Gas and Chemicals
A. Yasemi, Cenovus Energy, Inc.
X. Chen, *Contributing Member*, SINOPEC Engineering, Inc.
R. Goel, *Contributing Member*, McDermott
R. Gopalakrishnan, *Contributing Member*, Worley ECR
M. Guidara, *Contributing Member*, Engineering Procurement & Project Management, S.A.
W. Y. Sam, *Contributing Member*, Shell Sarawak Berhad — Deepwater Engineering

B31.3 SUBGROUP ON NON-METALLIC PIPING

M. McDaniel, *Chair*, The Dow, Inc.
C. A. Moore, *Vice Chair*, NOV Fiberglass Systems
B. Allen, Crane ResistoFlex
J. Becker, ISCO Industries, Inc.
M. Brandes, ISCO Industries, Inc.
C. Davison, Aquatherm
W. Fassler, Spears Manufacturing Co.
A. Gambino, Asahi/America, Inc.

J. M. Kalnins, Plastic-Lined Pipe Solutions
A. M. Kyu, Bechtel
R. Nadel, Charlotte Pipe and Foundry
A. Palovcak, Arkema
B. Shitole, Wood, PLC
D. Yanik, Crane ResistoFlex
C. Ziu, Nupi Americas, Inc.
R. Sils, *Contributing Member*, Terra Nimbus Pty, Ltd.

B31.3 PROCESS PIPING, INDIA INTERNATIONAL WORKING GROUP

R. Goel, *Chair*, McDermott
A. Jettley, *Vice Chair*, Bechtel India Private, Ltd.

R. Mohamed, *Secretary*, The American Society of Mechanical Engineers
V. D. Bharani, CH2M Hill

R. P. S. Bindra, CB&I Lummus Private, Ltd.
S. Biswas, Technip Noida
Y. Jangra, Fluor Daniel India Private, Ltd.
R. Jiwani, Intergraph Corp. India
N. Khera, CB&I India Private, Ltd.
A. Kumar, Larsen & Toubro, Ltd.
S. Kumar, McDermott
B. Mihir, CB&I
V. Pahuji, Bechtel

S. S. Palkar, CB&I India Private, Ltd.
V. Pranjal, Fluor Daniel India Private, Ltd.
R. S. Gururajan, Petrofac Engineering Services Private, Ltd.
P. S. Shriwal, Shriwal Enterprises
R. Singh, CB&I India Private, Ltd.
H. Toki, Bechtel India Private, Ltd.
D. D. Christian, *Contributing Member*, Victaulic
H. Tiwari, *Contributing Member*, TechnipFMC

B31 FABRICATION AND EXAMINATION COMMITTEE

R. D. Campbell, *Chair*, Bechtel
U. D'Urso, *Secretary*, The American Society of Mechanical Engineers
D. Bingham, Los Alamos National Laboratory
B. Boseo, Burns & McDonnell
M. DeLong, IHI E&C International Corp.
R. Duran, Chevron
R. J. Ferguson, Metallurgist
S. Findlan, Stone and Webster, Inc.
P. D. Flenner, Flenner Engineering Services
J. W. Frey, Joe W. Frey Engineering Services, LLC

D. R. Frikken, Becht Engineering Co.
S. Gingrich, AECOM
T. Monday, Team Industries, Inc.
A. D. Nalbandian, Thielsch Engineering, Inc.
R. Reamey, Turner Industries Group, LLC
R. J. Silvia, Process Engineers & Constructors, Inc.
W. J. Sperko, Sperko Engineering Services, Inc.
J. P. Swezy, Jr., Boiler Code Tech, LLC
K. P. Wu, Stellar Energy Systems

B31 MATERIALS TECHNICAL COMMITTEE

R. P. Deubler, *Chair*, Becht Engineering Co., Inc.
C. H. Eskridge, Jr., *Vice Chair*, Worley ECR
C. E. O'Brien, *Secretary*, The American Society of Mechanical Engineers
B. T. Bounds, Bechtel Corp.
W. P. Collins, WPC Sol, LLC
A. Esmaeili, APA Group
R. A. Grichuk, S&B Engineers and Constructors, Ltd.
J. Gundlach, Michigan Seamless Tube and Pipe
A. A. Hassan, Power Generation Engineering and Services Co.
L. Henderson, Jr., Kiewit Engineering Group, Inc.

C. Henley, Kiewit Engineering Group, Inc.
G. A. Jolly, Samshin Ltd.
C. J. Melo, S&B Engineers and Constructors, Ltd.
M. L. Nayyar, NICE
K. Pham, Fluor Federal Petroleum Operation
D. W. Rahoji, CCM 2000
R. A. Schmidt, Canadoil
S. Tonkins, BP
D. K. Verma, Bechtel Oil, Gas and Chemicals
Z. Djilali, *Contributing Member*, Sonatrach

B31 MECHANICAL DESIGN TECHNICAL COMMITTEE

J. E. Meyer, *Chair*, CDM Smith — Industrial Division
M. Engelkemier, *Vice Chair*, Cargill
R. Rahaman, *Secretary*, The American Society of Mechanical Engineers
G. A. Antaki, Becht Engineering Co., Inc.
D. Arnett, ExxonMobil Research and Engineering Co.
C. Becht IV, Becht Engineering Co.
R. Bethea, Huntington Ingalls Industries — Newport News Shipbuilding
J. P. Ellenberger, Retired
D. J. Fetzner, Retired
D. R. Fraser, NASA Ames Research Center
J. A. Graziano, Consultant
J. D. Hart, SSD, Inc.

R. W. Haupt, Pressure Piping Engineering Associates, Inc.
B. P. Holbrook, Consultant
R. A. Leishear, Leishear Engineering, LLC
G. D. Mayers, Serco, Inc.
T. Q. McCawley, TQM Engineering PC
P. Moore, Burns & McDonnell
A. W. Paulin, Paulin Resource Group
R. A. Robleto, KBR
M. J. Rosenfeld, RSI Pipeline Solutions, LLC
T. Sato, Japan Power Engineering and Inspection Corp.
M. Stewart, AECOM
H. Kosasayama, *Contributing Member*, JGC Corp.
J. C. Minichiello, *Contributing Member*, Bechtel National, Inc.

INTRODUCTION

The ASME B31 Code for Pressure Piping consists of a number of individually published Sections, each an American National Standard, under the direction of ASME Committee B31, Code for Pressure Piping.

Rules for each Section reflect the kinds of piping installations considered during its development, as follows:

- B31.1 Power Piping: piping typically found in electric power generating stations, in industrial and institutional plants, geothermal heating systems, and central and district heating and cooling systems
- B31.3 Process Piping: piping typically found in petroleum refineries; onshore and offshore petroleum and natural gas production facilities; chemical, pharmaceutical, textile, paper, ore processing, semiconductor, and cryogenic plants; food and beverage processing facilities; and related processing plants and terminals
- B31.4 Pipeline Transportation Systems for Liquids and Slurries: piping transporting products that are predominately liquid between plants and terminals and within terminals, pumping, regulating, and metering stations
- B31.5 Refrigeration Piping and Heat Transfer Components: piping for refrigerants and secondary coolants
- B31.8 Gas Transmission and Distribution Piping Systems: piping transporting products that are predominately gas between sources and terminals, including compressor, regulating, and metering stations; gas gathering pipelines
- B31.9 Building Services Piping: piping typically found in industrial, institutional, commercial, and public buildings, and in multi-unit residences, which does not require the range of sizes, pressures, and temperatures covered in B31.1
- B31.12 Hydrogen Piping and Pipelines: piping in gaseous and liquid hydrogen service and pipelines in gaseous hydrogen service

This is the B31.3 Process Piping Code Section. Hereafter, in this Introduction and in the text of this Code Section B31.3, where the word *Code* is used without specific identification, it means this Code Section.

It is the owner's responsibility to select the Code Section that most nearly applies to a proposed piping installation. Factors to be considered by the owner include limitations of the Code Section; jurisdictional requirements; and the applicability of other codes and standards. All applicable requirements of the selected Code Section shall be met. For some installations, more than one Code Section may apply to different parts of the installation. The owner is also responsible for imposing requirements supplementary to those of the Code if necessary to assure safe piping for the proposed installation.

Certain piping within a facility may be subject to other codes and standards, including but not limited to

- ANSI Z223.1 National Fuel Gas Code: piping for fuel gas from the point of delivery to the connection of each fuel utilization device

- NFPA Fire Protection Standards: fire protection systems using water, carbon dioxide, halon, foam, dry chemicals, and wet chemicals

- NFPA 99 Health Care Facilities: medical and laboratory gas systems

- building and plumbing codes, as applicable, for potable hot and cold water, and for sewer and drain systems

The Code specifies engineering requirements deemed necessary for safe design and construction of pressure piping. While safety is the primary consideration, this factor alone will not necessarily govern the final specifications for any piping installation. The Code is not a design handbook. Many decisions that must be made to produce a sound piping installation are not specified in detail within this Code. The Code does not serve as a substitute for sound engineering judgments by the owner and the designer.

To the greatest possible extent, Code requirements for design are stated in terms of basic design principles and formulas. These are supplemented as necessary with specific requirements to ensure uniform application of principles and to guide selection and application of piping elements. The Code prohibits designs and practices known to be unsafe and contains warnings where caution, but not prohibition, is warranted.

This Code Section includes the following:

(a) references to acceptable material specifications and component standards, including dimensional requirements and pressure–temperature ratings

(b) requirements for design of components and assemblies, including piping supports

(c) requirements and data for evaluation and limitation of stresses, reactions, and movements associated with pressure, temperature changes, and other forces

(d) guidance and limitations on the selection and application of materials, components, and joining methods

(e) requirements for the fabrication, assembly, and erection of piping

(f) requirements for examination, inspection, and testing of piping

Either International System (SI, also known as metric) or U.S. Customary units may be used with this edition. Local customary units may also be used to demonstrate compliance with this Code. One system of units should be used consistently for requirements applying to a specific installation. The equations in this Code may be used with any consistent system of units. It is the responsibility of the organization performing calculations to ensure that a consistent system of units is used.

ASME Committee B31 is organized and operates under procedures of The American Society of Mechanical Engineers that have been accredited by the American National Standards Institute. The Committee is a continuing one, and keeps all Code Sections current with new developments in materials, construction, and industrial practice. New editions are published at intervals of 2 years.

Code users will note that paragraphs in the Code are not necessarily numbered consecutively. Such discontinuities result from following a common outline, insofar as practical, for all Code Sections. In this way, corresponding material is correspondingly numbered in most Code Sections, thus facilitating reference by those who have occasion to use more than one Section.

This edition of Code Section B31.3 is not retroactive. Normally, agreement is made between contracting parties to use a specific edition, considering requirements

of the authority having jurisdiction. When specified as the latest edition and when no edition is specified, the specific edition is the one issued at least 6 months prior to the original contract date for the first design activity.

Users of this Code are cautioned against making use of Code revisions without assurance that they are acceptable to the proper authorities in the jurisdiction where the piping is to be installed.

The B31 Committee has established an orderly procedure to consider requests for interpretation and revision of Code requirements. To receive consideration, such request must be in writing and must give full particulars in accordance with [Appendix Z](#).

The approved reply to an inquiry will be sent directly to the inquirer. In addition, the question and reply will be published as part of an Interpretation supplement.

A Case is the prescribed form of reply when study indicates that the Code wording needs clarification, or when the reply modifies existing requirements of the Code or grants permission to use new materials or alternative constructions. The Case will be published as part of a Case supplement.

Code Cases remain available for use until annulled by the ASME B31 Standards Committee.

A request for revision of the Code will be placed on the Committee's agenda. Further information or active participation on the part of the proponent may be requested during consideration of a proposed revision.

Materials ordinarily are listed in the stress tables only when sufficient usage in piping within the scope of the Code has been shown. Requests for listing shall include evidence of satisfactory usage and specific data to permit establishment of allowable stresses, maximum and minimum temperature limits, and other restrictions. Additional criteria can be found in the guidelines for addition of new materials in the ASME Boiler and Pressure Vessel Code, Section II. (To develop usage and gain experience, unlisted materials may be used in accordance with [para. 323.1.2](#).)

ASME B31.3-2020 SUMMARY OF CHANGES

Following approval by the ASME B31 Committee and ASME, and after public review, ASME B31.3-2020 was approved by the American National Standards Institute on September 29, 2020.

ASME B31.3-2020 includes the following changes identified by a margin note, **(20)**.

<i>Page</i>	<i>Location</i>	<i>Change</i>
xx	Introduction	After subpara. (f), paragraph added
2	300.1.4	Added, and subsequent paragraph redesignated
10	Table 300.4	Appendix D deleted
12	301.3.2	Title revised
12	301.3.3	Title revised
12	301.3.4	Title revised
13	302.2.4	Revised
14	302.2.5	Last sentence deleted
16	Table 302.3.3C	General Note revised
19	302.3.6	Subparagraph (a)(1) revised
24	304.3.1	Subparagraphs (a) and (a)(2) revised
31	304.5.2	Subparagraph (b) revised
32	304.7.2	Subparagraphs (b) and (c) revised
34	306.5.2	Revised
34	307.1.2	Last sentence deleted
36	311.2.2	Subparagraph (d) revised
37	314.2.1	Subparagraph (c) revised
40	319.3.4	Subparagraph (b) revised
40	319.3.6	Revised
41	319.4.4	(1) Subparagraphs (a) and (b) revised (2) Subparagraph (c) and eqs. (19) and (20) deleted
43	320.1	Revised
44	320.2	(1) Revised (2) Footnote 9 added
49	Table 323.2.2	Items A-3(b) and B-3 revised
56	Table 323.3.1	(1) Items 4, A-5, and B-5 revised (2) Note (4) deleted
60	Table 326.1	Revised in its entirety
66	328.5.2	Revised in its entirety
66	328.5.4	Subparagraphs (d), (e)(2), and (f) revised
67	Figure 328.5.2A	Title revised
67	Figure 328.5.2B	Title revised
68	Figure 328.5.2C	(1) Title revised (2) Variable for nominal pipe wall thickness revised

<i>Page</i>	<i>Location</i>	<i>Change</i>
69	328.6	Revised
71	330.1	Last paragraph added
73	331.1.1	Subparagraph (a) revised
73	331.1.3	Subparagraph (b)(5)(-a) revised
74	Table 331.1.1	Note (7) revised
73	331.1.6	Subparagraph (c) revised
75	331.2.6	Revised
78	332.4	Last sentence added
90	344.6.2	Subparagraph (a) revised
103	A321.5.1	Subparagraph (a) revised
103	A321.5.2	Revised in its entirety
106	A328.2.1	Subparagraph (b)(6) revised
107	Table A326.1	Standards ASTM D3309, ASTM D2310, ASTM D2447, ASTM D3309, and ASTM F1974 deleted
109	A328.2.5	Nomenclature in subpara. (c)(1) revised
120	M331	Revised
124	K300	Revised in its entirety
124	K300.1	K300.1.4 added, subsequent paragraphs redesignated, and cross-references updated
125	K302.3.1	Subparagraphs (b) and (d) revised
126	K302.3.2	Subparagraphs (b), (c), and (d) revised
127	K302.3.6	Subparagraph (a) revised
128	K304.1.2	Revised
128	K304.1.3	Revised
128	K304.2.4	Revised
129	K304.7.2	Subparagraph (c) revised
130	K304.7.3	Revised
130	K304.8.1	First paragraph and footnote 6 revised
130	K304.8.2	Former subpara. (a) deleted, and subsequent subparagraphs revised and redesignated
130	K304.8.3	Subparagraph (c) revised
130	K304.8.5	First paragraph revised
131	K307	Revised in its entirety
132	K314.2	Subparagraph (b) revised
133	K317.2	Title revised
134	K322.6.3	(1) Subparagraphs (a) and (b) revised (2) Subparagraph (c) deleted
135	K323.2.2	Revised in its entirety
135	K323.3.1	Revised
135	K323.3.4	Revised in its entirety
139	Table K326.1	(1) Standards under “Bolting” and “Metallic Fittings, Valves, and Flanges” revised (2) Note (1)(c) added
140	K328	Revised
140	K328.1	Revised in its entirety

<i>Page</i>	<i>Location</i>	<i>Change</i>
140	K328.2.1	Subparagraphs (b) and (f) revised
140	K328.3.1	Revised in its entirety
141	K330.1	Revised
141	K331	Revised in its entirety
143	K332.4.1	Revised
143	K332.4.2	Subparagraph (a) revised
143	K333	Revised in its entirety
144	K341.3.3	Subparagraphs (a) and (b) revised
144	K341.4.1	(1) Subparagraph (b) revised (2) Subparagraph (c) added
148	K345.1	Subparagraphs (a), (b), and (d) revised
148	K345.2.1	Former footnote 10 deleted
149	K346.1	Revised
149	K346.2	(1) Subparagraph (b) added, and subsequent subparagraphs redesignated (2) Subparagraphs (d) and (f) revised
152	U328	Revised
152	U328.2	Revised in its entirety
152	U328.4.2	Added
154	U341.4.1	(1) First paragraph and subparas. (a) and (b) revised (2) Subparagraph (c) added
159	Specification Index for Appendix A	(1) A381, B166, B462, B649, B688, and B690 revised (2) B547 deleted
163	Notes for Tables A-1, A-1M, A-1A, A-1B, A-2, and A-2M	(1) General Note (f) and in-text table in Note (42) revised (2) Note (44) deleted
167	Table A-1	(1) Under Iron — Castings, for Gray A278 40, Note (9) reference deleted (2) Under Carbon Steel — Pipes and Tubes, for A285 Gr. A A134, A285 Gr. BA134, and A285 Gr. C A134, Type/Grade and UNS No. added (3) For A516 Gr. 60, stress values for 700°F and 800°F revised (4) For A516 Gr. 65, stress values for 850°F and 900°F revised (5) Under Carbon Steel — Pipes (Structural Grade), A283 Gr. A and B deleted (6) A1011 Gr. 30, 33, 36, and 40; A36; A283; and A1011 Gr. 45 and 50 revised (7) Under Carbon Steel — Plates, Bars, Shapes, and Sheets (Structural), A283 A and B deleted (8) A1011 30, 33, 36, 40, 45, and 50; A283 C and D; and A36 revised (9) Under Stainless Steel — Pipes and Tubes, A376 16-8-2H deleted (10) A312 TP310S revised (11) A358 310S deleted (12) For A813, A814, A249, and A312 S31254, Notes and stress values revised

<i>Page</i>	<i>Location</i>	<i>Change</i>
		(13) For A358 S31254, stress values revised
		(14) A789 S32900 deleted
		(15) Under Stainless Steel — Plates and Sheets, A240 439 deleted
		(16) A240 310H revised
		(17) A240 S31254 Notes and stress values revised
		(18) Under Stainless Steel — Forgings and Fittings, A182 F10 deleted
		(19) A182 F310, A403 WP310S, and A403 WP310H revised
		(20) For A182 and A403 S31254, Notes and stress values revised
		(21) A403 S31254, A815 S31803, A403 N08367, and A815 S32750 deleted
		(22) A815 S32101, A815 S32205, and A815 S32760 revised
		(23) A182 S41000 and A182 S41026 deleted
		(24) A182 S32750 revised
		(25) Under Stainless Steel — Bar, A479 S31254 Note and stress values revised
		(26) A479 S32205 and A479 S20910 revised
		(27) Under Stainless Steel — Castings, for A351 CH10, A351 CH20, and A351 CF8C, stress values revised
		(28) Under Nickel and Nickel Alloy — Castings, A494 CX2MW reordered and revised
		(29) A494 CW12MW and A494 CW6M revised
		(30) Under Zirconium and Zirconium Alloy — Pipes and Tubes, B523 R60702, B658 R60702, and B658 R60705 revised
		(31) B523 R60705 deleted
		(32) Under Zirconium and Zirconium Alloy — Plates and Sheets, B551 R60702 and B551 R60705 revised
		(33) Under Zirconium and Zirconium Alloy — Forgings and Bar, B493 R60702, B550 R60702, B493 R60705, and B550 R60705 revised
		(34) Aluminum Alloy — Welded Pipes and Tubes category deleted
242	Table A-1M	(1) Listings for Nominal Composition Fe revised in their entirety
		(2) A134 revised
		(3) For A524, A333, A334, A671, A672, A139, API 5L, and A381, stress values revised
		(4) A516, A515, A1011, A283, A36, and A992 revised
		(5) A376 deleted
		(6) For A312, Type/Grade, UNS No., and Notes revised
		(7) A358 deleted
		(8) For A813, A814, A249, and A312, Notes deleted
		(9) A789 and A240 deleted
		(10) For A240 and A403, Type/Grade, UNS No., and Notes revised
		(11) A182, A403, A815, and A479 revised
		(12) For A351, stress values revised
		(13) Wld. tube B626 added
		(14) A494, B523, B658, B551, B493, and B550 revised

<i>Page</i>	<i>Location</i>	<i>Change</i>
		(15) B547 deleted
349	Table A-1B	B547 deleted
354	Table A-2	(1) A194 4 and A194 4L deleted (2) A193 B8 added
364	Table A-2M	(1) A194 4 and A194 4L deleted (2) A193 B8 added
385	Specification Index for Appendix B	D2447 and D3309 deleted
386	Table B-1	D3309, D2239, D2447, D3035, and F714 deleted
388	Table B-1M	D3309, D2239, D2447, D3035, and F714 deleted
412	Appendix D	Deleted
413	Appendix E	Revised in its entirety
419	F300.1.5	Former para. F300.1.4 editorially redesignated
419	F301.10.2	Revised
420	F302	Added
421	F323	Subparagraph (b) revised
423	F331.1	Revised
424	FA328	Added
428	H301	Revised
428	H302	Revised
429	H303	Revised
431	H304	Revised
437	Appendix J	Cross-references updated
453	Appendix K	(1) ASTM A928 added to Specification Index (2) Page column deleted in Specification Index
455	Notes for Table K-1	(1) General Notes (b) and (d) and Notes (3), (4), and (20) revised (2) General Note (h) added (3) Notes (6) and (12) deleted
456	Table K-1	Revised in its entirety
474	Figure M300	In Col. 1, cross-references to para. K300.1.5 revised to K300.1.6
477	R301	(1) Subparagraph (b) revised (2) Subparagraph (c) deleted
480	Appendix S	Revised in its entirety
495	V304	Revised in its entirety
500	Table W302.1-4	Editorially redesignated
507	Index	Added

Chapter I

Scope and Definitions

300 GENERAL STATEMENTS

(a) *Identification.* This Process Piping Code is a Section of The American Society of Mechanical Engineers Code for Pressure Piping, ASME B31, an American National Standard. It is published as a separate document for convenience of Code users.

(b) *Responsibilities*

(1) *Owner.* The owner of a piping installation shall have overall responsibility for compliance with this Code, and for establishing the requirements for design, construction, examination, inspection, and testing that will govern the entire fluid handling or process installation of which the piping is a part. The owner is also responsible for designating piping in Category D, Category M, High Pressure, and High Purity Fluid Services, and for determining if a specific Quality System is to be employed. [See (d)(4) through (d)(7) and Appendix Q.] Where applicable, the owner shall consider requirements imposed by the authority having jurisdiction regarding the piping installation. The owner may designate a representative to carry out selected responsibilities required by this Code, but the owner retains ultimate responsibility for the actions of the representative.

(2) *Designer.* The designer is responsible to the owner for assurance that the engineering design of piping complies with the requirements of this Code and with any additional requirements established by the owner.

(3) *Manufacturer, Fabricator, and Erector.* The manufacturer, fabricator, and erector of piping are responsible for providing materials, components, and workmanship in compliance with the requirements of this Code and of the engineering design.

(4) *Owner's Inspector.* The owner's Inspector (see para. 340) is responsible to the owner for ensuring that the requirements of this Code for inspection, examination, and testing are met. If a Quality System is specified by the owner to be employed, the owner's Inspector is responsible for verifying that it is implemented.

(c) *Intent of the Code*

(1) It is the intent of this Code to set forth engineering requirements deemed necessary for safe design and construction of piping installations.

(2) This Code is not intended to apply to the operation, examination, inspection, testing, maintenance, or repair of piping that has been placed in service. See

para. F300.1 for examples of standards that may apply in these situations. The provisions of this Code may optionally be applied for those purposes, although other considerations may also be necessary.

(3) The Code generally specifies a simplified approach for many of its requirements. A designer may choose to use a more rigorous analysis to develop design and construction requirements. When the designer decides to take this approach, the designer shall provide to the owner details and calculations demonstrating that design, construction, examination, and testing are consistent with the design criteria of this Code. These details shall be adequate for the owner to verify the validity and shall be approved by the owner. The details shall be documented in the engineering design.

(4) Piping elements shall conform to the specifications and standards listed in this Code or, if not prohibited by this Code, shall be qualified for use as set forth in applicable Chapters of this Code.

(5) The engineering design shall specify any unusual requirements for a particular service. Where service requirements necessitate measures beyond those required by this Code, such measures shall be specified by the engineering design. Where so specified, the Code requires that they be accomplished.

(6) Compatibility of materials with the service and hazards from instability of contained fluids are not within the scope of this Code. See para. F323.

(d) *Determining Code Requirements*

(1) Code requirements for design and construction include fluid service requirements, which affect selection and application of materials, components, and joints. Fluid service requirements include prohibitions, limitations, and conditions, such as temperature limits or a requirement for safeguarding (see Appendix G). Code requirements for a piping system are the most restrictive of those that apply to any of its elements.

(2) For metallic piping not designated by the owner as Category M, High Pressure, or High Purity Fluid Service (see para. 300.2 and Appendix M), Code requirements are found in Chapters I through VI (the base Code) and fluid service requirements are found in

(-a) Chapter III for materials

(-b) Chapter II, Part 3, for components

(-c) Chapter II, Part 4, for joints