

ASME B31.8-2020
(Revision of ASME B31.8-2018)

Gas Transmission and Distribution Piping Systems

ASME Code for Pressure Piping, B31

AN INTERNATIONAL PIPING CODE®



**The American Society of
Mechanical Engineers**

ASME B31.8-2020
(Revision of ASME B31.8-2018)

Gas Transmission and Distribution Piping Systems

ASME Code for Pressure Piping, B31

AN INTERNATIONAL PIPING CODE®



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: May 31, 2021

The next edition of this Code is scheduled for publication in 2022. This Code will become effective 6 months after the Date of Issuance.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations are published on the Committee web page and under <http://go.asme.org/Interpretations>. Periodically certain actions of the ASME B31 Committee may be published as Cases. Cases are published on the ASME website under the B31 Committee Page at <http://go.asme.org/B31committee> as they are issued.

Errata to codes and standards may be posted on the ASME website under the Committee Pages of the associated codes and standards to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The B31 Committee Page can be found at <http://go.asme.org/B31committee>. The associated B31 Committee Pages for each code and standard can be accessed from this main page. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" an item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2021 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword		i
Committee Roster		xi
Correspondence With the B31 Committee		xiv
Introduction		xvi
Summary of Changes		xviii
	General Provisions and Definitions	1
801	General	1
802	Scope and Intent	1
803	Piping Systems Definitions	2
804	Piping Systems Component Definitions	5
805	Design, Fabrication, Operation, and Testing Terms and Definitions	7
806	Quality Assurance	13
807	Training and Qualification of Personnel	13
Chapter I	Materials and Equipment	15
810	Materials and Equipment	15
811	Qualification of Materials and Equipment	15
812	Materials for Use in Low-Temperature Applications	16
813	Marking	16
814	Material Specifications	16
815	Equipment Specifications	17
816	Transportation of Line Pipe	17
817	Conditions for the Reuse of Pipe	17
Chapter II	Welding	20
820	Welding	20
821	General	20
822	Preparation for Welding	20
823	Qualification of Procedures and Welders	21
824	Preheating	21
825	Stress Relieving	21
826	Weld Inspection Requirements	22
827	Repair or Removal of Defective Welds in Piping Intended to Operate at Hoop Stress Levels of 20% or More of the Specified Minimum Yield Strength	23
Chapter III	Piping System Components and Fabrication Details	24
830	General	24
831	Piping System Components	24
832	Expansion and Flexibility	31
833	Design for Longitudinal Stress	32
834	Supports and Anchorage for Exposed Piping	35

835	Anchorage for Buried Piping	36
836	Liquid Removal Equipment	36
Chapter IV	Design, Installation, and Testing	37
840	Design, Installation, and Testing	37
841	Steel Pipe	39
842	Other Materials	53
843	Compressor Stations	61
844	Pipe-Type and Bottle-Type Holders	64
845	Control and Limiting of Gas Pressure	65
846	Valves	71
847	Vaults	72
848	Customers' Meters and Regulators	73
849	Gas Service Lines	74
Chapter V	Operating and Maintenance Procedures	78
850	Operating and Maintenance Procedures Affecting the Safety of Gas Transmission and Distribution Facilities	78
851	Pipeline Maintenance	81
852	Distribution Piping Maintenance	87
853	Miscellaneous Facilities Maintenance	90
854	Location Class and Changes in Number of Buildings Intended for Human Occupancy	93
855	Pipeline Service Conversions	95
856	Odorization	96
857	Upgrading	96
Chapter VI	Corrosion Control	99
860	General	99
861	External Corrosion Control for Steel Pipelines	100
862	Cathodic Protection Criteria	102
863	Operation and Maintenance of Cathodic Protection Systems	102
864	Internal Corrosion Control	102
865	Steel Pipelines in Arctic Environments	104
866	Steel Pipelines in High-Temperature Service	104
867	Stress Corrosion and Other Phenomena	105
868	Cast Iron, Wrought Iron, Ductile Iron, and Other Metallic Pipelines	105
Chapter VII	Intentionally Left Blank	106
Chapter VIII	Offshore Gas Transmission	107
A800	Offshore Gas Transmission	107
A801	General	107
A802	Scope and Intent	107
A803	Offshore Gas Transmission Terms and Definitions	107
A811	Qualification of Materials and Equipment	109
A814	Material Specifications	109
A817	Conditions for the Reuse and Requalification of Pipe	109
A820	Welding Offshore Pipelines	109
A821	General	109
A823	Qualification of Procedures and Welders	110

A825	Stress Relieving	110
A826	Inspection of Welds	110
A830	Piping System Components and Fabrication Details	110
A831	Piping System Components	110
A832	Expansion and Flexibility	110
A834	Supports and Anchorage for Exposed Piping	111
A835	Anchorage for Buried Piping	111
A840	Design, Installation, and Testing	111
A841	Design Considerations	111
A842	Strength Considerations	112
A843	Compressor Stations	116
A844	On-Bottom Stability	117
A846	Valves	118
A847	Testing	118
A850	Operating and Maintenance Procedures Affecting the Safety of Gas Transmission Facilities	119
A851	Pipeline Maintenance	119
A854	Location Class	120
A860	Corrosion Control of Offshore Pipelines	120
A861	External Corrosion Control	120
A862	Cathodic Protection Criteria	122
A864	Internal Corrosion Control	122
Chapter IX	Sour Gas Service	123
B800	Sour Gas Service	123
B801	General	123
B802	Scope and Intent	123
B803	Sour Gas Terms and Definition	123
B813	Marking	124
B814	Material Specifications	124
B820	Welding Sour Gas Pipelines	124
B821	General	124
B822	Preparation for Welding	124
B823	Qualification of Procedures and Welders	124
B824	Preheating	125
B825	Stress Relieving	125
B826	Welding and Inspection Tests	125
B830	Piping System Components and Fabrication Details	125
B831	Piping System Components	125
B840	Design, Installation, and Testing	125
B841	Steel Pipe	125
B842	Other Materials	126
B843	Compressor Stations	126
B844	Pipe-Type and Bottle-Type Holders	126
B850	Additional Operating and Maintenance Considerations Affecting the Safety of Sour Gas Pipelines	127
B851	Pipeline Maintenance	127

B854	Location Class and Changes in Number of Buildings Intended for Human Occupancy . . .	127
B860	Corrosion Control of Sour Gas Pipelines	129
B861	External Corrosion Control for Steel Pipelines	129
B864	Internal Corrosion Control	129
B867	Stress Corrosion and Other Phenomena	129

Mandatory Appendices

A	References	131
B	Numbers and Subjects of Standards and Specifications That Appear in Mandatory Appendix A	136
D	Specified Minimum Yield Strength for Steel Pipe Commonly Used in Piping Systems	140
E	Flexibility and Stress Intensification Factors	143
F	Extruded Headers and Welded Branch Connections	149
G	Testing of Welders Limited to Work on Lines Operating at Hoop Stresses of Less Than 20% of the Specified Minimum Yield Strength	156
H	Flattening Test for Pipe	157
I	End Preparations for Buttwelding	158
K	Criteria for Cathodic Protection	173
Q	Scope Diagrams	185

Nonmandatory Appendices

C	Publications That Do Not Appear in the Code or Mandatory Appendix A	137
J	Commonly Used Conversion Factors	168
L	Determination of Remaining Strength of Corroded Pipe	174
M	Gas Leakage Control Criteria	175
N	Recommended Practice for Hydrostatic Testing of Pipelines in Place	181
O	Preparation of Technical Inquiries	183
P	Nomenclature for Figures	184
R	Estimating Strain in Dents	189

Figures

851.4.1-1	Allowable Ripple Fillets	84
F-1	Limits of Reinforcement Zone	150
F-2	Method of Establishing T_o When the Taper Encroaches on the Crotch Radius	150
F-3	Example Showing Constant Inside Diameter of Outlet	151
F-4	Example Showing Tapered Inside Diameter of Outlet	151
F-5	Rules for Reinforcement of Welded Branch Connections	152
F-6	Figure for Examples 1 and 1M	153
F-7	Figure for Examples 2 and 2M	154
I-1	Welding Details for Openings Without Reinforcement Other Than That in Header and Branch Walls	159
I-2	Welding Details for Openings With Localized-Type Reinforcement	160
I-3	Welding Details for Openings With Complete Encirclement Types of Reinforcement	161
I-3.1	Pressurized Hot Tap Tee Reinforcing Sleeve End Fillet Weld Design	162
I-4	Acceptable Combinations of Pipe End Preparations	163
I-5	Acceptable Design for Unequal Wall Thickness	164
I-6	Recommended Attachment Details of Flanges	165

Q-1	Scope of ASME B31.8 Transmission Piping Offshore	186
Q-2	Scope of ASME B31.8 Transmission Piping Onshore	187
Q-3	Scope of ASME B31.8 Distribution Piping	188
R-1	Method for Estimating Strain in Dents	190

Tables

817.1.3-1	Tensile Testing	1
831.4.2-1	Reinforcement of Welded Branch Connections, Special Requirements	30
832.2-1	Thermal Expansion or Contraction of Piping Materials — Carbon and Low Alloy High Tensile Steel and Wrought Iron	31
832.5-1	Modulus of Elasticity for Carbon and Low Alloy Steel	32
841.1.6-1	Basic Design Factor, F	41
841.1.6-2	Design Factors for Steel Pipe Construction	42
841.1.7-1	Longitudinal Weld Joint Quality Factor, E	43
841.1.8-1	Temperature Derating Factor, T , for Steel Pipe	43
841.1.11-1	Pipeline Cover Requirements	46
841.2.3-1	Pipeline Field Cold Bend Requirements	47
841.3.2-1	Test Requirements for Steel Pipelines and Mains to Operate at Hoop Stresses of 30% or More of the Specified Minimum Yield Strength of the Pipe	52
841.3.3-1	Maximum Hoop Stress Permissible During an Air or Water Test	52
842.1.1-1	Standard Thickness Selection Table for Ductile Iron Pipe	55
842.2.9-1	Nominal Values for Coefficients of Thermal Expansion of Thermoplastic Pipe Materials	58
844.3-1	Design Factors, F	64
844.3-2	Minimum Clearance Between Containers and Fenced Boundaries	65
845.2.2-1	Maximum Allowable Operating Pressure for Steel or Plastic Pipelines or Mains	66
845.2.3-1	Maximum Allowable Operating Pressure for Pipelines Operating at 100 psig (690 kPa) or More	67
845.2.3-2	Maximum Allowable Operating Pressure for Pipelines Operating at Less Than 100 psig (690 kPa)	67
851.4.4-1	Wall Thickness for Unlikely Occurrence of Burn-Through	85
854.1-1	Location Class	94
857.4-1	Wall Thickness Allowance for Upgrading a Ductile Iron High-Pressure Main or System	98
A842.2.2-1	Design Factors for Offshore Pipelines, Platform Piping, and Pipeline Risers	113
B850.1-1	100 ppm ROE	128
B850.1-2	500 ppm ROE	128
B850.1-3	Metric Example for 100 ppm ROE	128
B850.1-4	Metric Example for 500 ppm ROE	128
D-1	Specified Minimum Yield Strength for Steel Pipe Commonly Used in Piping Systems	141
D-2	HDB Values for Thermoplastic Materials	142
E-1	Flexibility Factor, k , and Stress Intensification Factor, i	144
I-1	Lightweight Flanges	166
I-1a	Lightweight Flanges (Metric Dimensions)	167
J-1	Commonly Used Conversion Factors	169
J-2	List of SI Units for Use With B31.8 Code	171
M-4-1	Leak Detection Instruments: Type and General Usage	177
M-5.3-1	Leak Classification and Action Criteria: Grade 1	179

M-5.3-2	Leak Classification and Action Criteria: Grade 2	180
M-5.3-3	Leak Classification and Action Criteria: Grade 3	180
Index	191

Currently in preview, click buy full versi

FOREWORD

The need for a national code for pressure piping became increasingly evident from 1915 to 1925. To meet this need, the American Engineering Standards Committee [later changed to the American Standards Association, now the American National Standards Institute (ANSI)] initiated Project B31 in March 1926 at the request of the American Society of Mechanical Engineers (ASME) and with that Society as sole sponsor. After several years of work by Sectional Committee B31 and its subcommittees, a first Edition was published in 1935 as an American Tentative Standard Code for Pressure Piping.

A revision of the original tentative standard began in 1937. Several more years of effort were given to securing uniformity among sections, eliminating divergent requirements and discrepancies, keeping the Code abreast of current developments in welding technique, calculating stress computations, and including reference to new dimensional and material standards. During this period, a new section on refrigeration piping was prepared in cooperation with the American Society of Refrigeration Engineers and complemented the American Standard Code for Mechanical Refrigeration. This work culminated in the 1942 American Standard Code for Pressure Piping.

Supplements 1 and 2 of the 1942 Code, which appeared in 1944 and 1947, respectively, introduced new dimensional and material standards, a new formula for pipe wall thickness, and more comprehensive requirements for instrument and control piping. Shortly after the 1942 Code was issued, procedures were established for handling inquiries requiring explanation or interpretation of Code requirements and for publishing such inquiries and answers in *Mechanical Engineering* for the information of all concerned.

By 1948, continuing increases in the severity of service conditions combined with the development of new materials and designs to meet these higher requirements warranted more extensive changes in the Code than could be provided from supplements alone. The decision was reached by the American Standards Association and the sponsor to reorganize the sectional committee and its several subcommittees and to invite the various interested bodies to reaffirm their representatives or to designate new ones.

Because of the wide field involved, between 30 and 40 different engineering societies, government bureaus, trade associations, institutes, and similar organizations had one or more representatives on the sectional committee, plus a few "members-at-large" to represent general interests. Code activities were subdivided according to the scope of the several sections. General direction of Code activities rested with the Standards Committee officers and an executive committee, membership of which consisted principally of Standards Committee officers and section chairmen.

Following its reorganization in 1948, Standards Committee B31 made an intensive review of the 1942 Code that resulted in

- (a) a general revision and extension of requirements to agree with present-day practice
- (b) the revision of references to existing dimensional standards and material specifications and the addition of references to the new ones
- (c) the clarification of ambiguous or conflicting requirements

A revision was presented to a letter ballot vote of Standards Committee B31. Following approval by this body, the project was approved by the sponsor organization and by the American Standards Association. It was finally designated as an American Standard with the designation B31.1-1951, in February 1951.

At its annual meeting on November 29, 1951, Standards Committee B31 authorized the separate publication of a section of the Code for Pressure Piping addressing gas transmission and distribution piping systems, to be completed with the applicable parts of Section 2, Gas and Air Piping Systems; Section 6, Fabrication Details; and Section 7, Materials — Their Specifications and Identification. The purpose was to provide an integrated document for gas transmission and distribution piping that would not require cross-referencing to other sections of the Code.

The first Edition of this integrated document, known as American Standard Code for Pressure Piping, Section 8, Gas Transmission and Distribution Piping Systems, was published in 1952 and consisted almost entirely of material taken from Sections 2, 6, and 7 of the 1951 Edition of the Pressure Piping Code.

A new section committee was organized in 1952 to update Section 8 as necessary to address modern materials and methods of construction and operation.

After a review by B31 Executive and Standards Committees in 1955, a decision was made to develop and publish industry sections as separate Code documents of the American Standard B31 Code for Pressure Piping. The 1955 Edition constituted a general revision of the 1952 Edition with a considerably expanded scope. Further experience in the application of the Code resulted in revisions in 1958, 1963, 1966, 1967, 1968, 1969, 1975, and 1982.

In December 1978, the American National Standards Committee B31 was reorganized as the ASME Code for Pressure Piping, B31 Committee. The code designation was also changed to ANSI/ASME B31.

The 1989 Edition of the Code was a compilation of the 1986 Edition and the subsequent addenda issued to the 1986 Edition.

The 1992 Edition of the Code was a compilation of the 1989 Edition, the subsequent three addenda, and the two special Errata issued to the 1989 Edition.

The 1995 Edition of the Code was a compilation of the 1992 Edition and the subsequent three addenda issued to the 1992 Edition.

The 1999 Edition of the Code was a compilation of the 1995 Edition and the revisions that occurred following the issuance of the 1995 Edition.

The 2003 Edition of the Code was a compilation of the 1999 Edition and revisions that occurred following the issuance of the 1999 Edition.

The 2007 Edition of the Code was a compilation of the 2003 Edition and revisions that occurred following the issuance of the 2003 Edition.

The 2010 Edition of the Code was a compilation of the 2007 Edition and revisions that occurred following the issuance of the 2007 Edition.

The 2012 Edition of the Code was a compilation of the 2010 Edition and revisions that occurred following the issuance of the 2010 Edition.

The 2014 Edition of the Code was a compilation of the 2012 Edition and revisions that occurred following the issuance of the 2012 Edition.

The 2016 Edition of the Code was a compilation of the 2014 Edition and revisions that occurred following the issuance of the 2014 Edition.

The 2018 Edition of the Code is a compilation of the 2016 Edition and revisions that have occurred since the issuance of the 2016 Edition.

The 2020 Edition of the Code is a compilation of the 2018 Edition and revisions that have occurred since the issuance of the 2018 Edition. ASME B31.8-2020 was approved by ANSI on September 18, 2020.

ASME B31 COMMITTEE

Code for Pressure Piping

(The following is the roster of the Committee at the time of approval of this Code.)

STANDARDS COMMITTEE OFFICERS

C. H. Eskridge, Jr., *Chair*
K. A. Vilminot, *Vice Chair*
J. Oh, *Secretary*

STANDARDS COMMITTEE PERSONNEL

D. D. Anderson , TransCanada	G. A. Jolly , Samshin, Ltd.
R. J. Appleby , Consultant	K. B. Kaplan , Consultant
K. C. Bodenhamer , TRC Pipeline Services	C. Kolovich , Quest Integrity
R. Bojarczuk , Retired	W. J. Mauro , Consultant
M. R. Braz , MRBraz and Associates, PLLC	J. E. Meyer , CDM Smith — Industrial Division
M. Burkhart , The Burkhart Group, Inc.	T. Monday , Team Industries, Inc.
R. D. Campbell , Bechtel	J. Oh , The American Society of Mechanical Engineers
J. S. Chin , TC Energy	D. W. Rahoi , Consultant
D. D. Christian , Victaulic	R. Reamey , Turner Industries Group, LLC
R. P. Deubler , Becht Engineering Co., Inc.	M. J. Rosenfeld , RSI Pipeline Solutions, LLC
D. Diehl , Retired	J. T. Schmitz , Southwest Gas Corp.
M. Engelkemier , Cargill	S. K. Sinha , Lucius Pitkin, Inc.
C. H. Eskridge, Jr. , Worley ECR	W. J. Sperko , Sperko Engineering Services, Inc.
D. J. Fetzner , BP Exploration (Alaska), Inc.	F. W. Tatar , FM Global
D. R. Frikken , Becht Engineering Co., Inc.	K. A. Vilminot , Commonwealth Associates, Inc.
R. A. Grichuk , S&B Engineers and Contractors, Ltd.	P. Flenner , <i>Contributing Member</i> , Flenner Engineering Services
R. W. Haupt , Pressure Piping Engineering Associates, Inc.	M. Nayyar , <i>Contributing Member</i> , NICE

B31.8 EXECUTIVE COMMITTEE

D. D. Anderson , <i>Chair</i> , TransCanada	K. G. Leewis , Leewis and Associates, Inc.
P. D. Stumpf , <i>Secretary</i> , The American Society of Mechanical Engineers	M. T. Reed , TC Energy
R. J. Appleby , Consultant	V. Romero , Southern California Gas Co.
K. B. Kaplan , Consultant	M. J. Rosenfeld , RSI Pipeline Solutions, LLC

B31.8 GAS TRANSMISSION AND DISTRIBUTION PIPING SYSTEMS SECTION COMMITTEE

D. D. Anderson , <i>Chair</i> , TransCanada	D. K. Moore , Trout Hydrodynamics, Inc.
M. J. Rosenfeld , <i>Vice Chair</i> , RSI Pipeline Solutions, LLC	E. K. Newton , Southern California Gas Co.
P. D. Stumpf , <i>Secretary</i> , The American Society of Mechanical Engineers	G. E. Ortega , Venture Global LNG
R. J. Appleby , Consultant	M. T. Reed , TC Energy
B. W. Bingham , T. D. Williamson, Inc.	E. J. Robichaux II , Atmos Energy Corp.
P. M. Dickenson , Elk Petroleum	R. A. Schmidt , Canadoil
S. A. Frehse , Southwest Gas Corp.	L. C. Thronson , Tecorp International, PLLC
R. W. Gailing , Consultant	H. Tiwari , TechnipFMC
M. W. Gragg , ExxonMobil Development Co.	F. R. Volgstadt , Volgstadt and Associates, Inc.
D. W. Haim , EnSiteUSA	W. J. Walsh , EN Engineering
M. E. Hovis , Energy Transfer	D. W. Wright , Wright Tech Services, LLC
K. B. Kaplan , Consultant	C. A. Bullock , <i>Contributing Member</i> , Integrity Solutions, Ltd.
M. Kieba , U.S. DOT — PHMSA	J. S. Chin , <i>Contributing Member</i> , TC Energy
R. W. Kivela , Consultant	A. M. Clarke , <i>Contributing Member</i> , Consultant
K. G. Leewis , Leewis and Associates, Inc.	D. J. Fetzner , <i>Contributing Member</i> , BP Exploration (Alaska), Inc.
	R. D. Huriaux , <i>Contributing Member</i> , Richard D. Huriaux, PE LLC

M.D. Huston, *Contributing Member*, Oneok Partners, LP
M. P. Lamontagne, *Contributing Member*, Lamontagne Pipeline Assessment Corp.

M. J. Mechlowicz, *Contributing Member*, Southern California Gas Co.
J. K. Wilson, *Contributing Member*, G2 Integrated Solutions
J. Zhou, *Contributing Member*, TransCanada Pipelines, Ltd.

B31.8 SUBGROUP ON DESIGN, MATERIALS, AND CONSTRUCTION

M. J. Rosenfeld, *Chair*, RSI Pipeline Solutions, LLC
K. B. Kaplan, *Vice Chair*, Consultant
W. J. Walsh, *Secretary*, EN Engineering
A. Akmal, Southern California Gas Co.
B. Albers, Fluor
R. J. Appleby, Consultant
B. W. Bingham, T. D. Williamson, Inc.
D. Chairez, Consultant
J. S. Chin, TC Energy
A. M. Clarke, Consultant
D. C. D'Eletto, National Grid
P. M. Dickinson, Elk Petroleum
A. Esmaeili, APA Group
D. J. Fetzner, BP Exploration (Alaska), Inc.
S. A. Frehse, Southwest Gas Corp.
R. W. Gailing, Consultant
D. W. Haim, EnSiteUSA

M. Kieba, U.S. DOT — PHMSA
J. Mauritz, WeldFit
E. K. Newton, Southern California Gas Co.
G. E. Ortega, Venture Global LNG
E. J. Robichaux II, Atmos Energy Corp.
R. A. Schmidt, Canadoil
L. C. Thronson, Tecorp International, PLLC
H. Tiwari, TechnipFMC
F. R. Volgstadt, Volgstadt and Associates, Inc.
J. Zhou, TransCanada Pipelines, Ltd.
H. M. Al-Muslim *Contributing Member*, Saudi Aramco
M. A. Boring, *Contributing Member*, DNV GL
J. W. Fee, *Contributing Member*, Consultant
R. D. Huriaux, *Contributing Member*, Richard D. Huriaux, LLC
M. D. Huston, *Contributing Member*, Oneok Partners, LP
M. J. Mechlowicz, *Contributing Member*, Southern California Gas Co.

B31.8 SUBGROUP ON DISTRIBUTION

V. Romero, *Chair*, Southern California Gas Co.
B. Tansey, *Secretary*, American Gas Association
D. Chairez, Consultant
J. Elder, Atmos Energy Corp.
S. A. Frehse, Southwest Gas Corp.

M. Kieba, U.S. DOT — PHMSA
E. K. Newton, Southern California Gas Co.
E. J. Robichaux II, Atmos Energy Corp.
F. R. Volgstadt, Volgstadt and Associates, Inc.
M. J. Mechlowicz, *Contributing Member*, Southern California Gas Co.

B31.8 SUBGROUP ON EDITORIAL REVIEW

K. G. Lewis, *Chair*, Lewis and Associates, Inc.
K. B. Kaplan, *Vice Chair*, Consultant
C. Maier, *Secretary*, TC Energy

R. W. Gailing, Consultant
D. W. Haim, EnSiteUSA

B31.8 SUBGROUP ON OFFSHORE PIPELINES

K. B. Kaplan, *Chair*, Consultant
R. J. Appleby, Consultant
R. Dotson, ROSEN USA, Inc.

K. K. Emeaba, National Transportation Safety Board
M. W. Gragg, ExxonMobil Production Co.
H. Tiwari, TechnipFMC

B31.8 SUBGROUP ON OPERATION AND MAINTENANCE

M. T. Reed, *Chair*, TC Energy
M. E. Hovis, *Vice Chair*, Energy Transfer
R. W. Kivela, *Secretary*, Consultant
D. D. Anderson, TransCanada
R. Dotson, ROSEN USA, Inc.
K. K. Emeaba, National Transportation Safety Board
E. Kostelka, Enable Midstream Partners
M. P. Lamontagne, Lamontagne Pipeline Assessment Corp.
K. G. Lewis, Lewis and Associates, Inc.

C. Maier, TC Energy
D. K. Moore, Trout Hydrodynamics, Inc.
V. Romero, Southern California Gas Co.
D. Spillers, U.S. DOT
D. W. Wright, Wright Tech Services, LLC
A. Bhatia, *Contributing Member*, Det Norske Veritas (Canada), Ltd.
C. A. Bullock, *Contributing Member*, Integrity Solutions, Ltd.
D. R. Thornton, *Contributing Member*, The Equity Engineering Group
J. K. Wilson, *Contributing Member*, G2 Integrated Solutions

B31.8 GAS TRANSMISSION AND DISTRIBUTION PIPING SYSTEMS INDIA INTERNATIONAL WORKING GROUP

J. Sivaraman, *Chair*, Reliance Gas Transportation Infrastructure, Ltd.
A. Karnatak, *Vice Chair*, Gail India, Ltd.
R. Uprety, *Vice Chair*, Oil Industry Safety Directorate
J. George, GSPL India Transco, Ltd. (GITL)
T. S. Kathayat, Welspun Corp., Ltd.
H. Khan, VCS Quality Services Pvt., Ltd.
R. Kishore, Engineers India, Ltd.
S. P. Mandal, Certification Engineers International, Ltd.

G. J. Murthy, Mahanagar Gas, Ltd.
B. B. Nallapaneni, Gujarat State Petronet, Ltd.
V. C. Patel, Athena Powertech, LLP
R. Anbu Selvan, Gail India, Ltd.
K. P. Radhakrishnan, Gujarat State Petronet, Ltd.
V. T. Randeria, Gujarat Gas Co., Ltd.
H. M. Solanki, T D. Williamson India Pvt., Ltd.
M. Sharma, *Contributing Member*, ASME India PVT., Ltd.

B31.8 INTERNATIONAL REVIEW GROUP

H. M. Al-Muslim, *Chair*, Saudi Aramco
A. Esmaili, APA Group
Q. Feng, PetroChina Pipeline Co.

W. Feng, PetroChina Pipeline Co.
W. Wu, China Petroleum Pipeline Engineering Corp.
Z. Yu, China Petroleum Pipeline Engineering Corp.

B31 FABRICATION AND EXAMINATION COMMITTEE

R. D. Campbell, *Chair*, Bechtel
U. D'Urso, *Secretary*, The American Society of Mechanical Engineers
D. Bingham, Los Alamos National Labs
B. Boseo, Burns and McDonnell
M. DeLong, IHI E and C International Corp.
R. Duran, Chevron
S. Findlan, Stone and Webster, Inc.
J. W. Frey, Joe W. Frey Engineering Services, LLC
D. R. Frikken, Becht Engineering Co., Inc.

S. Gingrich, AECOM
T. Monday, Team Industries, Inc.
A. D. Nalbandian, Thielsch Engineering, Inc.
R. Reamey, Turner Industries Group, LLC
W. J. Sperko, Sperko Engineering Services, Inc.
J. Swezy, Jr., Boiler Code Tech, LLC
K. Wu, Stellar Energy Systems
P. Flenner, *Contributing Member*, Flenner Engineering Services

B31 MATERIALS TECHNICAL COMMITTEE

R. P. Deubler, *Chair*, Becht Engineering Co., Inc.
C. Henley, *Vice Chair*, Kiewit Engineering Group, Inc.
C. E. O'Brien, *Secretary*, The American Society of Mechanical Engineers
B. T. Bounds, Bechtel Corp.
W. P. Collins, WPC Solutions, LLC
C. H. Eskridge, Jr., Worley ECR
A. Esmaili, APA Group
R. A. Grichuk, S&B Engineers and Constructors, Ltd.
J. Gundlach, Michigan Seamless Tube and Pipe
A. A. Hassan, PGESCO

L. Henderson, Jr., Kiewit Engineering Group, Inc.
G. A. Jolly, Samshin, Ltd.
C. J. Melo, S&B Engineers and Constructors, Ltd.
K. Pham, Fluor Federal Petroleum Operation
D. W. Rahoji, Consultant
R. A. Schmidt, Canadoil
S. Tonkins, BP Americas
D. K. Verma, Bechtel Corp. — Oil Gas and Chemicals
Z. Djilali, *Contributing Member*, Sonatrach
M. Nayyar, *Contributing Member*, NICE

B31 MECHANICAL DESIGN TECHNICAL COMMITTEE

M. Engelkemier, *Chair*, Cargill
D. Arnett, *Vice Chair*, Exxonmobil Research and Engineering
R. Rahman, *Secretary*, The American Society of Mechanical Engineers
G. A. Antaki, Becht Engineering Co., Inc.
R. Betha, Huntington Ingalls Industries, Newport News Shipbuilding
D. J. Fetzner, BP Exploration (Alaska), Inc.
D. A. Fraser, NASA Ames Research Center
J. A. Graziano, Consultant
J. D. Hart, SSD, Inc.
R. W. Haupt, Pressure Piping Engineering Associates, Inc.
B. P. Holbrook, Babcock Power, Inc.

R. A. Leishear, Leishear Engineering, LLC
G. D. Mayers, Serco, Inc.
T. Q. McCawley, TQM Engineering PC
J. E. Meyer, CDM Smith — Industrial Division
P. Moore, Burns and McDonnell
A. Paulin, Paulin Research Group
M. J. Rosenfeld, RSI Pipeline Solutions, LLC
M. J. Stewart, Amentum
H. Kosasayama, *Contributing Member*, JGC Corp.
J. Minichiello, *Contributing Member*, Bechtel Corp. — Nuclear, Security and Environmental

CORRESPONDENCE WITH THE B31 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Code may interact with the Committee by requesting interpretations, proposing revisions or a case, and attending Committee meetings. Correspondence should be addressed to:

Secretary, B31 Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Code to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Code. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Code. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued to provide alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Code and the paragraph, figure, or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Code to which the proposed Case applies.

Interpretations. Upon request, the B31 Standards Committee will render an interpretation of any requirement of the Code. Interpretations can only be rendered in response to a written request sent to the Secretary of the B31 Standards Committee.

Requests for interpretation should preferably be submitted through the online Interpretation Submittal Form. The form is accessible at <http://go.asme.org/InterpretationRequest>. Upon submittal of the form, the Inquirer will receive an automatic e-mail confirming receipt.

If the Inquirer is unable to use the online form, he/she may mail the request to the Secretary of the B31 Standards Committee at the above address. The request for an interpretation should be clear and unambiguous. It is further recommended that the Inquirer submit his/her request in the following format:

Subject:	Cite the applicable paragraph number(s) and the topic of the inquiry in one or two words.
Edition:	Cite the applicable edition of the Code for which the interpretation is being requested.
Question:	Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. Please provide a condensed and precise question, composed in such a way that a "yes" or "no" reply is acceptable.
Proposed Reply(ies):	Provide a proposed reply(ies) in the form of "Yes" or "No," with explanation as needed. If entering replies to more than one question, please number the questions and replies.
Background Information:	Provide the Committee with any background information that will assist the Committee in understanding the inquiry. The Inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in the format described above may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

Moreover, ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Code requirements. If, based on the inquiry information submitted, it is the opinion of the Committee that the Inquirer should seek assistance, the inquiry will be returned with the recommendation that such assistance be obtained.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

Attending Committee Meetings. The B31 Standards Committee regularly holds meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the B31 Standards Committee.

INTRODUCTION

(20) **1 General.** The ASME Code for Pressure Piping consists of many individually published sections, each an American National Standard. Hereafter, in this Introduction and in the text of this Code Section, B31.8, when the word “Code” is used without specific identification, it means this Code Section.

The Code specifies engineering requirements deemed necessary for the safe design and construction of pressure piping. While safety is the primary consideration, this factor alone will not necessarily govern the final specifications of any piping installation or operation. The Code is not a design handbook. Many decisions that must be made to produce a sound piping installation and maintain system integrity during operation are not specified in detail within this Code. The Code does not serve as a substitute for sound engineering judgement by the operating company and designer.

To the greatest possible extent, Code requirements for design are stated in terms of basic design principles and formulas. These are supplemented as necessary with specific requirements to ensure uniform application of principles and to guide selection and application of piping elements. The Code prohibits designs and practices known to be unsafe and contains warnings where caution, but not prohibition, is warranted.

This Code Section includes

(a) references to acceptable material specifications and component standards, including dimensional and mechanical property requirements

(b) requirements for designing components and assemblies

(c) requirements and data for evaluating and limiting stresses, reactions, and movements associated with pressure, temperature changes, and other forces

(d) guidance and limitations on selecting and applying materials, components, and joining methods

(e) requirements for fabricating, assembling, and installing piping

(f) requirements for examining, inspecting, and testing piping

(g) procedures for operation and maintenance that are essential to public safety

(h) provisions for protecting pipelines from external and internal corrosion

It is intended that this Edition of Code Section B31.8 not be retroactive. The latest edition issued at least 6 months before the original contract date for the first phase of activity covering a piping system or systems shall be the governing document, unless agreement is specifically

made between contracting parties to use another issue, or unless the regulatory body having jurisdiction imposes the use of another issue or different requirements.

Either U.S. Customary (USC) units or International System (SI, also known as metric) units may be used with this Edition. Local customary units may also be used to demonstrate compliance with this Code. One system of units should be used consistently for requirements applying to a specific installation. The equations in this Code may be used with any consistent system of units. It is the responsibility of the organization performing calculations to ensure that a consistent system of units is used.

Users of this Code are cautioned against making use of revisions without assurance that they are acceptable to any authorities of jurisdiction where the piping is to be installed.

The Code is under the direction of ASME Committee B31, Code for Pressure Piping, which is organized and operates under procedures of The American Society of Mechanical Engineers that have been accredited by the American National Standards Institute. The Committee is a continuing one and keeps all Code Sections current with new developments in materials, construction, and industrial practice.

When no Section of the ASME Code for Pressure Piping specifically covers a piping system, the user has discretion to select any Section determined to be generally applicable; however, it is cautioned that supplementary requirements to the Section chosen may be necessary to provide for a safe piping system for the intended application. Technical limitations of the various Sections, legal requirements, and possible applicability of other Codes or Standards are some of the factors to be considered by the user in determining the applicability of any Section of this Code.

2 Appendices. This Code contains two kinds of appendices: mandatory and nonmandatory. Mandatory appendices contain materials the user needs to carry out a requirement or recommendation in the main text of the Code. Nonmandatory appendices, which are written in mandatory language, are offered for application at the user's discretion.

3 Interpretations and Revisions. The Committee has established an orderly procedure to consider requests for interpretation and revision of Code requirements. To receive consideration, inquiries must be in writing and

must give full particulars. (See [Nonmandatory Appendix O](#) covering preparation of technical inquiries.)

The approved reply to an inquiry will be sent directly to the inquirer. In addition, the question and reply will be published as part of an Interpretation Supplement to the Code Section, issued with the revisions.

Requests for interpretation and suggestions for revision should be addressed to the Secretary, ASME B31 Committee, The American Society of Mechanical Engineers, Two Park Avenue, New York, NY 10016-5990.

4 Cases. A Case is the prescribed form of reply to an inquiry when study indicates that the Code wording needs clarification or when the reply modifies existing requirements of the Code or grants permission to use new materials or alternative constructions. The Case will be published on the B31.8 Committee Page at <http://cstools.asme.org/>.

A Case is normally issued for a limited period, after which it may be renewed, incorporated in the Code, or allowed to expire if there is no indication of further

need for the requirements covered by the Case. The provisions of a Case, however, may be used after its expiration or withdrawal, provided the Case was effective on the original contract date or was adopted before completion of the work, and the contracting parties agree to its use.

Materials are listed in the Stress Tables only when sufficient usage in piping within the scope of the Code has been shown. Materials may be covered by a Case. Requests for listing shall include evidence of satisfactory usage and specific data to permit establishment of allowable stresses or pressure rating, maximum and minimum temperature limits, and other restrictions. Additional criteria can be found in the guidelines for addition of new materials in the ASME Boiler and Pressure Vessel Code, Section II. (To develop usage and gain experience, unlisted materials may be used in accordance with [para. 811.2.2.](#))

5 Effective Date. This Edition, when issued, contains new Code provisions. It is a compilation of the 2018 Edition and revisions to the 2018 Edition.

ASME B31.8-2020 SUMMARY OF CHANGES

Following approval by the ASME B31 Committee and ASME, and after public review, ASME B31.8-2020 was approved by the American National Standards Institute on September 18, 2020.

ASME B31.8-2020 includes the following changes identified by a margin note, **(20)**.

<i>Page</i>	<i>Location</i>	<i>Change</i>
xiv	Correspondence With the B31 Committee	Added
xvi	Introduction	In General, paragraph on units of measure added
1	801.4	Revised
1	802.1	(1) Subparagraphs (b)(11) and (b)(13) revised (2) Subparagraph (b)(14) added
2	803.1	Definition of <i>gas</i> revised
4	803.7	Term <i>block</i> revised by errata to <i>block valve</i> and definition editorially revised
6	804.7.3	Revised in its entirety
8	805.1.4	(1) Definitions of <i>arc weld</i> and <i>seam weld</i> revised (2) Definition of <i>longitudinal weld joint quality factor, E</i> added
8	805.2.1	Term <i>stand-up pressure test</i> editorially revised
12	805.2.6	Definition of <i>design life</i> editorially revised
16	814.1.1	References updated
17	816	Second paragraph revised
18	817.1.3	Subparagraph (d) revised
22	825.2	Revised in its entirety
22	825.5	Subparagraphs (a) and (b) revised
23	826.3	Subparagraph (d) revised
26	831.3.1	In subpara. (c), second sentence added
29	831.4.2	Subparagraph (k) added
31	832.3	(1) Subparagraph (e) revised (2) Subparagraph (h) editorially revised
35	834.5	Subparagraph (a) added and subsequent subparagraphs redesignated
39	841.1.1	In subpara. (a) nomenclature, definition of <i>E</i> revised
39	841.1.2	(1) In subparas. (b) and (c), first sentence revised (2) In subpara. (c)(2), last two paragraphs revised
41	841.1.7	Revised
43	841.1.9	(1) In subpara. (b), “upported” corrected by errata to “supported” (2) Subparagraph (g)(1) revised
43	Table 841.1.7-1	(1) Title revised (2) Pipe class entries for API 5L revised
45	841.1.10	In subpara. (c), last sentence added

<i>Page</i>	<i>Location</i>	<i>Change</i>
48	841.2.4	Subparagraph (c)(3) revised
50	841.3.1	(1) Subparagraph (a) revised (2) Subparagraphs (h) and (i) added
51	841.3.2	Subparagraph (c)(3) revised
64	843.4.5	Revised in its entirety
64	843.4.6	Revised
71	846.1.1	First sentence editorially revised
75	849.1.6	Subparagraphs (e) and (f) added
84	851.4.3	(1) Subparagraphs (c) and (d) revised (2.) In subpara. (e), fifth sentence editorially revised
87	851.12.1	Subparagraph (b) editorially revised
96	856.1	First paragraph editorially revised
109	A814.1.1	Revised
110	A825	Deleted
110	A826	Former paras. A826.2, A826.2.1, A826.2.2, and A-826.2.3 redesignated as A826.3, A826.3.1, A826.3.2, and A836.3.3, respectively
111	A840.2	Last sentence added
113	A842.2.2	In subparas. (c) and (d), equations revised in their entirety
117	A844.3	Last sentence added
118	A847.1	Revised
118	A847.4	Revised
125	B826.3	Former paragraph B826.2 redesignated
131	Mandatory Appendix A	References updated
137	Nonmandatory Appendix C	References updated
141	Table D-1	(1) Entries for Type and SMYS revised (2) ASTM A3333, ASTM A381, ASTM A671, ASTM A672, and ASTM A691 added to Specs (3) Note 1 revised in its entirety
144	Table E-1	(1) General Note added (2) Last column head editorially revised (3) Under description, ninth entry revised
149	F-2	(1) Paragraphs F-2.1, F-2.1M, F-2.2, and F-2.2M revised in their entirety (2) Titles added to Figures F-1, F-2, F-3, F-4, F-6, and F-7 (3) General Note deleted from Figure F-3
158	Mandatory Appendix I	Term <i>sketch</i> revised as <i>illustration</i> throughout
164	Figure I-5	Illustration (g) revised
190	Figure R-1	Illustration (b) caption revised by errata

INTENTIONALLY LEFT BLANK

General Provisions and Definitions

801 GENERAL

801.1 Approved Standards and Specifications

Standards and specifications approved for use under this Code and the names and addresses of the sponsoring organizations are shown in [Mandatory Appendix A](#). It is not considered practicable to refer to a specific edition of each of the standards and specifications in the individual Code paragraphs.

801.2 Use of Standards and Specifications Incorporated by Reference

Some standards and specifications cited in [Mandatory Appendix A](#) are supplemented by specific requirements elsewhere in this Code. Users of this Code are advised against attempting direct application of any of these standards without carefully observing the Code's reference to that standard.

801.3 Standard Dimensions

Adherence to American National Standards Institute (ANSI) dimensions is strongly recommended wherever practicable. Paragraphs or notations specifying these and other dimensional standards in this Code, however, shall not be mandatory, provided that other designs of at least equal strength and tightness, capable of withstanding the same test requirements, are substituted.

(20) 801.4 Units of Measure

This Code states values in both USC and SI units. Within the text, the SI units are shown in parentheses or in separate tables. The values stated in each system are not exact equivalents; therefore, each system of units should be used independently of the other. When separate equations are provided for USC and SI units, those equations shall be executed using variables in the units associated with the specific equation. The results obtained from execution of these equations may be converted to other units.

When necessary to convert from one system of units to another, conversion should be made by rounding the values to the number of significant digits of implied precision in the starting value, but to not less than four significant digits for use in calculations. For factors used in converting USC units to SI units, see [Nonmandatory Appendix J](#).

802 SCOPE AND INTENT

802.1 Scope

(20)

(a) This Code covers the design, fabrication, installation, inspection, and testing of pipeline facilities used for the transportation of gas. This Code also covers safety aspects of the operation and maintenance of those facilities. (See [Mandatory Appendix Q](#) for scope diagrams.)

This Code is concerned only with certain safety aspects of liquefied petroleum gases when they are vaporized and used as gaseous fuels. All of the requirements of NFPA 58 and NFPA 59 and of this Code concerning design, construction, and operation and maintenance of piping facilities shall apply to piping systems handling butane, propane, or mixtures of these gases.

(b) This Code does not apply to

(1) design and manufacture of pressure vessels covered by the BPV Code.¹

(2) piping with metal temperatures above 450°F (232°C). (For low-temperature considerations, see [section 812](#).)

(3) piping beyond the outlet of the customer's meter set assembly. (Refer to ANSI Z223.1/NFPA 54.)

(4) piping in oil refineries or natural gasoline extraction plants, gas treating plant piping other than the main gas stream piping in dehydration, and all other processing plants installed as part of a gas transmission system, gas manufacturing plants, industrial plants, or mines. (See other applicable sections of the ASME Code for Pressure Piping, B31.)

(5) vent piping to operate at substantially atmospheric pressures for waste gases of any kind.

(6) wellhead assemblies, including control valves, flow lines between wellhead and trap or separator, offshore platform production facility piping, or casing and tubing in gas or oil wells. (For offshore platform production facility piping, see API RP 14E.)

(7) the design and manufacture of proprietary items of equipment, apparatus, or instruments.

(8) the design and manufacture of heat exchangers. (Refer to appropriate TEMA² standard.)

(9) liquid petroleum transportation piping systems. (Refer to ASME B31.4.)

¹ BPV Code references here and elsewhere in this Code are to the ASME Boiler and Pressure Vessel Code.

² Tubular Exchanger Manufacturers Association, 25 North Broadway, Tarrytown, NY 10591.