

**ASME B89.1.13-2013**

[Revision of ASME B89.1.13-2001 (R2006)]

# Micrometers

---

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**

INTENTIONALLY LEFT BLANK

**ASME B89.1.13-2013**

**[Revision of ASME B89.1.13-2001 (R2006)]**

# Micrometers

---

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: September 30, 2013

This Standard will be revised when the Society approves the issuance of a new edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME B89 Committee may be published as Cases. Cases and interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,  
in an electronic retrieval system or otherwise,  
without the prior written permission of the publisher.

The American Society of Mechanical Engineers  
Two Park Avenue, New York, NY 10016-5990

Copyright © 2013 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All rights reserved  
Printed in U.S.A.

# CONTENTS

Foreword .....	iv
Committee Roster .....	v
Correspondence With the B89 Committee .....	vi
<b>1 Scope</b> .....	1
<b>2 Definitions</b> .....	1
<b>3 References</b> .....	1
<b>4 Micrometers – General</b> .....	2
<b>5 Outside Micrometers</b> .....	3
<b>6 Inside Micrometers</b> .....	3
<b>7 Depth Micrometers</b> .....	5
<b>8 Micrometers With Digital Readout</b> .....	6
<b>Figures</b>	
5-1 Typical Outside Micrometer .....	3
6-1 Typical Inside Micrometer .....	5
7-1 Typical Depth Micrometer .....	6
8.1-1 Mechanical Digital Micrometer .....	6
8.2-1 Electronic Digital Micrometer .....	6
<b>Tables</b>	
5.1-1 Maximum Permissible Errors of Outside Micrometers (Metric System) .....	4
5.1-2 Maximum Permissible Errors of Outside Micrometers (Inch System) .....	4
5.6-1 Metric-Measure Setting Standards .....	5
5.6-2 Inch-Measure Setting Standards .....	5
6.1-1 Maximum Permissible Errors of Inside Micrometers (Metric System) .....	5
6.1-2 Maximum Permissible Errors of Inside Micrometers (Inch System) .....	5
7.3.1-1 Maximum Permissible Errors of Depth Micrometers (Metric System) .....	6
7.3.1-2 Maximum Permissible Errors of Depth Micrometers (Inch System) .....	6
<b>Nonmandatory Appendices</b>	
A Good Operating Procedure .....	7
B Environmental Considerations .....	9
C Test Methods .....	10
D Uncertainty for Micrometer Calibrations .....	13
E Comparison With ISO 3611:2010 .....	17

## FOREWORD

ASME Standards Committee B89 on Dimensional Metrology, under procedures approved by the American National Standards Institute (ANSI), has the responsibility of preparing standards that encompass the inspection and the means of measuring characteristics of various geometrical parameters, such as diameter, length, flatness, parallelism, concentricity, taper, and squareness. Since micrometers are widely used for the measurement and comparison of some of these features the B89 Consensus Committee authorized formation of Project Team B89.1.13 to prepare this Standard.

This Standard is a revision of the first edition, ASME B89.1.13-2001. The 2001 edition was based in part on Federal Specification GGG-C-105C, published by the General Services Administration (GSA), as well as manufacturer's current practices and technologies. In 2010, the International Organization for Standardization (ISO) published a revision of ISO 3611, the ISO standard for outside micrometers. The goal of this revision to ASME B89.1.13 is to bring some harmonization between these ISO and ASME standards while not changing the fundamental concepts of ASME B89.1.13-2001. In particular, the terminology and definitions associated with specifications and testing methods have been harmonized. In addition, this revision has been updated with many of the concepts developed and standardized by the ASME B89.7 subcommittee.

This Standard was approved by the American National Standards Institute on February 20, 2013.

# ASME B89 COMMITTEE

## Dimensional Metrology

(The following is the roster of the Committee at the time of approval of this Standard.)

### STANDARDS COMMITTEE OFFICERS

**B. Parry**, *Chair*  
**S. D. Phillips**, *Vice Chair*  
**F. Constantino**, *Secretary*

### STANDARDS COMMITTEE PERSONNEL

<b>T. Charlton, Jr.</b> , Charlton Associates	<b>E. P. Morse</b> , University of North Carolina at Charlotte
<b>D. J. Christy</b> , Mahr Federal, Inc.	<b>B. Parry</b> , The Boeing Co.
<b>F. Constantino</b> , The American Society of Mechanical Engineers	<b>P. Pereira</b> , Caterpillar, Inc.
<b>G. A. Hetland</b> , International Institute of Geometric Dimensioning and Tolerancing	<b>S. D. Phillips</b> , National Institute of Standards and Technology
<b>M. P. Krystek</b> , Physikalisch-Technische Bundesanstalt	<b>J. G. Salsbury</b> , Mitutoyo America Corp.
<b>M. Liebers</b> , Professional Instruments Co.	<b>D. Sawyer</b> , National Institute of Standards and Technology
	<b>R. L. Thompson</b> , U.S. Air Force

### SUBCOMMITTEE 1 — LENGTH

<b>D. Sawyer</b> , <i>Chair</i> , National Institute of Standards and Technology	<b>D. T. Harr</b> , Glastonbury Southern Gage
<b>C. J. Blackburn</b> , National Institute of Standards and Technology	<b>K. Kokal</b> , Micro Laboratories, Inc.
<b>M. Braine</b> , National Institute of Standards and Technology	<b>E. P. Morse</b> , University of North Carolina at Charlotte
<b>D. Carlson</b> , L.S. Starrett Co.	<b>J. G. Salsbury</b> , Mitutoyo America Corp.
<b>D. J. Christy</b> , Mahr Federal, Inc.	<b>F. S. Stanfield</b> , National Institute of Standards and Technology
<b>T. D. Doiron</b> , National Institute of Standards and Technology	<b>W. A. Watts</b> , Glastonbury Southern Gage

### PROJECT TEAM 1.13 — MICROMETERS

<b>J. G. Salsbury</b> , <i>Chair</i> , Mitutoyo America Corp.	<b>B. Parry</b> , The Boeing Co.
<b>E. W. Blackwood</b> , The Boeing Co.	<b>P. Pereira</b> , Caterpillar, Inc.
<b>D. Carlson</b> , L.S. Starrett Co.	<b>S. Ramsdale</b> , Honeywell Federal Manufacturing & Technologies, LLC
<b>K. W. John</b> , U.S. Air Force	<b>D. Sawyer</b> , National Institute of Standards and Technology
<b>K. Kokal</b> , Micro Laboratories, Inc.	<b>K. Skinner</b> , U.S. Air Force
<b>A. Kumar</b> , Mitutoyo America Corp.	<b>R. L. Thompson</b> , U.S. Air Force
<b>W. C. Lehmus</b> , Diamond Technical Services, Inc.	

## CORRESPONDENCE WITH THE B89 COMMITTEE

**General.** ASME Codes and Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions, and attending Committee meetings. Correspondence should be addressed to:

Secretary, B89 Standards Committee  
The American Society of Mechanical Engineers  
Two Park Avenue  
New York, NY 10016  
<http://go.asme.org/Inquiry>

**Proposing Revisions.** Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible: citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

**Proposing a Case.** Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard, the paragraph, figure or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

**Interpretations.** Upon request, the B89 Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the B89 Standards Committee.

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format:

Subject: Cite the applicable paragraph number(s) and provide a concise description.  
Edition: Cite the applicable edition of the standard for which the interpretation is being requested.  
Question: Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation.

Requests that are not in this format may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information which might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

**Attending Committee Meetings.** The B89 Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the Secretary of the B89 Standards Committee.

# MICROMETERS

## 1 SCOPE

This Standard is intended to provide the essential requirements for micrometers as a basis for mutual understanding between manufacturers and consumers. Outside, inside, and depth micrometers are described in the Standard.

## 2 DEFINITIONS

**backlash:** a relative movement between interacting mechanical parts, resulting from looseness. (ASME B5.54-2005) In this Standard, backlash is further defined as the rotation of the spindle, in the opposite direction of the initial reading, before spindle moves in a linear direction. This condition is typically caused by looseness of fit between the lead screw and adjusting nut.

**end shake:** the amount of spindle movement when an axial force is applied in the direction of the spindle, alternating towards the anvil and away from the anvil, without rotating the spindle.

**error of indication:** for a measuring instrument, difference between an instrument indication and the quantity being measured.

NOTE: The error of indication can be written as  $E = K - R_0$ , where  $R$  is the indication and  $R_0$  denotes the indication of an ideal measuring instrument measuring the same measurement. In the testing and verification of a measuring instrument, the error of indication is typically evaluated by measuring a calibrated reference standard. (Adapted from JCGM 100:2012)

**flatness:** the condition of a surface or derived median plane having all elements in one plane.

NOTE: A flatness tolerance specifies a tolerance zone defined by two parallel planes within which the surface or derived median plane must lie. (ASME Y14.5M-2009)

**full measuring face contact:** contact between the full area of the measuring face and a feature of a workpiece. (ISO 3611:2010)

**maximum permissible error (of indication) (MPE):** for a measuring instrument, maximum difference, permitted by specifications or regulations, between the instrument indication and the quantity being measured. (JCGM 106:2012)

**partial measuring face contact:** contact between a partial area of the measuring face and a feature of a workpiece. (ISO 3611:2010)

**side shake:** the amount of spindle side movement when a force is applied perpendicularly to the measuring end

of the spindle, alternating from side to side, without rotating the spindle.

**tolerance limit:** specified upper or lower bound of permissible values of a property. (JCGM 106:2012)

## 3 REFERENCES

- ASME B5.54-2005, Methods for Performance Evaluation of Computer Numerically Controlled Machining Centers
- ASME B46.1-2009, Surface Texture (Surface Roughness, Waviness, and Lay)
- ASME B89.1.9-2002, Core Locks
- ASME B89.6.2-1973 (R2012), Temperature and Humidity Environment for Dimensional Measurement
- ASME B89.7.3.1-2001, Guidelines for Decision Rules: Consideration of Measurement Uncertainty in Determining Conformance to Specifications
- ASME B89.7.3.2-2007, Guidelines for the Evaluation of Dimensional Measurement Uncertainty
- ASME B89.7.5-2006, Metrological Traceability of Dimensional Measurements to the SI Unit of Length
- ASME Y14.5-2009, Dimensioning and Tolerancing  
 Publisher: The American Society of Mechanical Engineers (ASME), Two Park Avenue, New York, NY 10016-5990; Order Department: 22 Law Drive, P.O. Box 2900, Fairfield, NJ 07007-2900 (www.asme.org)
- ASTM E18-08, Standard Test Methods for Rockwell Hardness of Metallic Materials
- IEEE/ASTM SI 10-2010, American National Standard for Metric Practice  
 Publisher: American Society for Testing and Materials (ASTM International), 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959 (www.astm.org)
- ISO 1:2002, Geometrical Product Specifications (GPS) — Standard reference temperature for geometrical product specification and verification
- ISO 3611:2010, Geometrical product specifications (GPS) — Dimensional measuring equipment: Micrometers for external measurements — Design and metrological characteristics  
 Publisher: International Organization for Standardization (ISO) Central Secretariat, 1, ch. de la Voie-Creuse, Case postale 56, CH-1211 Genève 20, Switzerland/Suisse (www.iso.org)
- JCGM 100:2008, Evaluation of measurement data — Guide to the expression of uncertainty in measurement (GUM)