

ASME MFC-11–2006
(Revision of ASME MFC-11M–2003)

Measurement of Fluid Flow by Means of Coriolis Mass Flowmeters

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Intentionally left blank

ASME MFC-11–2006
(Revision of ASME MFC-11M–2003)

Measurement of Fluid Flow by Means of Coriolis Mass Flowmeters

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Three Park Avenue • New York, NY 10016

Date of Issuance: March 30, 2007

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda issued to this edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org> as they are issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2007 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	iv
Committee Roster	v
Correspondence With the MFC Committee	vi
1 Scope	1
2 Terminology, Symbols, References, and Bibliography	2
3 Mass Flow Measurement	6
4 Coriolis Flowmeter Selection and Application Guidelines	9
5 Inspection and Compliance	15
6 Density Measurement of Liquid	15
7 Volume Flow Measurement Under Metering Conditions	17
8 Additional Measurements	19
9 Coriolis Flow Measurement Uncertainty Analysis Procedure	20
Figures	
3.1.1 Principle of Operation of a Coriolis Flowmeter	7
4.1.3-1 Examples of Coriolis Flowmeter Performance and Pressure Loss vs. Flow Rate	10
4.1.3-2 Examples of Coriolis Flowmeter Performance and Pressure Loss vs. Flow Rate	10
4.1.3-3 Examples of Coriolis Flowmeter Performance and Pressure Loss vs. Flow Rate	11
4.1.3-4 Examples of Coriolis Flowmeter Performance vs. Flow Rate	11
Tables	
2.3 Symbols	3
2.4 Abbreviations	6
Nonmandatory Appendices	
A Flow Calibration Techniques	23
B Safety Considerations and Secondary Containment of Coriolis Flowmeters	25
C Coriolis Flowmeter Sizing Considerations	26

FOREWORD

Coriolis flowmeters cover a family of devices with varying designs that depend on the Coriolis force generated by the fluid (liquid or gas) flowing through oscillating tube(s). The primary purpose of Coriolis flowmeters is to measure mass flow. However, some of these flowmeters also measure liquid density and temperature of the oscillating tube wall. From the measurements, the mass flow of liquid or gas, liquid density, liquid volume flow, and other related quantities can be determined. This Standard was approved by the American National Standards Institute (ANSI) on July 13, 2006.

ASME MFC COMMITTEE

Measurement of Fluid Flow in Closed Conduits

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

Z. D. Husain, *Chair*
R. J. DeBoom, *Vice Chair*
A. L. Guzman, *Secretary*

STANDARDS COMMITTEE PERSONNEL

C. J. Blechinger, *Member Emeritus*, Consultant
R. M. Bough, Rolls-Royce
G. P. Corpron, Consultant
R. J. DeBoom, Consultant
D. Faber, *Corresponding Member*, Badger Meter, Inc.
R. H. Fritz, *Corresponding Member*, Lonestar Measurement and Controls
F. D. Goodson, Emerson Process Management — Daniel Division
A. L. Guzman, The American Society of Mechanical Engineers
Z. D. Husain, Chevron Corp.
E. H. Jones, Jr., *Alternate*, Chevron Petroleum Technology
C. G. Langford, Consultant
W. M. Mattar, Invensys/Foxboro Co.

G. E. Mattingly, Consultant
D. R. Mesnard, Consultant
R. W. Miller, *Member Emeritus*, W. Miller and Associates, Inc.
A. M. Quraishi, American Gas Association
B. K. Rao, Consultant
W. F. Seidl, Colorado Engineering Experiment Station, Inc.
T. M. Kegel, *Alternate*, Colorado Engineering Experiment Station, Inc.
D. W. Spitzer, Spitzer and Boyes, LLC
R. N. Steven, Colorado Engineering Experiment Station, Inc.
D. H. Strobel, *Member Emeritus*, Consultant
J. H. Vignos, *Member Emeritus*, Consultant
D. W. Wheland, Rosemount, Inc.
D. C. Pratt, Wyatt Engineering

SUBCOMMITTEE 11 — DYNAMIC MASS FLOWMETERS (MFC)

R. J. DeBoom, *Chair*, Consultant
G. P. Corpron, Consultant
Z. D. Husain, Chevron Corp.
M. J. Keilty, Endress Hauser Flowtec AG
M. S. Lee, Micro Motion, Inc.
W. M. Mattar, Invensys/Foxboro Co.

D. R. Mesnard, Consultant
A. M. Quraishi, American Gas Association
B. K. Rao, Consultant
D. W. Spitzer, Spitzer and Boyes, LLC
J. H. Vignos, Consultant

CORRESPONDENCE WITH THE MFC COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions, and attending committee meetings. Correspondence should be addressed to:

Secretary, MFC Standards Committee
The American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed revision, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Interpretations. Upon request, the MFC Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the MFC Standards Committee.

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format.

Subject: Cite the applicable paragraph number(s), and the topic of the inquiry.
Edition: Cite the applicable edition of the Standard for which the interpretation is being requested.
Question: Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format will be rewritten in this format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Attending Committee Meetings. The MFC Committee regularly holds meetings, which are open to the public. Persons wishing to attend any meeting should contact the Secretary of the MFC Standards Committee.

MEASUREMENT OF FLUID FLOW BY MEANS OF CORIOLIS MASS FLOWMETERS

1 SCOPE

ASME MFC-11 establishes common terminology and gives guidelines for the selection, installation, calibration, and operation of Coriolis flowmeters for the determination of mass flow, density, volume flow, and other parameters. The content of this Standard is applied to the flow measurement of liquids, gases, mixtures of gases, multiphase flows, and miscible and immiscible mixtures of liquids.

2 TERMINOLOGY, SYMBOLS, REFERENCES, AND BIBLIOGRAPHY

Paragraph 2.1 lists definitions from ASME MFC-1M used in ASME MFC-11.

Paragraph 2.2 lists definitions specific to this Standard.

Paragraph 2.3 lists symbols (see Table 2.3) used in this Standard (see notes and superscripts).

Paragraph 2.4 lists abbreviations (see Table 2.4) used in this Standard.

Paragraph 2.5 lists references used in this Standard and a bibliography.

2.1 Definitions Copied From ASME MFC-1M

accuracy: the degree of freedom from error; the degree of conformity of the indicated value to the true value of the measured quantity.

calibration:

(a) the process of comparing the indicated flow to a traceable reference standard

(b) the process of adjusting the output of a device to bring it to a desired value within a specified tolerance for a particular value of the input.

cavitation: the implosion of vapor bubbles formed after flashing when the local pressure rises above the vapor pressure of the liquid. See also *flashing*.

Coriolis flowmeter: a device consisting of a flow sensor and a transmitter which measures the mass flow by means of the Coriolis force generated by flowing fluid through oscillating tube(s); it may also provide measurements of density and temperature.

cross-talk: if two or more Coriolis flowmeters are to be mounted close together, interference through mechanical coupling may occur. This is often referred to as cross-talk. The manufacturer should be consulted for methods of avoiding cross-talk.

density calibration factor(s): calibration factor(s) associated with density measurement.

drive system: means for inducing the oscillation of the tube(s).

flashing: the formation of vapor bubbles in a liquid when the local pressure falls to or below the vapor pressure of the liquid, often due to local lowering of pressure because of an increase in the liquid velocity. See also *cavitation*.

flow calibration factor(s): calibration factor(s) associated with mass flow measurement.

flow sensor: a mechanical assembly consisting of an oscillating tube(s), coil drive system, oscillating tube deflection measurement sensor(s), flanges/fittings, and housing

housing: environmental protection of the flow sensor.

oscillating tube(s): tube(s) through which the fluid to be measured flows.

rangeability: Coriolis flowmeter rangeability is the ratio of the maximum to minimum flowrates or Reynolds number in the range over which the flowmeter meets a specified uncertainty and/or accuracy.

repeatability of measurement (qualitative): the closeness of agreement among a series of results obtained with the same method on identical test material, under the same conditions (same operator, same apparatus, same laboratory, and short intervals of time).

repeatability of measurement (quantitative): the value below which the absolute difference between any two single test results obtained under the same conditions, [see *repeatability of measurement (qualitative)*], may be expected to lie with a specified probability. In the absence of other indications, the probability is 95%.

reproducibility (quantitative): the closeness of agreement between results obtained when the conditions of measurement differ; for example, with respect to different test apparatus, operators, facilities, time intervals, etc.

NOTE: The following three paragraphs are included to help with understanding the definitions of repeatability and reproducibility.

(a) Repeatability is a quantified measure of the short term stability of a flowmeter. Repeatability can be determined from successive tests of the meter, over short periods of time, without changing the test conditions. Repeatability can be quantified in terms of the standard deviation or the max./min. differences in these results.

(b) Reproducibility is a quantified measure of the longer-term stability of a flowmeter. Reproducibility can be determined from