
ASME MFC-3M-1989

(REVISION OF ASME MFC 3M-1985)

REAFFIRMED 1995

FOR CURRENT COMMITTEE PERSONNEL
PLEASE SEE ASME MANUAL AS-11

**Measurement of
Fluid Flow in Pipes
Using Orifice, Nozzle,
and Venturi**

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers

AN ASME STANDARD

Measurement of Fluid Flow in Pipes Using Orifice, Nozzle, and Venturi

ASME MFC-3M-1989

(REVISION OF ASME MFC-3M-1985)



The American Society of
Mechanical Engineers

345 East 47th Street, New York, N.Y. 10017

Date of Issuance: January 31, 1990

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda or written interpretations of the requirements of this Standard issued to this Edition.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Consensus Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment which provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable Letters Patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME does not accept any responsibility for interpretations of this document made by individual volunteers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

Copyright © 1990 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All Rights Reserved
Printed in U.S.A.

FOREWORD

(This Foreword is not part of ASME MFC-3M-1989.)

Prior to the publication of the first edition of this Standard, ASME MFC-3M-1984, there was no U.S. standard covering all of the measurements of fluid flows through closed conduits and pipes and using differential pressure devices (primary elements). Most people have used for guidance the ASME Fluid Meters. The International Organization for Standardization (ISO) developed a general use standard, ISO 5167, but incorporating expressions for discharge coefficients that the ASME Fluid Meters Research Committee determined covers a considerably broader span of fluids and flowing conditions, and reduced the uncertainty in the prediction of the discharge coefficient.

This Standard has been prepared by the ASME Standards Committee on the Measurement of Fluid Flow in Closed Conduits (MFC) and incorporates the ASME-ISO orifice coefficient equations in both U.S. customary and SI (metric) units. It is intended to:

- (a) cover the broader requirements of flow measurements found throughout industry using differential producing flowmeters; and
- (b) be a practical working document, with representative calculations for some of the equations given in Appendix B.

In order to promote U.S. competitiveness in international trade, this Standard has been made as consistent and technically equivalent as practical with ISO 5167. There have been some technical and many editorial changes made in consideration of U.S. practice and some new technical insights.

This revision includes extensive editorial, stylistic, and format changes to the 1985 edition. There have been no substantive changes to the text of the Standard.

Suggestions for improvement of this Standard will be welcome. They should be sent to Secretary, ASME MFC Main Committee, 345 East 47th Street, New York, NY 10017.

This revision was approved as an ASME National Standard on November 11, 1989.

ASME STANDARDS COMMITTEE MFC
Measurement of Fluid Flow in Closed Conduits

(The following is the roster of the Committee at the time of approval of this Standard.)

OFFICERS

R. W. Miller, *Chairman*
W. F. Z. Lee, *Vice Chairman*
C. J. Gomez, *Secretary*

COMMITTEE PERSONNEL

N. A. Alston
S. R. Beitler
C. Blechinger
M. Bradner
J. S. Castorina
G. P. Corpron
R. G. Dieck

A. G. Ferron
R. L. Galley
T. L. Hillburn
Z. D. Husain
E. H. Jones, Jr.
D. R. Keyser
S. Klak

C. G. Langford
E. D. Mannherz
G. E. Mattingly
W. Seidl
D. W. Spitzer
D. A. Sullivan
R. G. Teyssandier
J. H. Vignos

SUBCOMMITTEE 2 — PRESSURE DIFFERENTIAL DEVICES

M. Bradner, *Chairman*
H. P. Bean
S. R. Beitler
E. E. Buxton

P. J. Disimile
R. B. Dowdell
W. A. Fling, Jr.
G. B. Golden

D. Halmi
S. Klak
D. W. Spitzer
R. G. Teyssandier

CONTENTS

Foreword.....	iii
Standards Committee Roster.....	v
1 Scope and Field of Application.....	1
2 References.....	2
3 Symbols and Definitions.....	2
3.1 Symbols.....	2
3.2 Definitions.....	2
4 Principle of Measurement and the Method of Computation.....	10
4.1 Principle of Measurement.....	10
4.2 Method of Sizing the Bore of Selected Primary Element.....	11
4.3 Computation of Flow Rate.....	12
4.4 Determination of Gas (Vapor) Density.....	12
5 General Measurement Requirements.....	13
5.1 Primary Device.....	13
5.2 Type of Fluid.....	13
5.3 Flow Conditions.....	13
6 Installation Requirements.....	14
6.1 General.....	14
6.2 Specific Installation Requirements for Orifice Plates.....	16
6.3 Upstream Length.....	17
6.4 Upstream and Downstream Straight Lengths for Installation Between Various Fittings and the Primary Device.....	17
6.5 Flow Conditioning Devices.....	18
6.6 General Requirement for Flow Conditions at the Primary Device.....	21
7 Orifice Plates and Pressure Taps.....	21
7.1 Description.....	21
7.2 Differential Pressure Taps.....	25
7.3 Coefficients and Corresponding Uncertainties for Orifice Plates.....	29
7.4 Pressure Loss $\Delta\omega [h]$	32
8 ASME Flow Nozzles.....	32
8.1 Recommended Proportions for ASME Nozzles.....	32
8.2 Pressure Tap Requirements.....	34
8.3 Installation Requirements.....	34

8.4	ASME Flow Nozzle Requirements.....	35
8.5	Uncertainties.....	35
8.6	Unrecovered Pressure Loss.....	36
9	ASME Venturi Tubes.....	36
9.1	Types of Venturi Tubes.....	36
9.2	Geometric Profiles for ASME Venturi Tubes.....	37
9.3	Materials and Manufacture of ASME Venturi Tubes.....	39
9.4	Pressure Taps.....	39
9.5	ASME Venturi Tube Discharge Coefficients.....	39
9.6	Uncertainties.....	41
9.7	Pressure Loss of Venturi Tubes $\zeta [h_1]$	41
9.8	Installation Requirements for ASME Venturi Tubes.....	42
10	Uncertainties in the Measurement of Flow Rate.....	43
10.1	Definition of Uncertainty.....	43
10.2	Practical Computation of Uncertainty.....	44

Figures

1	Eccentricity of Installed Orifice.....	17
2	Flow Conditioners.....	19
3	Standard Orifice Plate.....	22
4	Location for Orifice Flange, and D and $D/2$ taps.....	27
5	Corner Taps.....	28
6	ASME Flow Nozzles.....	33
7	Profile of the ASME Venturi Tube.....	37
8	Discharge Coefficients of ASME Rough Cast Venturi Tubes as a Function of R_D	40
9	Pressure Loss Across an ASME Venturi Tube.....	42
D1	Pressure Loss Across an ASME Venturi Tube.....	56

Tables

1	Symbols.....	3
2	Recommended Straight Lengths for Nozzles and Orifice Plates for 0.5% Additional Uncertainty.....	15
3	Minimum Orifice Plate Thickness.....	24
4	Recommended Maximum Diameters of Pressure Tap Holes for Flange and D and $D/2$ Taps.....	25
5	Upper Limits of Relative Roughness of the Upstream Pipe for Corner Tap Orifice Plates.....	29
6	Uncertainty of Discharge Coefficients.....	36
7	Recommended Straight Lengths for ASME Venturi Tubes (for 0.5% Additional Uncertainty).....	43
A1	47
B1	Results of Sample Calculations for Discharge Coefficients at $R_D = 10^5$	49
B2	Results of Sample Calculations for Expansion Factor $\epsilon [Y]$	49
E1	Thermal Expansion Data [SI].....	58
E2	Thermal Expansion Data [U.S.].....	59
E3	Thermal Expansion of Various Materials.....	60

Appendices	
A	Typical Values of the Pipe Wall Roughness k 47
B	Sample Calculations for Discharge Coefficients and Expansion Factors 49
C	Classical Venturi Tubes Used Outside the Scope Covered by ASME MFC-3M 51
D	Pressure Loss in a Classical Venturi Tube 55
E	Thermal Expansion Factor 57
	Index 61

MEASUREMENT OF FLUID FLOW IN PIPES USING ORIFICE, NOZZLE, AND VENTURI

1 SCOPE AND FIELD OF APPLICATION

This Standard specifies the geometry and method of use (installation and flowing conditions) for orifice plates, nozzles, and Venturi tubes when they are inserted in a conduit running full, to determine the rate of the fluid flowing. It also gives necessary information for calculating flow rate and its associated uncertainty.

It applies only to pressure difference devices in which the flow remains turbulent and subsonic throughout the measuring section, is steady or varies only slowly with time and the fluid is considered single-phased. In addition, the uncertainties are given in the appropriate sections of this Standard for each of these devices, within the pipe size and Reynolds number limits which are specified.

It deals with devices for which sufficient calibrations have been made to enable the specification of coherent systems of application and to enable calculations to be made with certain predictable limits of uncertainty.

The devices introduced into the pipe are called primary devices. The term *primary device* also includes the pressure taps and the associated upstream and downstream piping. All other instruments or devices required for the measurement or transmission of the differential pressures are known as *secondary elements*, and in combination are referred to as the secondary devices. This Standard covers the primary devices; secondary devices¹ will be mentioned only occasionally.

The following primary devices are covered in this Standard:

- (a) orifice plates, which can be used with the following arrangements of pressure taps:
 - (1) flange pressure taps
 - (2) D and $D/2$ pressure taps²
 - (3) corner pressure taps
- (b) nozzles:
 - (1) ASME long radius nozzles
- (c) Venturi tubes:
 - (1) classical Venturi tubes.³

This Standard does not cover pipe or conduit sizes under 50 mm [2 in.] nominal.

This Standard does not apply to ASME Performance Test Code measurements.

This Standard is applicable to measurement of flow of any fluid, (liquid, vapor, or gas).

¹See ASME/ANSI MFC-8M.

²Orifice plates with *vena contracta* taps are not considered in this Standard.

³In the U.S. the classical Venturi tube is sometimes called the Herschel Venturi tube.