

ASME NQA-1–2004
(Revision of ASME NQA-1–2000)

Quality Assurance Requirements for Nuclear Facility Applications

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME NQA-1-2004
(Revision of ASME NQA-1-2000)

Quality Assurance Requirements for Nuclear Facility Applications

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Three Park Avenue • New York, NY 10016

Date of Issuance: December 22, 2004

The 2004 edition of this Standard is being issued with an automatic addenda subscription service. The use of an addenda allows revisions made in response to public review comments or committee actions to be published on a regular yearly basis; revisions published in addenda will become effective 6 months after the Date of Issuance of the addenda. The next edition of this Standard is scheduled for publication in 2007.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. The interpretations will be included with the above addenda service.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of the infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2004 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

(A detailed Contents precedes each NQA Part.)

Foreword	iv
Preparation of Technical Inquiries to the Nuclear Quality Assurance Committee	vi
Committee Roster	vii
Summary of Changes	viii
Part I Requirements for Quality Assurance Programs for Nuclear Facilities (From Former NQA-1)	1
Part II Quality Assurance Requirements for Nuclear Facility Applications	35
Part III Nonmandatory Appendices (From Former NQA-1 and NQA-2)	113
Part IV Nonmandatory Appendices: Positions and Applications Matrices	169

FOREWORD

Early in 1975, the American National Standards Institute (ANSI) assigned overall responsibility for coordination among technical societies and development and maintenance of nuclear power quality assurance standards to the American Society of Mechanical Engineers (ASME). The ASME Committee on Nuclear Quality Assurance was constituted on October 3, 1975, and began operating under the ASME Procedures for Nuclear Projects. The ASME Committee on Nuclear Quality Assurance currently operates under the ASME Operating Procedures and Practices for Nuclear Codes and Standards Development Committees. This Committee prepared ANSI/ASME NQA-1, Quality Assurance Program Requirements for Nuclear Power Plants, and ANSI/ASME NQA-2, Quality Assurance Requirements for Nuclear Power Plants, which were first issued in 1979 and 1983, respectively, as American National Standards.

NQA-1-1979 was based upon the contents of ANSI/ASME N45.2-1977, Quality Assurance Program Requirements for Nuclear Facilities; ANSI N46.2, Revision 1, Quality Assurance Program Requirements for Post Reactor Nuclear Fuel Cycle Facilities; and the following seven daughter Standards of ANSI/ASME N45.2:

- N45.2.6-1978 Qualifications of Inspection, Examination, and Testing Personnel for Nuclear Power Plants
- N45.2.9-1979 Requirements for Collection, Storage, and Maintenance of Quality Assurance Records for Nuclear Power Plants
- N45.2.10-1973 Quality Assurance Terms and Definitions
- N45.2.11-1974 Quality Assurance Requirements for the Design of Nuclear Power Plants
- N45.2.12-1977 Requirements for Auditing of Quality Assurance Programs for Nuclear Power Plants
- N45.2.13-1976 Quality Assurance Requirements for Control of Procurement of Items and Services for Nuclear Power Plants
- N45.2.23-1978 Qualification of Quality Assurance Program Audit Personnel for Nuclear Power Plants

Since the 1979 Edition was issued, NQA-1 was revised and published in 1983, 1986, 1989, 1994, 1997, and 2000. From its initial publication in 1979, the Standard has retained the 18-criteria structure of 10 CFR 50 Appendix B in a portion of the document. For this edition, Part I is organized by the 18-criteria structure and is intended to meet and implement the criteria of 10 CFR 50 Appendix B, Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants, dated January 20, 1975.

The ASME NQA-2 1983 standard incorporated the requirements of the following quality assurance Standards not included in ASME NQA-1:

- N45.2.1-1980 Cleaning of Fluid Systems and Associated Components for Nuclear Power Plants
- N45.2.2-1978 Packaging, Shipping, Receiving, Storage, and Handling of Items for Nuclear Power Plants
- N45.2.3-1973 (R1978) Housekeeping During the Construction Phase of Nuclear Power Plants
- N45.2.5-1978 Supplementary Quality Assurance Requirements for Installation, Inspection, and Testing of Structural Concrete, Structural Steel, Soils, and Foundations During the Construction Phase of Nuclear Power Plants
- N45.2.8-1975 (R1980) Supplementary Quality Assurance Requirements for Installation, Inspection and Testing of Mechanical Equipment and Systems for the Construction Phase of Nuclear Power Plants
- N45.2.15-1981 Hoisting, Rigging, and Transporting of Items for Nuclear Power Plants

In 1984, the NQA Committee initiated work to expand the Standard to address quality assurance program requirements appropriate to site characterization of high-level nuclear waste repositories. This effort resulted in the preparation of a new standard, ASME NQA-3, Quality Assurance Program Requirements for the Collection of Scientific and Technical Information for Site Characterization of High-Level Nuclear Waste Repositories, which was issued in 1989.

The NQA Committee has regularly updated and revised the Standards since the 1979 Edition was issued to improve its utility and value to the nuclear industry. In the early 1990s, the NQA Committee recognized that the NQA-1, NQA-2, and NQA-3 standards were not easily understood and applied by all users, and some potential users were not selecting NQA-1 and NQA-2 as the Standard of choice. The Committee decided to restructure the NQA Standards into a single multipart document that would improve the clarity of the standard, allow more rapid response to varied applications of NQA requirements and guidance, and provide a performance based focus. The restructured requirements, guidance, and applications appendices facilitate judicious application of the entire Standard or portions of the Standard to the wide variety of work encountered by today's nuclear industry. The new structure aids improved understanding and supports effective implementation of the requirements, continues to address quality assurance program compliance aspects, and adds focus on quality results.

This multipart Standard, issued initially as NQA-1-1994, includes requirements and nonmandatory guidance to establish and implement a quality assurance program for any nuclear facility application. Part I contains quality assurance program requirements for the siting, design, construction, operation, and decommissioning of nuclear facilities. Part II contains quality assurance requirements for the planning and conducting of the fabrication, construction, modification, repair, maintenance, and testing of systems, components, or activities for nuclear facilities. Part III contains nonmandatory guidance and application appendices previously included in NQA-1, NQA-2, and NQA-3. Part IV contains NQA position papers, application matrices for users, cross-reference comparisons to NQA, and other quality program information.

The arrangement of the requirements in Part I (from former NQA-1), requirements for work practices in Part II (from former NQA-2), and nonmandatory guidance and applications appendices in Part III (from former NQA-1 and NQA-2) permits judicious application of the entire Standard or portions of the Standard. This edition (or post-1994 edition or addenda) is invoked by a procurement document or contract, only Parts I and II should be considered requirements as applicable, unless other specific Parts, Subparts, or Appendices of NQA-1 are specified. The guidance in Part III is not intended to be automatically imposed as supplemental requirements. The extent to which this Standard should be applied will depend upon the specific type of nuclear facility, items, or services involved and the nature and scope and the relative importance of the activities being performed. The extent of application is to be determined by the organization imposing the Standard. For example, the organization may invoke all requirements, selected requirements, or requirements with appropriate changes. Part III is intended to provide explanatory information and guidance for use by organizations in developing and implementing their program. It also provides examples of methods for implementing the requirements of Parts I and II. Other methods may be equally suitable. The Standard may be applied to any structure, system, component, or activity that is essential to the satisfactory performance of the facility. The Standard may also be applied to a structure, system, component, or activity independent of a facility if its satisfactory performance is essential.

The NQA Committee is aware of, and actively endorses, the growing worldwide movement toward rational, cost-effective quality assurance practices — practices that focus on results. Therefore, changes considered necessary to improve the understanding and effective implementation have been made that are intended to address compliance aspects with a focus on results. To assure consistency with outside activities of a similar nature, the Committee is maintaining liaison with other national and international groups that have a similar interest.

Requests for interpretation or suggestions for improvement of this Standard should be addressed to the Secretary of the ASME Committee on Nuclear Quality Assurance, The American Society of Mechanical Engineers, Three Park Avenue, New York, NY 10016-5990.

PREPARATION OF TECHNICAL INQUIRIES TO THE NUCLEAR QUALITY ASSURANCE COMMITTEE

INTRODUCTION

The ASME Nuclear Quality Assurance Committee will consider written requests for interpretations and revisions to NQA Standards and develop new requirements or guidance if dictated by technological development. The Committee's activities in this regard are limited strictly to interpretations of the requirements and guidance, or to the consideration of revisions to the present Standard on the basis of new data or technology. As a matter of published policy, ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, specific organizations, individual titles, or activity and, accordingly, inquiries requiring such consideration will be returned. Moreover, ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the inquiry information submitted, it is the opinion of the Committee that the inquirer should seek assistance, the inquiry will be returned with the recommendation that such assistance be obtained.

All inquiries that do not provide the information needed for the Committee's full understanding will be returned.

INQUIRY FORMAT

Inquiries shall be limited strictly to interpretations of the requirements and guidance, or to the consideration of revisions to the present Standard on the basis of new data or technology.

Inquiries shall be submitted in the following format:

(a) *Scope.* The inquiry shall involve a single requirement/guidance or closely related requirements/guidance. An inquiry letter concerning unrelated subjects will be returned.

(b) *Background.* State the purpose of the inquiry, which would be either to obtain an interpretation of the Standard or to propose consideration of a revision to the present Standard. Provide the information needed for the Committee's understanding of the inquiry concisely, being sure to include reference to the applicable Standard, Edition, Addenda, Requirements, Parts, Subparts, Appendices, paragraph figures, and tables. If illustrations are provided, they shall be limited to the scope of the inquiry.

(c) *Inquiry Structure*

(1) *Proposed Question(s).* The inquiry shall be stated in a condensed and precise question format, omitting superfluous background information, and, where appropriate, composed in such a way that "yes" or "no" (perhaps with provisos) would be an acceptable reply. The inquiry statement should be technically and editorially correct.

(2) *Proposed Reply(ies).* State what it is believed that the Standard requires. If, in the inquirer's opinion, a revision to the Standard is needed, recommended wording shall be provided.

(3) *Submission.* The inquiry shall be submitted in typewritten form; however, legible, handwritten inquiries will be considered. It shall include the name and mailing address and telephone number of the inquirer and be mailed to the following address:

Secretary
ASME Nuclear Quality Assurance Committee
Nuclear Department
Three Park Avenue
New York, NY 10016-5990

COMMITTEE ON NUCLEAR QUALITY ASSURANCE

(As of September 1, 2003)

STANDARDS COMMITTEE

J. G. Adkins, <i>Chair</i>	D. A. Harmon
T. E. Dunn, <i>Vice Chair</i>	H. H. Hoffman
R. F. Hartstern, Jr., <i>Vice Chair</i>	D. Jennings
S. J. Rossi, <i>Secretary</i>	N. C. Kazanas
J. W. Anderson	H. J. Kirschenmann
N. R. Barker	H. G. Kitchen
S. A. Bernsen	M. E. Langston
R. J. Blauw	J. W. McIntyre
D. A. Brown	N. P. Moreau
J. M. Case	C. H. Moseley, Jr.
R. W. Clark	T. Muraki
T. R. Colandrea	M. F. Nicol
G. Danielson	T. V. Sarma
D. H. Dorman	R. C. Schrotke, Jr.
M. C. Eagle	M. E. Smith
B. Evans	W. K. Sowder
R. J. Fitzgerald	J. R. Yanek
M. A. Gavett	J. A. Perry, <i>Honorary Member</i>

EXECUTIVE COMMITTEE

T. E. Dunn, <i>Chair</i>	D. Jennings
R. F. Hartstern, Jr., <i>Vice Chair</i>	M. F. Nicol
S. J. Rossi, <i>Secretary</i>	T. V. Sarma
J. G. Adkins	R. C. Schrotke, Jr.
G. Danielson	W. K. Sowder

Subcommittee on Applications

G. Danielson, <i>Chair</i>	D. L. Hoffman
J. J. Connelly, <i>Vice Chair</i>	D. Lee
M. E. Smith, <i>Secretary</i>	M. L. Hernandez-Royce
J. W. Anderson	R. C. Schrotke, Jr.
M. A. Gavett	W. R. Smith

Subcommittee on Assessment and Verification

T. V. Sarma, <i>Chair</i>	N. C. Kazanas
M. E. Langston, <i>Vice Chair</i>	J. W. McIntyre
N. R. Barker, <i>Secretary</i>	J. J. Pearson
S. A. Bernsen	D. L. Robinson
R. J. Fitzgerald	T. T. Suzuki
J. G. Adkins	R. J. Vurpillat, Jr.
R. A. Jacobus	

Subcommittee on Engineering and Procurement Processes

R. C. Schrotke, Jr., <i>Chair</i>	D. A. Harmon
R. J. Blauw, <i>Vice Chair</i>	M. L. Hernandez-Royce
S. B. Ailes, <i>Secretary</i>	H. H. Hoffman
J. G. Adkins	C. H. Moseley, Jr.
K. W. Brayman	P. L. Bussolini
W. J. Bryan	N. P. Moreau
T. Carter	N. W. Mowery, Sr.
J. M. Case	T. Muraki
G. F. Deaton	K. W. Wells
T. E. Dunn	J. R. Yanek

Subcommittee on Interfaces and Administration

W. K. Sowder, <i>Chair</i>	G. Danielson
C. H. Moseley, Jr., <i>Secretary</i>	O. P. Gormley
D. A. Brown	R. A. Sacco
R. C. Schrotke, Jr.	

Subcommittee on Program Management Processes

D. Jennings, <i>Chair</i>	B. Evans
H. J. Kirschenmann, <i>Vice Chair</i>	R. F. Hartstern, Jr.
J. L. Day, <i>Secretary</i>	K. A. Morrell
J. E. Bergstrom	E. Schwartz
L. L. Campbell	D. A. Winchester

Subcommittee on Waste Management

M. F. Nicol, <i>Chair</i>	J. M. Floyd
P. L. Bussolini, <i>Vice Chair</i>	H. G. Kitchen
S. H. Horton, <i>Secretary</i>	R. J. Laskey
D. A. Armour	M. L. Matthews
A. E. Bradford	G. Olson
R. W. Clark	C. L. Pittiglio, Jr.
T. R. Colandrea	F. J. Schelling
M. C. Eagle	

ASME NQA-1–2004 SUMMARY OF CHANGES

Following approval by the Standards Committee of the Committee on Nuclear Quality Assurance, and after public review, ASME NQA-1–2004 was approved by the American National Standards Institute on November 8, 2004.

ASME NQA-1–2004 includes revisions, corrections, and editorial changes introduced in ASME NQA-1a–2002, as well as the following changes identified by a margin note, **(04)**, placed next to the affected area.

<i>Page</i>	<i>Location</i>	<i>Change</i>
iv, v	Foreword	Revised in its entirety
vi	Preparation of Technical Inquiries to the Nuclear Quality Assurance	Introduction revised
4–6	Part I, Introduction	Revised
9	Requirement 2, 303.3	Revised
11	Requirement 3, 300	In subpart (c)(1), (2), (3), and the last paragraph, “characteristics” has been revised to read “critical characteristics”
12	Requirement 3, 500	Subparagraph (a) revised
13, 14	Requirement 3, 801.4	Revised
19–21	Requirement 7, 70C	Revised in its entirety
27	Requirement 12	Revised in its entirety
28	Requirement 14, 400	Revised
39	Part II, Introduction, 700	Revised
40–43	Table 700	Formerly undesignated table, designated as Table 700 and revised
47	Subpart 2.1, 304.1	Revised
48	Subpart 2.1, Table 302.5	Redesignated and editorially revised
49	Subpart 2.1, Table 304.1	Revised
98	Subpart 2.16	Revised
133–137	Nonmandatory Appendix 7A-2	Revised in its entirety
150	Nonmandatory Appendix 17A-1, 204	Paragraphs 204.2 through 204.6 redesignated as 204.1.1 through 204.1.5, respectively
152–154	Nonmandatory Appendix 18A-1, 100	Revised
	Nonmandatory Appendix 18A-1, 600	Revised

<i>Page</i>	<i>Location</i>	<i>Change</i>
161	Nonmandatory Appendix 2.18A	Redesignated (formerly Appendix 2.18)
162, 163	Nonmandatory Appendix 2.18B	Added
166, 167	Nonmandatory Appendix 3.1	Added
180	Subpart 4.2, Table 600	Revised
184–197	Subpart 4.3	Added
198, 199	Subpart 4.4	Added
200–205	Subpart 4.5	Added

SPECIAL NOTE:

The interpretations to ASME NQA-1–2004 are included as a separate section for the user's convenience.

PART I: REQUIREMENTS FOR QUALITY ASSURANCE PROGRAMS FOR NUCLEAR FACILITIES

(FROM FORMER NQA-1)

CONTENTS

Introduction	4
100	Purpose	4
200	Applicability	4
300	Responsibility	4
400	Terms and Definitions	4
Requirement 1	Organization	7
100	Basic	7
200	Structure and Responsibility	7
300	Interface Control	7
Requirement 2	Quality Assurance Program	8
100	Basic	8
200	Indoctrination and Training	8
300	Qualification Requirements	8
400	Certification of Qualification	9
500	Records	10
Requirement 3	Design Control	11
100	Basic	11
200	Design Input	11
300	Design Process	11
400	Design Analyses	11
500	Design Verification	12
600	Change Control	12
700	Interface Control	13
800	Software Design Control	13
900	Documentation and Records	14
Requirement 4	Procurement Document Control	15
100	Basic	15
200	Content of the Procurement Documents	15
300	Procurement Document Review	15
400	Procurement Document Changes	15
Requirement 5	Instructions, Procedures, and Drawings	16
100	Basic	16
Requirement 6	Document Control	17
100	Basic	17

200	Document Control	17
300	Document Changes	17
Requirement 7	Control of Purchased Items and Services	18
100	Basic	18
200	Supplier Evaluation and Selection	18
300	Bid Evaluation	18
400	Control of Supplier-Generated Documents	18
500	Acceptance of Item or Service	18
600	Control of Supplier Nonconformances	19
700	Commercial Grade Items and Services	19
800	Records	21
Requirement 8	Identification and Control of Items	22
100	Basic	22
200	Identification Methods	22
300	Specific Requirements	22
Requirement 9	Control of Special Processes	23
100	Basic	23
200	Process Control	23
300	Responsibility	23
400	Records	23
Requirement 10	Inspection	24
100	Basic	24
200	Inspection Requirements	24
300	Inspection Hold Points	24
400	Inspection Planning	24
500	In-Process Inspection	24
600	Final Inspections	24
700	Records	24
Requirement 11	Test Control	25
100	Basic	25
200	Test Requirements	25
300	Test Procedures (Other Than for Computer Programs)	25
400	Computer Program Test Procedures	25
500	Test Results	26
600	Test Records	26
Requirement 12	Control of Measuring and Test Equipment	27
100	Basic	27
200	Selection	27
300	Calibration and Control	27
400	Records	27
Requirement 13	Handling, Storage, and Shipping	28
100	Basic	28
200	Special Requirements	28
300	Procedures	28
400	Tools and Equipment	28
500	Operators	28
600	Marking or Labeling	28
Requirement 14	Inspection, Test, and Operating Status	29
100	Basic	29
Requirement 15	Control of Nonconforming Items	30
100	Basic	30
200	Identification	30

300	Segregation	30
400	Disposition	30
Requirement 16	Corrective Action	31
100	Basic	31
Requirement 17	Quality Assurance Records	32
100	Basic	32
200	Generation of Records	32
300	Authentication of Records	32
400	Classification	32
500	Receipt Control of Records	32
600	Storage	32
700	Retention	32
800	Maintenance of Records	32
Requirement 18	Audits	34
100	Basic	34
200	Scheduling	34
300	Preparation	34
400	Performance	34
500	Reporting	34
600	Response	34
700	Follow-Up Action	34
800	Records	34

(04)

PART I

INTRODUCTION

This Standard reflects industry experience and current understanding of the quality assurance requirements necessary to achieve safe, reliable, and efficient utilization of nuclear energy, and management and processing of radioactive materials. The Standard focuses on the achievement of results, emphasizes the role of the individual and line management in the achievement of quality, and fosters the application of these requirements in a manner consistent with the relative importance of the item or activity.

100 PURPOSE

This Part sets forth requirements for the establishment and execution of quality assurance programs during siting, design, construction, operation, and decommissioning of nuclear facilities. Nonmandatory guidance is provided in the Appendices in Part III.

200 APPLICABILITY

The requirements of Part I apply to activities that could affect the quality of nuclear material applications, structures, systems, and components of nuclear facilities. Examples of nuclear facilities are facilities for power generation, spent fuel storage, waste management, fuel reprocessing, nuclear material processing, fuel fabrication, and other related facilities. Activities include siting, designing, procuring, fabricating, constructing, handling, shipping, receiving, storing, cleaning, erecting, installing, inspecting, testing, operating, maintaining, repairing, refueling, modifying, and decommissioning. The application of this Part, or portions thereof, shall be invoked by written contracts, policies, procedures, specifications, or other appropriate documents.

300 RESPONSIBILITY

The organization invoking this Part shall be responsible for specifying which requirements, or portions thereof, apply, and appropriately relating them to specific items and services. The organization implementing this Part, or portions thereof, shall be responsible for complying with the specific requirements to achieve quality results.

400 TERMS AND DEFINITIONS

The following definitions are provided to assure a uniform understanding of select terms as they are used in this Part.

acceptance criteria: specified limits placed on the performance, results, or other characteristics of an item, process, or service defined in codes, standards, or other requirement documents.

audit: a planned and documented activity performed to determine by investigation, examination, or evaluation of objective evidence the adequacy of and compliance with established procedures, instructions, drawings, and other applicable documents, and the effectiveness of implementation. An audit should not be confused with surveillance or inspection activities performed for the sole purpose of process control or product acceptance.

Certificate of Conformance: a document signed or otherwise authenticated by an authorized individual certifying the degree to which items or services meet specified requirements.

certification: the act of determining, verifying, and attesting in writing to the qualifications of personnel, processes, procedures, or items in accordance with specified requirements.

characteristic: any property or attribute of an item, process, or service that is distinct, desirable, and measurable.

commercial grade item:¹ an item satisfying the following:

- (a) not subject to design or specification requirements that are unique to those facilities or activities
- (b) used in applications other than those facilities or activities

(c) to be ordered from the manufacturer/supplier on the basis of specifications set forth in the manufacturer's published product description (e.g., a catalog)

commercial grade item:² a structure, system, or component, or part thereof, that affects its safety function, that was not designed and manufactured in accordance with the requirements of this Standard.

¹ This definition is applicable to facilities and activities other than nuclear power plants licensed pursuant to 10 CFR Part 50.

² These definitions are for nuclear power plants pursuant to 10 CFR Part 50 and also provides sufficient quality criteria for facilities identified in Part I, Introduction.

PART II: QUALITY ASSURANCE REQUIREMENTS FOR NUCLEAR FACILITY APPLICATIONS

CONTENTS

Introduction	38
100	Purpose	38
200	Applicability	38
300	Responsibility	38
400	Planning and Procedures	38
500	Qualification of Personnel	39
600	Definitions	39
700	Referenced Codes, Standards, and Specifications	39
800	Multiunit Facility Provisions	39
Table		
700	Codes, Standards, and Specifications Referenced in Part II	40
Subpart 2.1	Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components for Nuclear Power Plants	44
100	General	44
200	General Requirements	45
300	Cleanness Criteria	46
400	Manufacturing Phase Cleanness	48
500	Cleanness Prior to Installation	49
600	Cleanness During Installation	50
700	Maintenance of Installation Cleanness	50
800	Preoperational Cleaning	50
900	Layup and Postlayup Cleaning	51
1000	Postoperational Repairs and Modifications	51
1100	Records	52
Tables		
302.5	Summary Table for Cleanness Classes	48
304.1	Water Requirements	49
304.4	Flushing Requirements for Hydraulic, Instrument Control, and Lubrication Systems	49
Subpart 2.2	Quality Assurance Requirements for Packaging, Shipping, Receiving, Storage, and Handling of Items for Nuclear Power Plants	53
100	General	53
200	General Requirements	53
300	Packaging	54
400	Shipping	60
500	Receiving	61
600	Storage	62
700	Handling	64

800	Records	64
Subpart 2.3	Quality Assurance Requirements for Housekeeping for Nuclear Power Plants	65
100	General	65
200	General Requirements	65
300	Requirements	65
400	Records	67
Subpart 2.4	Installation, Inspection, and Testing Requirements for Power, Instrumentation, and Control Equipment at Nuclear Facilities	68
Subpart 2.5	Quality Assurance Requirements for Installation, Inspection, and Testing of Structural Concrete, Structural Steel, Soils, and Foundations for Nuclear Power Plants	69
100	General	69
200	General Requirements	69
300	Requirements	69
400	Preconstruction Verification	70
500	Inspection of Soils and Earthwork	70
600	Inspection of Foundation Pile and Caisson Construction	71
700	Inspection of Concrete Construction	73
800	Inspection of Steel Construction	76
900	Data Analysis and Evaluation	77
1000	Records	78
Table		
506	Required In-Process Tests	72
Subpart 2.7	Quality Assurance Requirements for Computer Software for Nuclear Facility Applications	79
100	General	79
200	General Requirements	80
300	Software Acquisition	81
400	Software Engineering Method	81
500	Standards, Conventions, and Other Work Practices	82
600	Support Software	82
700	References	83
Subpart 2.8	Quality Assurance Requirements for Installation, Inspection, and Testing of Mechanical Equipment and Systems for Nuclear Power Plants	84
100	General	84
200	General Requirements	84
300	Preinstallation Verification	85
400	Control During Installation Process	86
500	Installed Systems Inspection and Tests	87
600	Data Analysis and Evaluation	89
700	Records	89
Subpart 2.15	Quality Assurance Requirements for Hoisting, Rigging, and Transporting of Items for Nuclear Power Plants	90
100	General	90
200	General Requirements	90
300	Types of Handling Equipment	91
400	Design Requirements	92
500	Acceptance Criteria for Manufactured Handling Equipment	94
600	Testing, Inspection, and Maintenance	94
700	Control of the Use of Handling Equipment	96
800	Qualifications of Personnel	97

900	Records	97
Subpart 2.16	Requirements for the Calibration and Control of Measuring and Test Equipment Used in Nuclear Facilities	98
Subpart 2.18	Quality Assurance Requirements for Maintenance of Nuclear Facilities	99
100	General	99
200	General Requirements	99
300	Preventive Maintenance	100
400	Corrective Maintenance	101
500	Records	101
Subpart 2.20	Quality Assurance Requirements for Subsurface Investigations for Nuclear Power Plants	102
100	General	102
200	General Requirements	102
300	Verification Requirements	103
400	Field Investigation Requirements	104
500	Laboratory Testing	106
600	Evaluation and Analysis	106
700	Records	107
Subpart 2.21	Quality Assurance Guidelines for Decommissioning Nuclear Facilities	108
100	General	108
200	Prerequisites	108
300	Pre-Decommissioning Checks	109
400	Control During Decommissioning	111
500	Post-Decommissioning Checks	112
600	Records	112

PART II

INTRODUCTION

100 PURPOSE

Part II supplements the quality assurance requirements of Part I for the planning and execution of identified tasks during siting, design, construction, operation, and decommissioning of nuclear facilities. Applicable non-mandatory guidance for various subparts is provided in Part III.

200 APPLICABILITY

An appropriate quality assurance program, based on the nature and scope of the work to be performed and the relative importance of the items or services, shall be specified in contractual documents by selective applications of portions of Part I for programmatic activities and of this Part for work-oriented activities. The requirements of this Part (Part II) apply to siting, design, construction, operation, and decommissioning activities that affect the quality of structures, systems, and components for nuclear facilities. These activities include the performing function of attaining quality objectives and verifying that activities affecting quality have been correctly performed. These activities include planning, siting investigation, designing, procuring, fabricating, handling, shipping, storing, cleaning, erecting, installing, inspecting, testing, operating, maintaining, repairing, modifying, and decommissioning. To the extent applicable to the activities being performed, the application of this Part, or portions thereof, and the provisions of Part I shall be specified in written contracts, policies, procedures, or instructions.

300 RESPONSIBILITY

The organization invoking this Part shall be responsible for specifying which section, or portions thereof, apply and appropriately relating them to specific items and services. To the extent necessary, this organization shall invoke the applicable provision of Part I to specify a complete quality assurance program appropriate for the specific items or services.

The organization upon which this Part, or portions thereof, is invoked shall be responsible for complying with the specified requirements.

400 PLANNING AND PROCEDURES

401 Planning

A plan shall be developed outlining the work to be performed and the work procedures or instructions

required to comply with the requirements of the defined work scope.

Planning for activities such as fabrication, installation, operation, modification, repair, maintenance, decommissioning, inspection, testing, and software verification and validation shall include a review of structure, system or component design and procurement specifications, materials lists, drawings, construction work plans, and schedules to ensure that appropriate activities have been incorporated; that the work can be accomplished as specified; and that time and resources, plus training, are sufficient to accomplish the work in accordance with the specified requirements.

Planning shall define the operations to be performed, the systematic sequential progression of operations, and the overall measures to be employed to preserve the quality of the work.

402 Procedures

Procedures and work instructions identified during planning shall be prepared. Preparation and approval of the procedures/instructions shall be in advance of the need to use the documents. The documents shall be kept current and revised as necessary to assure that the work is performed in accordance with the latest approved information.

The documents shall include the following as applicable:

- (a) personnel safety and structure or facility protection considerations
- (b) precautions to be observed
- (c) work requirements such as those included in specifications, procedures, and instructions for performing an activity
- (d) sequence of activities to be followed and steps within a given activity
- (e) prerequisites
- (f) software verification and validation, test and inspection objectives
- (g) special equipment required
- (h) identification of inspection and test equipment and related calibration requirements including recalibration dates
- (i) sequence and frequency of activities for verifying
- (j) acceptance criteria and methods for verifying
- (k) responsibility and required qualifications of personnel
- (l) approvals and authorizing or verifying signatures