

ASME PCC-1–2010
(Revision of ASME PCC-1–2000)

Guidelines for Pressure Boundary Bolted Flange Joint Assembly

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**



Copyright © 2010 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



Currently in preview, click buy full version

INTENTIONALLY LEFT BLANK



ASME PCC-1–2010
(Revision of ASME PCC-1–2000)

Guidelines for Pressure Boundary Bolted Flange Joint Assembly

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**



Copyright © 2010 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



Date of Issuance: March 5, 2010

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda issued to this edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this document. Interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org> as they are issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2010 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.



CONTENTS

Foreword	v
Committee Roster	vi
1 Scope	1
2 Introduction	1
3 Training, Qualification, and Certification of Joint Assembly Personnel	1
4 Cleaning and Examination of Flange and Fastener Contact Surfaces	1
5 Alignment of Flanged Joints	2
6 Installation of Gasket	2
7 Lubrication of “Working” Surfaces	5
8 Installation of Bolts	5
9 Numbering of Bolts When a Single Tool Is Used	6
10 Tightening of Bolts	6
11 Tightening Sequence When a Single Tool Is Used	10
12 Target Torque Determination	10
13 Joint Pressure and Tightness Testing	11
14 Records	11
15 Joint Disassembly	15
16 References	16
Figures	
1 Indicator-Type Bolt Tightening for Through-Bolted Joints	8
2 Indicator-Type Bolt Tightening for Studed Joints	9
3 Example Legacy Cross-Pattern 12-Bolt Tightening Sequence	14
4 48-Bolt Flange Bolt Grouping Example	15
Tables	
1M Reference Values for Calculating Target Torque Values for Low-Alloy Steel Bolted Joints Based on Target Prestress of 345 MPa (Root Area) (SI Units)	3
1 Reference Values for Calculating Target Torque Values for Low-Alloy Steel Bolted Joints Based on Target Prestress of 50 ksi (Root Area) (U.S. Customary Units)	4
2 Torque Increments for Legacy Cross-Pattern Tightening Using a Single Tool	7
3 Recommended Tool, Tightening Method, and Load-Control Technique Selection Based on Service Applications	11
4 Legacy Cross-Pattern Tightening Sequence and Bolt Numbering System When Using a Single Tool	12
4.1 Alternative to Legacy Cross-Pattern Tightening Sequence and Bolt Numbering System When Using a Single Tool	13
Appendices	
A Notes Regarding Qualifying Flanged Joint Assemblers	19
B Recommendations for Flanged Joint Assembly Procedure Qualification	20



C	Recommended Gasket Contact Surface Finish for Various Gasket Types	21
D	Guidelines for Allowable Gasket Contact Surface Flatness and Defect Depth	22
E	Flange Joint Alignment Guidelines	27
F	Alternatives to Legacy Tightening Sequence/Pattern	30
G	Use of Contractors Specializing in Bolting Services	44
H	Bolt Root and Tensile Stress Areas	45
I	Interaction During Tightening	46
J	Calculation of Target Torque	47
K	Nut Factor Calculation of Target Torque	48
L	ASME B16.5 Flange Bolting Information	49
M	Washer Usage Guidance and Purchase Specification for Through-Hardened Washers	50
N	Definitions, Commentary, and Guidelines on the Reuse of Bolts	55
O	Assembly Bolt Stress Determination	7
P	Guidance on Troubleshooting Flanged Joint Leakage Incidents	69



FOREWORD

ASME formed an Ad Hoc Task Group on Post Construction in 1993 in response to an increased need for recognized and generally accepted engineering standards for the inspection and maintenance of pressure equipment after it has been placed in service. At the recommendation of this Task Group, the Board on Pressure Technology Codes and Standards (BPTCS) formed the Post Construction Committee (PCC) in 1995. The scope of this committee was to develop and maintain standards addressing common issues and technologies related to post-construction activities and to work with other consensus committees in the development of separate, product-specific codes and standards addressing issues encountered after initial construction for equipment and piping covered by Pressure Technology Codes and Standards. The BPTCS covers non-nuclear boilers, pressure vessels (including heat exchangers), piping and piping components, pipelines, and storage tanks.

The PCC selects standards to be developed based on identified needs and the availability of volunteers. The PCC formed the Subcommittee on Inspection Planning and the Subcommittee on Flaw Evaluation in 1995. In 1998, a Task Group under the PCC began preparation of Guidelines for Pressure Boundary Bolted Flange Joint Assembly and in 1999 the Subcommittee on Repair and Testing was formed. Other topics are under consideration and may possibly be developed into future guideline documents.

The subcommittees were charged with preparing standards dealing with several aspects of the in-service inspection and maintenance of pressure equipment and piping. *Guidelines for Pressure Boundary Bolted Flange Joint Assembly* (PCC-1) provides guidance and is applicable to both new and in-service bolted flange joint assemblies. The *Inspection Planning Using Risk-Based Methods* Standard (PCC-3) provides guidance on the preparation of a risk-based inspection plan. Imperfections found at any stage of assembly, installation, inspection, operation, or maintenance are then evaluated, when appropriate, using the procedures provided in the *Fitness-For-Service* Standard (API 579-1/ASME FFS-1). If it is determined that repairs are required, guidance on repair procedures is provided in the appropriate portions of the *Repair of Pressure Equipment and Piping* Standard (PCC-2). To provide all stakeholders involved in pressure equipment with a guide to identify publications related to pressure equipment integrity, a *Guide to Life Cycle Management of Pressure Equipment Integrity* has been prepared (PTB-2).

None of these documents are Codes. They provide recognized and generally accepted good practices that may be used in conjunction with Post-Construction Codes, such as API 510, API 570, and NB-23, and with jurisdictional requirements.

The first edition of ASME PCC-1, *Guidelines for Pressure Boundary Bolted Flange Joint Assembly*, was approved for publication in 2000. This revision was approved by ANSI as an American National Standard on January 14, 2010.



ASME PRESSURE TECHNOLOGY POST CONSTRUCTION COMMITTEE

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

D. A. Lang, Sr., *Chair*
J. R. Sims, Jr., *Vice Chair*
S. J. Rossi, *Secretary*

STANDARDS COMMITTEE PERSONNEL

G. A. Antaki, Becht Engineering Co., Inc.
J. E. Batey, The Dow Chemical Co.
C. Becht IV, Becht Engineering Co., Inc.
D. L. Berger, PPL Generation LLC
W. Brown, The Equity Engineering Group
P. N. Chaku, Lummus Technology, Inc.
E. W. Hayman, Consultant
W. J. Koves, Retired
D. A. Lang, FM Global
D. E. Lay, Hytorc
C. R. Leonard, Life Cycle Engineering
K. Mokhtarian, Consultant
C. C. Neely, Becht Engineering Co., Inc.

T. M. Parks, The National Board of Boiler and Pressure Vessel Inspectors
J. R. Payne, JPAC, Inc.
J. T. Reynolds, Pro-Inspect, Inc.
S. C. Roberts, Shell Global Solutions (UK), Inc.
C. D. Rodery, BP North American Products, Inc.
S. J. Rossi, The American Society of Mechanical Engineers
C. W. Rowley, The Wesley Corp.
J. R. Sims, Jr., Becht Engineering Co., Inc.
K. Oyamada, Delegate
T. Tahara, Delegate
C. D. Cowley, *Contributing Member*, Consultant
E. Michalopoulos, *Contributing Member*, City of Kozani, Greece

POST CONSTRUCTION SUBCOMMITTEE ON WELD JOINT ASSEMBLY (PCC)

C. C. Neely, *Chair*, Becht Engineering Co., Inc.
B. J. Barron, Northrop Grumman Newport News
W. Brown, The Equity Engineering Group
E. W. Hayman, Consultant
D. E. Lay, Hytorc

G. Milne, Hydratight
J. R. Payne, JPAC, Inc.
C. D. Rodery, BP North American Products, Inc.
J. Waterland, Virginia Sealing Products, Inc.



GUIDELINES FOR PRESSURE BOUNDARY BOLTED FLANGE JOINT ASSEMBLY

1 SCOPE

The bolted flange joint assembly (BFJA) guidelines described in this document apply to pressure-boundary flanged joints with ring-type gaskets that are entirely within the circle enclosed by the bolt holes and with no contact outside this circle.¹ By selection of those features suitable to the specific service or need, these guidelines may be used to develop effective joint assembly procedures for the broad range of sizes and service conditions normally encountered in industry.

Guidance on troubleshooting BFJAs not providing leak-tight performance is also provided in this document (Appendix P).

2 INTRODUCTION

A BFJA is a complex mechanical device; therefore, BFJAs that provide leak-free service are the result of many selections/activities having been made/performed within a relatively narrow band of acceptable limits. One of the activities essential to leak-free performance is the joint assembly process. The guidelines outlined in this document cover the assembly elements essential for a high level of leak-tightness integrity of otherwise properly designed/constructed BFJAs. It is recommended that written procedures, incorporating the features of these guidelines that are deemed suitable to the specific application and, in consideration, be developed for use by the joint assemblers. Alternative features and methods for specific applications may be used subject to endorsement by the user or his designated agent.

3 TRAINING, QUALIFICATION, AND CERTIFICATION OF JOINT ASSEMBLY PERSONNEL

It is recommended that the user or his designated agent provide, or arrange to have provided, as appropriate, essential training and qualification testing of the joint assembly personnel who will be expected to follow procedures developed from this Guideline. Notes

¹ Rules for design of bolted flanges with ring-type gaskets are covered in Mandatory Appendix 2 of ASME Boiler and Pressure Vessel Code, Section VIII, Division 1; see also Nonmandatory Appendix S for supplementary considerations for bolted flanges that are helpful to the designer of Appendix 2 flanges.

regarding qualifying flanged joint assemblies are provided in Appendix A.

See section F-2 of Appendix F for comments on accepting flange joint assembly procedures not currently listed in these guidelines.

4 CLEANING AND EXAMINATION OF FLANGE AND FASTENER CONTACT SURFACES

Before assembly is started, clean and examine flange and fastener contact surfaces as described in this section.

With one exception, remove all indications of the previous gasket installation from the gasket contact surfaces; use approved solvents and/or soft-wire brushes, if required, for cleaning to prevent surface contamination and damage to existing surface finish. Avoid using carbon steel brushes on stainless steel flanges.

The exception based on experience is flexible graphite that may remain in the surface finish grooves when either a flexible graphite clad or a spiral-wound gasket with flexible graphite filler is to be used as the replacement gasket.

(a) Examine the gasket contact surfaces of both mating joint flanges for compliance with recommended surface finish (see Appendix C) and for damage to surface finish such as scratches, nicks, gouges, and burrs. Indications running radially across the facing are of particular concern. Refer to Appendix D for guidelines covering recommended limits on gasket contact surface imperfections and their locations.

(1) It is recommended that surface-finish comparator gages be available to joint assembly personnel.

(2) Report any questionable imperfections for appropriate disposition. If weld repair of imperfections is deemed to be required, see ASME PCC-2, Article 3.5 for repair considerations. Appendix C provides recommended final surface finishes.

(b) When working with problematic or critical service [see Note (1) of Table 3] flanges of large diameter with leak histories or suspect fabrication, it is recommended to check gasket contact surfaces of both joint flanges for flatness, both radially and circumferentially. This may be accomplished in many cases using a machinist's straight edge and feeler gages, but using a securely mounted run-out gage or field machining equipment capable of

