

ASME PTB-2-2009

Guide to Life Cycle Management of Pressure Equipment Integrity

Currently in preview, click buy full version



PTB-2-2009

Guide to Life Cycle Management of Pressure Equipment Integrity

Prepared by:

J. R. Sims, Jr.
Becht Engineering Co., Inc.



Date of Issuance: June 30, 2009

This document was prepared as an account of work sponsored by ASME Pressure Technology Codes and Standards (PTCS) through the ASME Standards Technology, LLC (ASME ST-LLC).

Neither ASME, the author, nor others involved in the preparation or review of this document, nor any of their respective employees, members or persons acting on their behalf, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe upon privately owned rights.

Reference herein to any specific commercial product, process or service by trade name, trademark, manufacturer or otherwise does not necessarily constitute or imply its endorsement, recommendation or favoring by ASME or others involved in the preparation or review of this document, or any agency thereof. The views and opinions of the authors, contributors and reviewers of the document expressed herein do not necessarily reflect those of ASME or others involved in the preparation or review of this document, or any agency thereof.

ASME does not “approve,” “rate”, or “endorse” any item, construction, proprietary device or activity.

ASME does not take any position with respect to the validity of any patent rights associated in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME is the registered trademark of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2009 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in the U.S.A.



TABLE OF CONTENTS

List of Appendices.....	vi
List of Tables.....	xii
Foreword.....	xiii
1. Scope.....	1
2. Abbreviations.....	2
3. Definitions.....	3
4. Organization of this Guide.....	4
5. Overview.....	6
6. Power (Steam) Boilers.....	7
6.1. Specification (Purchase) of Power (Steam) Boilers.....	7
6.2. Design and Construction of Power (Steam) Boilers.....	8
6.3. Operation of Power (Steam) Boilers.....	9
6.4. In-service Inspection of Power (Steam) Boilers.....	9
6.5. Fitness-for-service Analysis of Power (Steam) Boilers.....	10
6.6. Repair of Power (Steam) Boilers.....	10
7. Heat Recovery Steam Generators (HRSGs).....	12
7.1. Specification (Purchase) of HRSGs.....	12
7.2. Design and Construction of HRSGs.....	14
7.3. Operation of HRSGs.....	14
7.4. In-service Inspection of HRSGs.....	15
7.5. Fitness-for-service Analysis of HRSGs.....	15
7.6. Repair of HRSGs.....	16
8. Heating Boilers.....	17
8.1. Specification (Purchase) of Heating Boilers.....	17
8.2. Designs and Construction of Heating Boilers.....	19
8.3. Operation of Heating Boilers.....	19
8.4. In-service Inspection of Heating Boilers.....	19
8.5. Fitness-for-service Analysis of Heating Boilers.....	20
8.6. Repair of Heating Boilers.....	21
9. Unfired Steam Boilers.....	22
9.1. Specification (Purchase) of Unfired Steam Boilers.....	22
9.2. Designs and Construction of Unfired Steam Boilers.....	24
9.3. Operation of Unfired Steam Boilers.....	24



9.4.	In-service Inspection of Unfired Steam Boilers	24
9.5.	Fitness-for-service Analysis of Unfired Steam Boilers	25
9.6.	Repair of Unfired Steam Boilers	26
10.	Typical Pressure Vessels	27
10.1.	Specification (Purchase) of Typical Pressure Vessels	27
10.2.	Design and Construction of Typical Pressure Vessels	29
10.3.	Operation of Typical Pressure Vessels	30
10.4.	In-service Inspection of Typical Pressure Vessels	30
10.5.	Fitness-for-service Analysis of Typical Pressure Vessels	31
10.6.	Repair of Typical Pressure Vessels	32
11.	Large, Heavy Wall and High Temperature Pressure Vessels	33
11.1.	Specification (Purchase) of Large, Heavy Wall and High Temperature Pressure Vessels	33
11.2.	Design and Construction of Large, Heavy Wall and High Temperature Pressure Vessels	35
11.3.	Operation of Large, Heavy Wall and High Temperature Pressure Vessels	37
11.4.	In-service Inspection of Large, Heavy Wall and High Temperature Pressure Vessels	37
11.5.	Fitness-for-service Analysis of Large, Heavy Wall and High Temperature Pressure Vessels	38
11.6.	Repair of Large, Heavy Wall and High Temperature Pressure Vessels	38
12.	High Pressure Vessels	40
12.1.	Specification (Purchase) of High Pressure Vessels	40
12.2.	Design and Construction of High Pressure Vessels	42
12.3.	Operation of High Pressure Vessels	42
12.4.	In-service Inspection of High Pressure Vessels	42
12.5.	Fitness-for-service Analysis of High Pressure Vessels	43
12.6.	Repair of High Pressure Vessels	43
13.	Heat Exchangers	45
13.1.	Specification (Purchase) of Heat Exchangers	45
13.2.	Design and Construction of Heat Exchangers	47
13.3.	Operation of Heat Exchangers	48
13.4.	In-service Inspection of Heat Exchangers	49
13.5.	Fitness-for-service Analysis of Heat Exchangers	49
13.6.	Repair of Heat Exchangers	50
14.	Storage Tanks	51
14.1.	Specification (Purchase) of Storage Tanks	51
14.2.	Design and Construction of Storage Tanks	53



14.3. Operation of Storage Tanks 53

14.4. In-service Inspection of Typical Pressure Vessels 53

14.5. Fitness-for-service Analysis of Storage Tanks 54

14.6. Repair of Storage Tanks 55

15. Piping Systems 56

15.1. Specification (Purchase) of Piping Systems 56

15.2. Design and Construction of Piping Systems 56

15.3. Operation of Piping Systems 59

15.4. In-service Inspection of Piping Systems 59

15.5. Fitness-for-service Analysis of Piping Systems 60

15.6. Repair of Piping Systems 60

16. Acquisition (Purchase) of Components, Including Fittings 61

17. Post-construction Documents for Components, Including Fittings 63

18. Overpressure Protection Systems 64

18.1. Specification (Purchase) of Overpressure Protection Systems 64

18.2. Design and Construction of Overpressure Protection Systems 65

18.3. Operation of Overpressure Protection Systems 66

18.4. In-service Inspection of Overpressure Protection Systems 66

18.5. Fitness-for-service Analysis of Overpressure Protection Systems 66

18.6. Repair of Overpressure Protection Systems 66

19. Specific Tasks 67

Acknowledgments 228



LIST OF APPENDICES

Appendix A Summary of Standards Referenced	68
American Petroleum Institute (API) Standards.....	68
A-1 5UE <i>Recommended Practice for Ultrasonic Evaluation of Pipe Imperfections</i>	68
A-2 Publication 327 <i>Aboveground Storage Tank Standards: A Tutorial</i>	69
A-3 API 510 <i>Pressure Vessel Inspection Code: Maintenance Inspection, Rating, Repair, and Alteration</i>	70
A-4 RP 520 Part I <i>Sizing, Selection, and Installation of Pressure-Relieving Devices in Refineries, Part I: Sizing and Selection</i>	71
A-5 RP 520 Part II <i>Sizing, Selection, and Installation of Pressure-Relieving Devices in Refineries, Part II: Installation</i>	73
A-6 Std 521 <i>Guide for Pressure-Relieving and Depressuring Systems</i>	74
A-7 Std 526 <i>Flanged Steel Pressure Relief Valves</i>	75
A-8 Std 530 <i>Calculation of Heater-Tube Thickness in Petroleum Refineries</i>	76
A-9 RP 534 <i>Heat Recovery Steam Generators</i>	77
A-10 Std 560 <i>Fired Heaters for General Refinery Service</i>	78
A-11 API 570 <i>Piping Inspection Code: Inspection, Repair, Alteration, and Rerating of In-service Piping Systems</i>	79
A-12 RP 571 <i>Damage Mechanisms Affecting Fixed Equipment in the Refining Industry</i>	81
A-13 RP 572 <i>Inspection of Pressure Vessels (Towers, Drums, Reactors, Heat Exchangers, and Condensers)</i>	82
A-14 RP 573 <i>Inspection of Fired Boilers and Heaters</i>	83
A-15 RP 574 <i>Inspection Practice for Piping System Components</i>	84
A-16 RP 575 <i>Guidelines and Methods for Inspection of Existing Atmospheric and Low-pressure Storage Tanks</i>	85
A-17 RP 576 <i>Inspection of Pressure-Relieving Devices</i>	86
A-18 RP 577 <i>Welding Inspection and Metallurgy</i>	87
A-19 RP 578 <i>Material Verification Program for New and Existing Alloy Piping Systems</i>	88
A-20 API 579-1/ASME FFS-1 <i>Fitness-For-Service</i>	89
A-21 RP-580 <i>Risk-Based Inspection</i>	90
A-22 RP-581 <i>Risk-Based Inspection: Base Resource Document</i>	91
A-23 RP 582 <i>Welding Guidelines for the Chemical, Oil and Gas Industries</i>	92
A-24 RP 591 <i>Process Valve Qualification Procedure</i>	93
A-25 Std 594 <i>Check Valves: Flanged, Lug, Wafer and Butt-Welding</i>	94
A-26 Std 598 <i>Valve Inspection and Testing</i>	95



A-27	Std API 600/ISO 10434 <i>Bolted Bonnet Steel Gate Valves for Petroleum and Natural Gas Industries</i>	96
A-28	Std 602 <i>Steel Gate, Globe and Check Valves for Sizes DN 100 and Smaller for the Petroleum and Natural Gas Industries</i>	98
A-29	Std 607 <i>Testing of Valves-Fire Type—Testing Requirements</i>	100
A-30	Std 608 <i>Metal Ball Valves-Flanged, Threaded and Butt-Welding Ends</i>	101
A-31	Std 609 <i>Butterfly Valves: Double Flanged, Lug- and Water-Type</i>	102
A-32	Std 620 <i>Design and Construction of Large, Welded, Low-pressure Storage Tanks</i>	103
A-33	RP 621 <i>Reconditioning of Metallic Gate, Globe, and Check Valves</i>	105
A-34	RP 622 <i>Type Testing of Process Valve Packing for Fugitive Emissions</i>	106
A-35	Std 650 <i>Welded Steel Tanks for Oil Storage</i>	107
A-36	RP 651 <i>Cathodic Protection of Aboveground Storage Tanks</i>	108
A-37	RP 652 <i>Lining of Aboveground Petroleum Storage Tank Bottoms</i>	109
A-38	Std 653 <i>Tank Inspection, Repair, Alteration, and Reconstruction</i>	110
A-39	Std 660 <i>Shell-and-Tube Heat Exchangers</i>	111
A-40	Std 661 <i>Air-Cooled Heat Exchangers for General Refinery Service</i>	112
A-41	Std 662, Part 1 <i>Plate Heat Exchangers for General Refinery Services, Plate-and-Frame Heat Exchangers</i>	113
A-42	Std 662, Part 2 <i>Plate Heat Exchangers for General Refinery Services, Brazed Aluminum Plate-Fin Heat Exchangers</i>	114
A-43	Publication 920 <i>Prevention of Brittle Fracture of Pressure Vessel</i>	115
A-44	RP 934A <i>Materials and Fabrication of 2¼Cr-1Mo, 2¼Cr-1Mo-¼V, 3Cr-1Mo and 3Cr-1Mo-¼V Steel Heavy Wall Pressure Vessels for High-Temperature, High-Pressure Hydrogen Service</i>	116
A-45	RP 934C <i>Materials and Fabrication of 1¼Cr-½Mo Steel Heavy Wall Pressure Vessels for High-Pressure Hydrogen Service Operating at or Below 825°F (441°C)</i>	117
A-46	RP 934E <i>RP for Materials and Fabrication of 1¼Cr-½Mo and 1Cr-½Mo Steel Pressure Vessels for Service above 825°F (441°C)</i>	118
A-47	Publication 941 <i>Steels for Hydrogen Service at Elevated Temperatures and Pressures in Petroleum Refineries and Petrochemical Plants</i>	119
A-48	Publication 945 <i>Avoiding Environmental Cracking in Amine Units</i>	121
A-49	Std 1104 <i>Welding of Pipelines and Related Facilities</i>	122
A-50	RP 1107 <i>Pipeline Maintenance Welding Practices</i>	123
A-51	Std 2000 <i>Venting Atmospheric and Low-Pressure Storage Tanks, Nonrefrigerated and Refrigerated</i>	124
A-52	RP 2201 <i>Safe Hot Tapping Practices in the Petroleum and Petrochemical Industries</i>	125



American Society of Civil Engineers (ASCE) Standards	126
A-53 ASCE/SEI 7 <i>Minimum Design Loads for Buildings and Other Structures</i>	126
American Society of Mechanical Engineers (ASME) Standards	127
A-54 B16.1 <i>Gray Iron Pipe Flanges and Flanged Fittings (Classes 25, 125, and 250)</i>	127
A-55 B16.3 <i>Malleable Iron Threaded Fittings (Classes 150 and 300)</i>	128
A-56 B16.4 <i>Gray Iron Threaded Fittings (Classes 125 and 250)</i>	129
A-57 B16.5 <i>Pipe Flanges and Flanged Fittings</i>	130
A-58 B16.9 <i>Factory-Made Wrought Butt-Welding Fittings</i>	131
A-59 B16.10 <i>Face-to-Face and End-to-End Dimension of Valves</i>	132
A-60 B16.11 <i>Forged Fitting, Socket-Welding and Threaded</i>	133
A-61 B16.14 <i>Ferrous Pipe Plugs, Bushings, and Locknuts with Pipe Threads</i>	134
A-62 B16.15 <i>Cast Copper Alloy Threaded Fittings (Classes 125 and 250)</i>	135
A-63 B16.18 <i>Cast Copper Alloy Solder Joint Pressure Fittings</i>	136
A-64 B16.20 <i>Metallic Gaskets for Pipe Flanges (Ring Joint, Spiral Wound, and Jacketed)</i>	137
A-65 B16.21 <i>Nonmetallic Flat Gaskets for Pipe Flanges</i>	139
A-66 B16.22 <i>Wrought Copper and Copper Alloy Solder Joint Pressure Fittings</i>	140
A-67 B16.24 <i>Cast Copper Alloy Pipe Flanges and Flanged Fittings (Classes 150, 300, 600, 900, 1500, and 2500)</i>	141
A-68 B16.25 <i>Butt-Welding Ends</i>	142
A-69 B16.26 <i>Cast Copper Alloy Fittings for Flared Copper Tubes</i>	143
A-70 B16.34 <i>Valves – Flanged, Threaded, and Welding End</i>	144
A-71 B16.36 <i>Orifice Flanges</i>	145
A-72 B16.39 <i>Malleable Iron Threaded Pipe Unions</i>	146
A-73 B16.42 <i>Ductile Iron Pipe Flanges and Flanged Fittings (Classes 150 and 300)</i>	147
A-74 B16.47 <i>Large Diameter Steel Flanges (NPS 26 through NPS 60 Metric/Inch Standard)</i>	148
A-75 B16.48 <i>Line Blanks</i>	149
A-76 B16.50 <i>Wrought Copper and Copper Alloy Braze-Joint Pressure Fittings</i>	150
A-77 B31.1 <i>Power Piping</i>	151
A-78 B31.3 <i>Process Piping</i>	152
A-79 B31.5 <i>Refrigeration Piping and Heat Transfer Components</i>	153
A-80 B31.9 <i>Building Services Piping</i>	154
A-81 B31E <i>Standard for the Seismic Design and Retrofit of Above-Ground Piping Systems</i>	156
A-82 B31G <i>Manual for Determining the Remaining Strength of Corroded Pipelines</i>	157



A-83	B36.10M <i>Welded and Seamless Wrought Steel Pipe</i>	159
A-84	B36.19M <i>Stainless Steel Pipe</i>	160
A-85	B40.100 <i>Pressure Gauges and Gauge Attachments (B40.1, B40.2, B40.5, B40.6, and B40.7)</i>	161
A-86	ASME BPE <i>Bioprocessing Equipment</i>	163
A-87	BPVC Section I <i>Rules for Construction of Power Boilers</i>	164
A-88	BPVC Section II – Materials - Part A <i>Ferrous Material Specifications</i>	165
A-89	BPVC Section II – Materials - Part B <i>Nonferrous Material Specifications</i>	166
A-90	BPVC Section II - Materials Part C <i>Specifications for Welding Rods, Electrodes, and Filler Metals</i>	167
A-91	BPVC Section II – Materials – Part D <i>Materials Properties (Customary)</i>	168
A-92	BPVC Section II – Materials – Part D <i>Materials Properties (Metric)</i>	169
A-93	BPVC Section IV <i>Rules for Construction of Heating Boilers</i>	170
A-94	BPVC Section V <i>Nondestructive Examination</i>	171
A-95	BPVC Section VI <i>Recommended Rules for the Care and Operation of Heating Boilers</i>	172
A-96	BPVC Section VII <i>Recommended Guidelines for the Care of Power Boilers</i>	173
A-97	BPVC Section VIII - Division 1 <i>Rules for Construction of Pressure Vessels</i>	174
A-98	BPVC Section VIII - Division 2 <i>Rules for Construction of Pressure Vessels – Alternative Rules</i>	175
A-99	BPVC Section VIII - Division 3 <i>Rules for Construction of Pressure Vessels - Alternative Rules for Construction of High Pressure Vessels</i>	176
A-100	BPVC Section IX <i>Qualification Standard for Welding and Brazing Procedures, Welders, Brazers, and the Welding and Brazing Operations</i>	177
A-101	BPVC Section X <i>Fiber-Reinforced Plastic Pressure Vessels</i>	178
A-102	BPVC Code Cases <i>Boilers and Pressure Vessels</i>	180
A-103	RTP-1 <i>Fiber-Reinforced Thermoset Plastic Corrosion-Resistant Equipment</i>	181
A-104	PCC-1 <i>Guidelines for Pressure Boundary Bolted Flange Joint Assembly</i>	183
A-105	PCC-2 <i>Repair of Pressure Equipment and Piping</i>	184
A-106	PCC-3 <i>Inspection Planning Using Risk-Based Methods</i>	185
A-107	PTC 25 <i>Pressure Relief Devices (Performance Test Codes)</i>	186
	American Society of NonDestructive Testing Standards	187
A-108	CP-189 <i>ASNT Standard for Qualification and Certification of Nondestructive Testing Personnel</i>	187
A-109	RP SNT-TC-1A <i>Personnel Qualification and Certification in Nondestructive Testing</i>	188
	Electric Power Research Institute (EPRI) Standards	190



A-110	EPRI CS-4774 <i>Guidelines for the Evaluation of Seam-Welded High-Energy Piping</i>	190
A-111	EPRI CS-5208 <i>Life Extension and Assessment of Fossil Power Plants (Conference Proceedings)</i>	191
A-112	EPRI CS-5235 <i>Recommended Practices for Operating and Maintaining Steam Surface Condensers</i>	193
National Association of Corrosion Engineers (NACE) Standards.....		194
A-113	NACE SP0106-2006 <i>Control of Internal Corrosion in Steel Pipelines and Piping Systems</i>	194
A-114	NACE SP0169-2007 <i>Control of External Corrosion on Underground or Submerged Metallic Piping Systems</i>	195
A-115	NACE RP0288-2004 <i>Inspection of Linings on Steel and Concrete</i>	196
A-116	NACE SP0472-2007 <i>Methods and Controls to Prevent In-Service Environmental Cracking of Carbon Steel Weldments in Corrosive Petroleum Refining Environments</i>	197
A-117	NACE SP0590-20007 <i>Prevention, Detection, and Correction of Deaerator Cracking</i>	198
National Board of Boiler and Pressure Vessel Inspectors (NBBPVI) Standards.....		199
A-118	NB-18 <i>National Board Pressure Relief Device Certifications</i>	199
A-119	NB-23 <i>National Board Inspection Code</i>	201
A-120	NB-370 <i>National Board Synopsis of Boiler and Pressure Vessel Laws, Rules and Regulations</i>	203
Tubular Exchanger Manufacturers Association (TEMA) Standards		204
A-121	<i>Standards of the Tubular Exchanger Manufacturers Association</i>	204
Appendix B Additional Reading		205
B-1	<i>Companion Guide to the ASME Boiler & Pressure Vessel Code, Third Edition - Volumes 1, 2 & 3</i>	205
B-2	<i>ASME Section VIII - Division 2, Criteria and Commentary</i>	206
B-3	WRC 488 <i>Damage Mechanisms Affecting Fixed Equipment in the Pulp and Paper Industry</i>	207
B-4	WRC 489 <i>Damage Mechanisms Affecting Fixed Equipment in the Refining Industry</i>	209
B-5	WRC 490 <i>Damage Mechanisms Affecting Fixed Equipment in the Fossil Electric Power Industry</i>	211
B-6	WRC 409 <i>Fundamental Studies of the Metallurgical Causes and Mitigation of Reheat Cracking in 1¼Cr-½Mo and 2¼Cr-1Mo Steels</i>	213
B-7	WRC 411 <i>An Experimental Study of Causes and Repair of Cracking of 1¼Cr-½Mo Steel Equipment</i>	214
B-8	WRC 412 <i>Challenges and Solutions in Repair Welding for Power and Processing Plants – Proceedings of a Workshop</i>	215



B-9	WRC 452 <i>Recommended Practices for Local Heating of Welds in Pressure Vessels</i>	216
B-10	WRC 435 <i>Evaluation of Design Margins for Section VIII, Div. 1 And 2 of the ASME Boiler and Pressure Vessel Code</i>	217
B-11	WRC 447 <i>Evaluation of Operating Margins for In-Service Pressure Equipment</i>	218
B-12	WRC 430 <i>Review of Existing Fitness-For-Service Criteria for Crack-Like Flaws</i> ..	219
B-13	WRC 465 <i>Technologies for the Evaluation of Non-Crack-Like Flaws in Pressurized Components—Erosion/Corrosion, Pitting, Blisters, Shell Out-Of-Roundness, Weld Misalignment, Bulges and Dents</i>	220
B-14	WRC 465 <i>Analysis of the Effects of Temperature on Bolted Joints</i>	221
B-15	WRC 470 <i>Recommendations for Design of Vessels for Elevated Temperature Service</i>	222
B-16	WRC 517 <i>Examination of Mechanical Properties and Corrosion of High Temperature Alloys after Long Term Service Under Advanced Power Plant Boiler Conditions: The Eddystone Studies</i>	223
B-17	WRC 517 <i>Half-Bead Temper-Bead Controlled Deposition Techniques for Improvement of Fabrication and Service Performance of Cr-Mo Steels</i>	224
B-18	WRC 175 <i>PVRC Recommendations on Toughness Requirements for Ferritic Materials</i>	225
B-19	WRC 265 <i>Interpretive Report on Small Scale Test Correlations with K_{IC} Data</i>	226
B-20	Additional Publications	227



LIST OF TABLES

Table 1: Power (Steam) Boilers	7
Table 2: Heat Recovery Steam Generators (HRSGs)	12
Table 3: Heating Boilers	17
Table 4: Unfired Steam Boilers	22
Table 5: Typical Pressure Vessels	27
Table 6: Large, Heavy Wall and High Temperature Pressure Vessels	33
Table 7: High Pressure Vessels.....	40
Table 8: Heat Exchangers	45
Table 9: Storage Tanks	51
Table 10: Piping Systems.....	56
Table 11: Overpressure Protection.....	64



FOREWORD

In 1993, ASME initiated activity to address the development of post construction standards in response to an identified need for recognized and generally accepted engineering standards for the inspection and maintenance of pressure equipment after it has been placed in service. In 1995 the Post Construction Committee (PCC) was appointed to develop and maintain standards addressing common issues and technologies related to post-construction activities, and to work with other consensus committees in the development of separate, product-specific codes and standards addressing issues encountered after initial construction of non-nuclear pressure equipment such as boilers, pressure vessels (including heat exchangers), piping and piping components, pipelines, and storage tanks. Subcommittees were formed on bolted flange joint assembly, repair and testing, and inspection planning. The subcommittees were charged with preparing standards dealing with several aspects of the inservice inspection and maintenance of pressure equipment. As a result, ASME PCC-1 Guidelines for Pressure Boundary Bolted Flange Joint Assembly was published in 2000; ASME PCC-2 Repair of Pressure Equipment and Piping was published in 2006 and ASME PCC-3 Inspection Planning Using Risk-Based Methods was published in 2007.

In the course of preparing the documents described above, the Post Construction Committee recognized the need to provide a guideline or “roadmap” to help users of pressure equipment and their designated agents, as well as manufacturers, owners, regulators and other stakeholders, identify the codes, standards, recommended practices, specifications and guidelines that apply to the life cycle management of pressure equipment integrity. Accordingly, ASME held a workshop in March 2009 to review a proposal for guidance that provides an integrated approach to the understanding and application of technologies in these standards in engineering programs for management of the life cycle of pressure equipment, including inspection, fitness for continued service and repair. The transition from new construction to post construction was an essential part of this study, as new construction standards address inspectability and provide a baseline critical to any post-construction assessment. The post construction standards presented and reviewed included:

PCC-1-2000 Guidelines for Pressure Boundary Bolted Flange Joint Assembly

PCC-2-2006 Repair of Pressure Equipment and Piping Standard

PCC-3-2007 Inspection Planning Using Risk-Based Methods

API 579-1/ASME FFS-1 2007 Fitness-For-Service

This Guide is intended to fill that need. It is not intended to be an industry standard, but rather to provide general guidance. Also note that this document is not intended to be a complete listing of all of the publications related to pressure equipment integrity, which would fill many bookshelves, but rather lists the most pertinent references in the opinion of the author and the reviewers.



[This page intentionally left blank]



1. Scope

This guide provides a summary of some of the more commonly used codes, standards, recommended practices (RPs), specifications and guidelines produced by organizations based in the United States that assist manufacturers, owners, users and their designated agents, regulators and other stakeholders in maintaining the integrity of fixed pressure equipment in process plants and in general industrial use. For the convenience of the user of this guide, the term “documents” will be used throughout to refer collectively to “codes, standards, recommended practices, specifications and guidelines.” This guide is not all-inclusive.

There are many documents that are useful for specific applications of pressure equipment that have not been described or included as references in this guide. This does not imply that these documents should not be used or that they have any deficiencies. Note also that engineering knowledge and experience is necessary for the proper application of most of the standards listed.

The following applications for pressure equipment are not specifically included in the scope. However, the owner of these categories of equipment may use those portions of this guide that are applicable:

- (a) Upstream “non-process” equipment in the oil and gas industry (e.g., pressure equipment used in oil and gas exploration and production such as Christmas trees, wellhead equipment, flow lines, subsea equipment)
- (b) Equipment in commercial nuclear power plants
- (c) Domestic plumbing and other domestic pressure equipment such as hot water heaters. Portable air receivers (air tanks) used by homeowners and contractors are excluded from the scope but air receivers in industrial facilities are included
- (d) Liquefied natural gas (LNG) and liquefied petroleum gas (LPG) transport and storage (API and ship classification societies)
- (e) Pipelines
- (f) Pressure equipment used in transport service.

This guide includes only documents that are pertinent to maintaining equipment integrity (e.g., pressure containment) through appropriate design, construction, inspection, maintenance, alteration and repair. Standards related to areas such as identification schemes, plant or pipeline operator qualification, etc. are outside of its scope.

The inclusion of a document in this guide does not imply that the document is endorsed by ASME. This listing is provided only for the convenience of manufacturers, users and their designated agents, regulators and other stakeholders to help identify documents that are potentially applicable.