

ASME PTC 19.3 TW-2016
(Revision of ASME PTC 19.3 TW-2010)

Thermowells

Performance Test Codes

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME PTC 19.3 TW-2016
(Revision of ASME PTC 19.3 TW-2010)

Thermowells

Performance Test Codes

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: February 26, 2016

This Code will be revised when the Society approves the issuance of a new edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations are published on the Committee Web page and under go.asme.org/InterpsDatabase. Periodically certain actions of the ASME PTC Committee may be published as Cases. Cases are published on the ASME Web site under the PTC Committee Page at go.asme.org/PTCcommittee as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Page to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The PTC Committee Page can be found at go.asme.org/PTCcommittee. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2016 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	v
Committee Roster	vi
Correspondence With the PTC Committee	vii
Section 1 Object and Scope	1
1-1 Object	1
1-2 Scope	1
Section 2 Nomenclature	2
Section 3 Jurisdiction of Codes	4
3-1 Reference Standards and Governing Codes	4
3-2 Specification of Thermowells	4
Section 4 Dimensions	5
4-1 Configurations	5
4-2 Dimensional Limits	5
Section 5 Materials	10
5-1 General Considerations	10
Section 6 Stress Equations	11
6-1 General Considerations	11
6-2 Corrosion and Erosion	11
6-3 Flow-Induced Thermowell Stresses	12
6-4 Strouhal Number, Drag Coefficients, and Lift Coefficient	14
6-5 Natural Frequency of Thermowells	15
6-6 Mounting Compliance Factor	17
6-7 Unsupported Length, Diameter, and Fillet Radius	19
6-8 Frequency Limit	20
6-9 Magnification Factor	23
6-10 Bending Stresses	24
6-11 Pressure and Shear Stresses	28
6-12 Steady-State Static and Dynamic Stress Limits	29
6-13 Pressure Limit	31
Section 7 Overview of Calculations	32
7-1 Quantitative Criteria	32
7-2 Fluid Properties	32
7-3 Fluid Velocity	32
7-4 Material Properties and Dimensions	32
7-5 Reynolds and Strouhal Numbers	33
7-6 Natural Frequency at Operation Temperature	33
7-7 Natural Frequency at Expected Mode of Operation	33
7-8 Steady-State and Dynamic Stresses	33
7-9 Allowable Fatigue Limits	33
7-10 Pressure Rating	33
Section 8 Examples	34
8-1 Tapered, Welded Thermowell for a Steam-Header Application (U.S. Customary Units)	34
8-2 Step-Shank, Threaded Thermowell for a Hot Water Application (SI Units)	39

Section 9	Statement of Compliance	46
9-1	Specification of a Thermowell	46
9-2	Velocity and Pressure Ratings	46
Section 10	References	47
10-1	Referenced Documents	47
10-2	Referenced ASME Documents	47
Figures		
4-1-1	Schematic Diagram of a Thermowell	6
4-1-2	Examples of Straight-Shank Thermowells	7
4-1-3	Examples of Step-Shank Thermowells	8
4-1-4	Examples of Tapered Thermowells	9
6-3.1-1	Fluid-Induced Forces and Assignment of Axes for Calculation of Thermowell Stresses	12
6-6-1	Unsupported Length of Thermowells	12
6-8.1-1	Schematic Indicating Excitation of Resonances When Excitation Frequency Coincides With the Thermowell Natural Frequency	20
6-8.1-2	Schematic Showing the Amplitude Response of a Thermowell Subjected to Fluid-Induced Forces as Solid Lines, for In-Line and Transverse Excitation Modes	21
6-10.1-1	Bending Moment, Stress at the Support Plane, and Location of Maximum Steady-State or Oscillating In-Line Stress	25
6-10.7-1	Mounting of a Thermowell in an Elbow, With the Tip Facing Downstream	27
6-10.7-2	Geometry to Be Used in Calculation of Thermowell Ratings	27
6-10.7-3	Mounting of a Thermowell in an Elbow, With the Tip Facing Upstream	28
Tables		
4-1-1	Dimensional Limits for Straight and Tapered Thermowells Within the Scope of This Standard	7
4-2-1	Dimensional Limits for Step-Shank Thermowells Within the Scope of This Standard	8
6-5.3-1	Parameters for Natural Frequency Calculation for Step-Shank Thermowells	16
6-12.3-1	Allowable Fatigue-Stress Amplitude Limits for Material Class A and Class B	30
Nonmandatory Appendix		
A	Conversion Factors	49

FOREWORD

In 1957, the ASME Performance Test Codes Committee 19.3 determined that the 1930 edition of the *Supplement on Temperature Measurement* dealing with thermowells was unsatisfactory. Since the design of thermowells requires both thermal and stress considerations, the ASME Boiler and Pressure Vessel Committee was approached for assistance. However, the special needs for the design of intrusive pipe fittings were deemed beyond the scope of what could be properly included in the vessel codes.

The PTC 19.3 Committee is charged with temperature measurement and thermowell design. The purpose of the thermowell is to facilitate temperature measurement while resisting fluid forces of the process. This committee undertook the task of providing guidance in this area, on the basis of a paper authored by J. W. Murdock[1], ultimately leading to the publication of PTC 19.3-1974, *Supplement on Instruments and Apparatus, Part 3, Temperature Measurement*. Prior to the acceptance of PTC 19.3-1974, the incidence of thermowell failures during the start-up testing of high-pressure steam turbines was unacceptable; its subsequent use in steam services has been highly successful at preventing catastrophic thermowell failures.

Since its publication, PTC 19.3 has received widespread acceptance and use in both steam and nonsteam applications outside the scope of the performance test codes. In 1971 an ASME ad hoc committee, PB51, under the jurisdiction of the PTC Board, was formed to assess the thermowell standard. This committee, designated PTC 19.3.1, produced a draft thermowell standard. In 1999, PTC 19.3 undertook the task of completing this draft. In the course of this effort, it was discovered that a number of thermowells designed to PTC 19.3-1974 but placed in nonsteam services suffered catastrophic failure. Review of the literature revealed that the PTC 19.3.1 draft did not incorporate recent, significant advances in our knowledge of thermowell behavior, and in 1998 the committee decided to thoroughly rewrite the standard. The goals of the new Standard were to provide a thermowell rating method that could be used in a myriad array of services, including processes involving corrosive fluids; offer advice where fatigue endurance is critical; and establish criteria for insuring sensor reliability. These factors resulted in a more reliable basis for thermowell design than the PTC 19.3-1974 Supplement. By 2004, it was decided that users would be better served if the new thermowell strength calculation Standard was separated from the rest of PTC 19.3.

The publication of the 2010 edition was well received by industry and adoption of the Code generated significant feedback. In addition to several Technical Inquiries, a Code Case was approved by the PTC Standards Committee in 2012 to add additional guidance for passing through the in-line resonance condition and adjust the manufacturing tolerances in the tables. Citing the continued industry feedback, the PTC Committee decided to revise the document again to incorporate the Code Case and add clarifications to elbow and angled installations. It is intended that this Edition of the Standard not be retroactive.

This Edition of PTC 19.3 TW was approved as an American National Standard by the ANSI Board of Standards Review on January 5, 2016.

ASME PTC COMMITTEE

Performance Test Codes

(The following is the roster of the Committee at the time of approval of this Code.)

STANDARDS COMMITTEE OFFICERS

P. G. Albert, *Chair*
J. W. Milton, *Vice Chair*
F. Constantino, *Secretary*

STANDARDS COMMITTEE PERSONNEL

P. G. Albert, Consultant
R. P. Allen, Consultant
J. M. Burns, Burns Engineering
A. E. Butler, ST Global & CC Americas
W. C. Campbell, True North Consulting, LLC
F. Constantino, The American Society of Mechanical Engineers
J. W. Cuchens, Southern Company Services
M. J. Dooley, Alstom Power
G. J. Gerber, Retired
P. M. Gerhart, University of Evansville
J. Gonzalez, Iberdrola Ingeniería Y Construcción, SAU
R. E. Henry, Sargent & Lundy
D. R. Keyser, Survice Engineering
T. K. Kirkpatrick, McHale & Associates, Inc.

S. J. Korellis, Electric Power Research Institute
M. McHale, McHale & Associates, Inc.
J. W. Milton, Chevron, USA
S. P. Nuspl, Consultant
R. Pearce, Kansas City Power & Light
R. R. Priestley, Consultant
S. A. Scavuzzo, The Babcock & Wilcox Co.
T. C. Heil, *Alternate*, The Babcock & Wilcox Co.
J. A. Silvaggio, Jr., Babcock Demag Delaval Turbomachinery, Inc.
T. L. Toburen, Consultant
G. E. Weber, OIsoft
W. C. Wood, Duke Energy
R. Jorgenson, *Honorary Member*, Consultant
P. M. McHale, *Honorary Member*, McHale & Associates, Inc.
R. E. Sommerlad, *Honorary Member*, Consultant

PTC 19.3 COMMITTEE — TEMPERATURE MEASUREMENT

D. Bauschke, *Chair*, Emerson Process Management
A. L. Guzman, *Secretary*, The American Society of Mechanical Engineers
R. P. Allen, Consultant
C. W. Brook, Wika Instruments Ltd.
M. Carugati, Alloy Engineering Co., Inc.
S. E. Dahler, General Electric Co.
A. G. Gilson, Black & Veatch

M. P. Johnson, JMS Southeast, Inc.
E. P. Sawyer, Pyromation, Inc.
R. Steelhammer, Jr., Sandelius Instruments
G. F. Strouse, National Institute of Standards & Technology
T. L. Toburen, T2E3
R. Tramel, Tennessee Valley Authority
F. L. Johnson, *Alternate*, JMS Southeast, Inc.
M. A. Thaxton, *Alternate*, Pyromation, Inc.

CORRESPONDENCE WITH THE PTC COMMITTEE

General. ASME Codes are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Code may interact with the Committee by requesting interpretations, proposing revisions or a Case, and attending Committee meetings. Correspondence should be addressed to

Secretary, PTC Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Code to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Code. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Code. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Code and the paragraph, figure or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Code to which the proposed Case applies.

Interpretations. Upon request, the PTC Standards Committee will render an interpretation of any requirement of the Code. Interpretations can only be rendered in response to a written request sent to the Secretary of the PTC Standards Committee at go.asme.org/Inquiry.

The request for an interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format:

Subject: Cite the applicable paragraph number(s) and the topic of the inquiry.
Edition: Cite the applicable edition of the Code for which the interpretation is being requested.
Question: Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Attending Committee Meetings. The PTC Standards Committee and PTC Committees regularly hold meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the PTC Standards Committee. Future Committee meeting dates and locations can be found on the Committee Page at go.asme.org/PTCcommittee.

Currently in preview, click buy full version

INTENTIONALLY LEFT BLANK

THERMOWELLS

Section 1 Object and Scope

1-1 OBJECT

The object of this Standard is to establish a mechanical design standard for reliable service of tapered, straight, and stepped-shank thermowells in a broad range of applications. This includes an evaluation of the forces caused by external pressure, and the combination of static and dynamic forces resulting from fluid impingement.

1-2 SCOPE

This Standard applies to thermowells machined from bar stock and includes those welded to or threaded into a flange as well as those welded into a process vessel or pipe with or without a weld adaptor. Thermowells manufactured from pipe are outside the scope of this Standard.

Thermowells with specially designed surface structures (e.g., a beveled surface or a surface with spiral ridges) are beyond the scope of this Standard, due to the difficulty of providing design rules with broad applicability for these types of thermowells.

Thermowell attachment methods, standard dimensions, parasitic vibration of a sensor mounted inside the thermowell, and thermal equilibrium of the sensor relative to the process stream are beyond the scope of this Standard. In addition, thermowells fabricated by welding, including flame spray or weld overlays, at any place along the length of the shank or at the tip are outside the scope of this Standard.

The application of the overlay to a bar-stock thermowell may affect any number of critical attributes such as natural frequency, damping, material properties, or surface finish. These changes are difficult to account for in the calculations, therefore, there is risk that an otherwise properly designed thermowell could be installed.