

**ASME PTC 4-2013**  
(Revision of ASME PTC 4-2008)

# Fired Steam Generators

**Performance Test Codes**

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**



Currently in preview, click buy full version

INTENTIONALLY LEFT BLANK



**ASME PTC 4-2013**  
(Revision of ASME PTC 4-2008)

# Fired Steam Generators

---

**Performance Test Codes**

AN AMERICAN NATIONAL STANDARD



**The American Society of  
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA



Date of Issuance: February 7, 2014

This Code will be revised when the Society approves the issuance of a new edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations are published on the Committee Web page and under [go.asme.org/InterpsDatabase](http://go.asme.org/InterpsDatabase). Periodically certain actions of the ASME PTC Committee may be published as Code Cases. Code Cases are published on the ASME Web site under the PTC Committee Page at [go.asme.org/PTCcommittee](http://go.asme.org/PTCcommittee) as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The PTC Committee Page can be found at [go.asme.org/PTCcommittee](http://go.asme.org/PTCcommittee). There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures recognized as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposal for a code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,  
in an electronic retrieval system or otherwise,  
without the prior written permission of the publisher.

The American Society of Mechanical Engineers  
Two Park Avenue, New York, NY 10016-5990

Copyright © 2014 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All rights reserved  
Printed in U.S.A.



# CONTENTS

Notice .....	vi
Foreword .....	vii
Committee Roster .....	ix
Correspondence With the PTC Committee .....	
<b>Section 1 Object and Scope .....</b>	<b>1</b>
1-1 Object .....	1
1-2 Scope .....	1
1-3 Typical Uncertainty for Efficiency .....	2
1-4 Steam Generator Boundaries .....	3
<b>Section 2 Definitions and Description of Terms .....</b>	<b>12</b>
2-1 Definitions .....	12
2-2 Abbreviations .....	15
2-3 Units and Conversions .....	15
<b>Section 3 Guiding Principles .....</b>	<b>17</b>
3-1 Introduction .....	17
3-2 Performance Test Procedures .....	20
3-3 References to Other Codes and Standards .....	27
3-4 Tolerances and Test Uncertainties .....	28
<b>Section 4 Instruments and Methods of Measurement .....</b>	<b>29</b>
4-1 Guiding Principles .....	29
4-2 Data Required .....	29
4-3 General Measurement Requirements .....	32
4-4 Temperature Measurement .....	49
4-5 Pressure Measurement .....	53
4-6 Velocity Traverse .....	54
4-7 Flow Measurement .....	54
4-8 Solid Fuel and Sorbent Sampling .....	57
4-9 Liquid and Gaseous Fuel Sampling .....	62
4-10 Sampling of Flue Gas .....	62
4-11 Residue Sampling .....	63
4-12 Fuel, Sorbent, and Residue Analysis .....	64
4-13 Flue Gas Analysis .....	64
4-14 Electric Power .....	65
4-15 Humidity .....	66
4-16 Measurements for Surface Radiation and Convection Loss .....	66
<b>Section 5 Computation of Results .....</b>	<b>68</b>
5-1 Introduction .....	68
5-2 Measurement Data Reduction .....	68
5-3 Capacity .....	71
5-4 Output ( $Q_{rO}$ ), Btu/hr ( $W$ ) .....	71
5-5 Input .....	72
5-6 Energy Balance .....	72
5-7 Efficiency .....	73
5-8 Fuel Properties .....	74
5-9 Sorbent and Other Additive Properties .....	76
5-10 Residue Properties .....	78
5-11 Combustion Air Properties .....	80
5-12 Flue Gas Products .....	84



5-13	Air and Flue Gas Temperature .....	86
5-14	Losses .....	88
5-15	Credits .....	95
5-16	Uncertainty .....	96
5-17	Other Operating Parameters .....	99
5-18	Corrections to Standard or Design Conditions .....	100
5-19	Enthalpy of Air, Flue Gas, and Other Substances Commonly Required for Energy Balance Calculations .....	111
5-20	Calculation Acronyms .....	122
<b>Section 6</b>	<b>Report of Test Results .....</b>	<b>122</b>
6-1	Introduction .....	132
6-2	Report Contents .....	132
<b>Section 7</b>	<b>Uncertainty Analysis .....</b>	<b>134</b>
7-1	Introduction .....	134
7-2	Fundamental Concepts .....	134
7-3	Pretest Uncertainty Analysis and Test Planning .....	140
7-4	Equations and Procedures for Determining the Standard Deviation for the Estimate of Random Error .....	141
7-5	Equations and Guidance for Determining Systematic Uncertainty .....	145
7-6	Uncertainty of Test Results .....	150
<b>Figures</b>		
1-4-1	Typical Oil- and Gas-Fired Steam Generator .....	5
1-4-2	Typical Pulverized-Coal-Fired Steam Generator, Alternative 1: Single Air Heater .....	6
1-4-3	Typical Pulverized-Coal-Fired Steam Generator, Alternative 2: Bifactor Air Heater .....	7
1-4-4	Typical Pulverized-Coal-Fired Steam Generator, Alternative 3: Trifactor Air Heater .....	8
1-4-5	Typical Circulation Bed Steam Generator .....	9
1-4-6	Typical Stoker-Coal-Fired Steam Generator .....	10
1-4-7	Typical Bubbling Bed Steam Generator .....	11
3-1.1-1	Steam Generator Energy Balance .....	18
3-2.2.1-1	Repeatability of Runs .....	21
3-2.6.1-1	Illustration of Short-Term (Peak to Valley) Fluctuation and Deviation From Long-Term (Run) Average .....	25
4-4.3.1-1	Sampling Grids: Rectangular Ducts .....	51
4-4.3.1-2	Sampling Grids: Circular Ducts .....	52
4-8.2.1-1	Full Stream Cut Solid Sampling Process .....	58
4-8.2.1-2	Typical "Thief" Probe for Solid Sampling in a Solids Stream .....	59
5-19.12-1	Mean Specific Heat of Dry Air Versus Temperature .....	117
5-19.12-2	Mean Specific Heat of Water Vapor Versus Temperature .....	118
5-19.12-3	Mean Specific Heat of Dry Flue Gas Versus Temperature .....	120
5-19.12-4	Mean Specific Heat of Dry Residue Versus Temperature .....	121
7-2.2-1	Types of Errors in Measurements .....	136
7-2.2-2	Time Dependence of Errors .....	136
7-2.3-1	Constant Value and Continuous Variable Models .....	138
7-5.2.1-1	Generic Calibration Curve .....	147
<b>Tables</b>		
1-3-1	Typical Code Test Uncertainties for Efficiency .....	3
2-3-1	Units and Conversions .....	16
3-1.3-1	Comparison of Efficiency Determination .....	20
3-2.3-1	Operating Parameter Deviations .....	23
3-2.3-2-1	Minimum Test-Run Duration .....	26
4-2-1(a)	Parameters Required for Efficiency Determination by Energy Balance Method: Energy Losses .....	30
4-2-1(b)	Parameters Required for Efficiency Determination by Energy Balance Method: Energy Credits .....	33
4-2-2	Parameters Required for Efficiency Determination by Input-Output Method .....	34
4-2-3	Parameters Required for Capacity Determination .....	35
4-2-4	Parameters Required for Steam Temperature/Control Range Determination .....	36



4-2-5	Parameters Required for Exit Flue Gas and Air Entering Temperature Determinations .....	37
4-2-6	Parameters Required for Excess Air Determination .....	38
4-2-7	Parameters Required for Water/Steam Pressure Drop Determinations .....	39
4-2-8	Parameters Required for Air/Flue Gas Pressure Drop Determinations .....	40
4-2-9	Parameters Required for Air Infiltration Determination .....	41
4-2-10	Parameters Required for Sulfur Capture/Retention Determination .....	42
4-2-11	Parameters Required for Calcium-to-Sulfur Molar Ratio Determination .....	42
4-2-12	Parameters Required for Fuel, Air, and Flue Gas Flow Rate Determinations .....	43
4-3.6-1	Potential Instrumentation Systematic Uncertainty .....	45
4-3.6-2	Potential Systematic Uncertainty for Coal Properties .....	47
4-3.6-3	Potential Systematic Uncertainty for Limestone Properties .....	47
4-3.6-4	Potential Systematic Uncertainty for Fuel Oil Properties .....	48
4-3.6-5	Potential Systematic Uncertainty for Natural Gas Properties .....	48
4-8.4.2-1	<i>F</i> Distribution .....	61
5-16.5-1	Two-Tailed Student's <i>t</i> Table for the 95% Confidence Level .....	99
5-20.2-1	Acronyms .....	124
5-20.2-2	Measurement and Uncertainty Acronyms .....	131
<b>Nonmandatory Appendices</b>		
A	Calculation Forms .....	151
B	Sample Calculations .....	185
C	Derivations .....	254
D	Gross Efficiency: Energy Balance and Input–Output Method; LHV Efficiency: Energy Balance Method .....	258
E	The Probable Effects of Coal and Sorbent Properties .....	261
F	References .....	272



## NOTICE

All Performance Test Codes must adhere to the requirements of ASME PTC 1, General Instructions. The following information is based on that document and is included here for emphasis and for the convenience of the user of the Code. It is expected that the Code user is fully cognizant of Sections 1 and 3 of ASME PTC 1 and has read them prior to applying this Code.

ASME Performance Test Codes provide test procedures that yield results of the highest level of accuracy consistent with the best engineering knowledge and practice currently available. They were developed by balanced committees representing all concerned interests and specify procedures, instrumentation, equipment-operating requirements, calculation methods, and uncertainty analysis.

When tests are run in accordance with a Code, the test results themselves, without adjustment for uncertainty, yield the best available indication of the actual performance of the tested equipment. ASME Performance Test Codes do not specify means to compare those results to contractual guarantees. Therefore, it is recommended that the parties to a commercial test agree before starting the test and preferably before signing the contract on the method to be used for comparing the test results to the contractual guarantees. It is beyond the scope of any Code to determine or interpret how such comparisons shall be made.



# FOREWORD

The Test Code for Stationary Steam Generating Units was one of the group of 10 forming the 1915 Edition of the ASME Power Test codes. A revision of these codes was begun in 1918, and the Test Code for Stationary Steam Generating Units was reissued in revised form in October 1926. Further revisions were issued in February 1930 and January 1936.

In October 1936 the standing Power Test Code Committee requested Committee No. 4 to consider a revision of the Code to provide for heat balance tests on large steam generating units. In rewriting the Code, advantage was taken of the experience of the several companies in the utility field that had developed test methods for large modern units including the necessary auxiliary equipment directly involved in the operation of the units. At the same time the needs of the small installations were not overlooked. At the November 3, 1945, meeting of the standing Power Test Codes Committee, this revision was approved. On May 23, 1946, the Code was approved and adopted by the Council.

In view of the continuously increasing size and complexity of steam generating units, it was obvious that changes were required in the 1946 Edition of the Test Code. In May 1958 the technical committee was reorganized to prepare this revision. The completely revised Code, the Test Code for Steam Generating Units, was approved by the Power Test Codes Committee on March 20, 1964. It was further approved and adopted by the Council as a standard practice of the Society by action of the Board on Codes and Standards on June 24, 1964.

The Board on Performance Test Codes (BPTC) in 1980 directed that the Code be reviewed to determine whether it should be revised to reflect current engineering practices. A committee was soon formed and it had its first meeting in May 1981. The Committee soon recognized that the Code should be totally rewritten to reflect several changes in steam generator technology (primarily the increasing usage of fluidized bed combustors and other technologies for emission control) and in performance testing technology (primarily the widespread use of electronic instrumentation and the consideration of test uncertainty analysis as a tool for designing and measuring the quality of a performance test).

The Committee decided that the new code should discourage the use of an abbreviated test procedure (commonly known as "The Short Form" from PTC 4.1). The PTC 4 Code superseded PTC 4.1, which is no longer an American National Standard or ASME Code. (Technical Inquiry #04-05 describes the differences between the PTC 4 and the invalid PTC 4.1.) The Committee reasoned that the best test is that which requires the parties to the test to deliberate on the scope of the performance test required to meet the objective(s) of the test. Measurement uncertainty analysis was selected as the tool whereby the parties could design a test to meet these objectives. (See para. 3-2.1.) As this Code will be applied to a wide configuration of steam generators, from small industrial and commercial units to large utility units, the soundness of this philosophy should be self-evident.

This expanded edition of the Code was reissued as Fired Steam Generators to emphasize its limitation to steam generators fired by combustible fuels. The Code was subjected to a thorough review by Industry, including members of the BPTC. Many of their comments were incorporated and the Committee finally approved the Code on June 23, 1998. It was then approved and adopted by the Council as a Standard practice of the Society by action of the Board on Performance Test Codes on August 2, 1998. It was also approved as an American National Standard by the ANSI Board of Standards Review on November 2, 1998.

Calculations associated with the application of this Code can be facilitated by the use of computer software. Software programs that support calculations for this Code may become available at a future date on the ASME Web site. Any such software that may be furnished would not have been subject to the ASME consensus process and ASME would make no warranties, expressed or implied, including, without limitation, the accuracy or applicability of the program.

A revision to the Code was published in 2008. The main purpose of this revision was to include a general update of the Code to bring it into compliance with the definitions and terminology used in the revised PTC 19.1, Test Uncertainty. The major issue in this regard was to change all references to "bias" and "precision" to "systematic" and "random," respectively. Also, "precision index" was changed to "standard deviation." In conformance with PTC 19.1, a value of 2 was stipulated for the "Student's *t*" parameter, which simplifies the uncertainty calculations. This revision also included the addition of subsection 4-16 and para. 5-18.14. Subsection 4-16 provides procedures for the measurement of surface radiation and convection loss. Paragraph 5-18.14 contains procedures for calculating the uncertainty of corrected results. Also, the procedures for determining the average value of spatially nonuniform parameters were simplified. In addition to these changes, the 2008 revision included corrections of minor errors and omissions, an update of references, and text revisions for better clarity.

The 2008 revision was approved by the PTC Standards Committee on October 16, 2007, and approved and adopted as a Standard practice of the Society by action of the Board on Standardization and Testing on February 19, 2008. It was also approved as an American National Standard by the ANSI Board of Standards Review on October 14, 2008.

Work on the current edition began in 2009. The main purpose of this edition is to include revisions occasioned by Technical Inquiry 09-01, Code Case P-2, and the errata posted on February 8, 2012. As a result of

Technical Inquiry 09-01, changes to the text of para. 5-19.5, "Enthalpy of Steam/Water at 1 psia Btu/lbm," and Nonmandatory Appendix D, subsection D-4, "Efficiency on a Lower Heating Value, *LHV*, Basis," were made for improved clarity. Code Case P-2, concerning a mass balance/efficiency error on units utilizing sorbent, resulted in revisions to text, equations, and acronyms in Section 5 and changes to calculation forms in Nonmandatory Appendix A. The errata required changes in subsections A-3, A-4, and A-5 of Nonmandatory Appendix A and subsections D-3, D-4, and D-5 of Nonmandatory Appendix D. In addition to these changes, all the Code Sections were reviewed to correct minor errors and omissions, to update references, and to revise text for better clarity.

The following is a summary of major changes to each Section:

**In Section 1**, references to codes and standards were updated. Figures 1-4-2 through 1-4-5 were revised. These revisions and corrections included adding missing flow streams, revising text for improved clarity, and correcting spelling.

**In Section 3**, references to codes and standards were updated. Figure 3-1.1-1 (formerly designated as Fig. 3-1-1) was edited to correct the equation for  $\text{NO}_x$  formation loss.

**In Section 4**, Table 4-2-1 was split into two tables, one for energy losses [Table 4-2-1(a)] and one for energy credits [Table 4-2-1(b)]. Tables 4-3.6-1 and 4-3.6-4 (formerly designated as Tables 4-3-1 and 4-3-4, respectively) were edited to correct errors, and references to codes and standards were updated.

**In Section 5**, revisions occasioned by Technical Inquiry 09-01 and Code Case P-2 were made to text, equations, and acronyms. Changes required by the errata posted on February 8, 2012, were made. Other changes and corrections were made to formulas and acronyms. Also, text was revised to improve clarity, and references were corrected and updated.

**In Nonmandatory Appendix A**, many of the forms were revised in accordance with Code Case P-2 and the errata posted on February 8, 2012. Minor changes were made to the text and forms to improve clarity.

**In Nonmandatory Appendix B**, many of the forms were revised in accordance with Code Case P-2 and the errata posted on February 8, 2012. Paragraph B-5.1, including text and tables, was added to provide a sample steam generator efficiency calculation for a circulating fluidized bed (CFB) steam generator. Minor changes were made to the text and tables to improve clarity.

**In Nonmandatory Appendix D**, the text and equations in subsection D-4 concerning *LHV* were revised for clarity.

The PTC 4 Committee approved the Code on May 31, 2013. It was also approved by the PTC Standards Committee on May 31, 2013, and approved and adopted as a Standard practice of the Society by action of the Board on Standardization and Testing on October 21, 2013. Finally, it was also approved as an American National Standard by the ANSI Board of Standards Review on November 21, 2013.



# ASME PTC COMMITTEE Performance Test Codes

(The following is the roster of the Committee at the time of approval of this Code.)

## STANDARDS COMMITTEE OFFICERS

P. G. Albert, *Chair*  
J. W. Milton, *Vice Chair*  
J. H. Karian, *Secretary*

## STANDARDS COMMITTEE PERSONNEL

P. G. Albert, General Electric Co.

R. P. Allen, Consultant

J. M. Burns, Burns Engineering

W. C. Campbell, Southern Company Services

M. J. Dooley, Alstom Power, Inc.

G. J. Gerber, Consultant

P. M. Gerhart, University of Evansville

R. E. Henry, Sargent & Lundy

J. H. Karian, The American Society of Mechanical Engineers

D. R. Keyser, Survice Engineering

T. K. Kirkpatrick, McHale & Associates, Inc.

S. J. Korellis, Electric Power Research Institute

M. P. McHale, McHale & Associates, Inc.

J. W. Milton, Genon Energy

S. P. Nuspl, Consultant

R. R. Priestley, Consultant

S. A. Scavuzzo, The Babcock & Wilcox Co.

T. C. Heil, *Alternate*, Retired, The Babcock & Wilcox Co.

J. A. Silvaggio, Jr., Siemens Demag Delaval Turbomachinery, Inc.

W. G. Steele, Jr., Mississippi State University

T. L. Toburen, T2E3, Inc.

G. E. Weber, Midwest Generation EME, LLC

W. C. Wood, Duke Energy Corp.

## PTC 4 COMMITTEE — FIRED STEAM GENERATORS

P. M. Gerhart, *Chair*, University of Evansville

T. C. Heil, *Vice Chair*, Retired, The Babcock & Wilcox Co.

J. H. Karian, *Secretary*, The American Society of  
Mechanical Engineers

J. Briggs, Florida Power and Light

M. Dittus, Black & Veatch

M. J. Dooley, Alstom Power, Inc.

B. Fisher, Consultant

S. Ma, Bechtel Corp.

S. A. Scavuzzo, The Babcock & Wilcox Co.

A. W. Sutherland, Cummins & Barnard, Inc.

B. P. Vitalis, Riley Power, Inc.

J. J. Youmans, Youmans Consulting LLC



# CORRESPONDENCE WITH THE PTC COMMITTEE

**General.** ASME Codes are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Code may interact with the Committee by requesting interpretations, proposing revisions, and attending Committee meetings. Correspondence should be addressed to:

Secretary, PTC Standards Committee  
The American Society of Mechanical Engineers  
Two Park Avenue  
New York, NY 10016-5990

**Proposing Revisions.** Revisions are made periodically to the Code to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Code. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Code. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal including any pertinent documentation.

**Proposing a Code Case.** Code Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Code Cases are effective immediately upon ASME approval and shall be posted on the ASME PTC Committee Web page.

Requests for Code Cases shall provide a Statement of Need and Background Information. The request should identify the Code, the paragraph, figure or table number(s), and be written as a Question and a Reply in the same format as existing Code Cases. Requests for Code Cases should also indicate the applicable Code edition(s) to which the proposed Code Case applies.

**Interpretations.** Upon request, the PTC Standards Committee will render an interpretation of any requirement of the Code. Interpretations can only be rendered in response to a written request sent to the Secretary of the PTC Standards Committee at [go.asme.org/Inquiry](http://go.asme.org/Inquiry).

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his request in the following format:

Subject: Cite the applicable paragraph number(s) and a concise description.  
Edition: Cite the applicable edition of the Code for which the interpretation is being requested.  
Question: Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format will be rewritten in this format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

**Attending Committee Meetings.** The PTC Standards Committee holds meetings or telephone conferences, which are open to the public. Persons wishing to attend any meeting or telephone conference should contact the Secretary of the PTC Standards Committee. Future Committee meeting dates and locations can be found on the Committee Page at [go.asme.org/PTCcommittee](http://go.asme.org/PTCcommittee).



# FIRED STEAM GENERATORS

## Section 1 Object and Scope

### 1-1 OBJECT

The object of this Code is to establish procedures for conducting performance tests of fuel-fired steam generators. This Code provides standard test procedures that can yield results giving the highest level of accuracy consistent with current engineering knowledge and practice.

The accuracy of a particular test may be affected by the fuel fired during the test or other factors within the discretion of the operator. A test is considered an ASME Code test only if the following conditions are met:

- (a) Test procedures comply with procedures and allowed variations defined by this Code.
- (b) Uncertainties of test results, determined in accordance with Section 7 of this Code, do not exceed target test uncertainties defined by prior written agreement in accordance with Section 3 of this Code.

#### 1-1.1 Determination of Performance Characteristics

This Code can be used to determine the following performance characteristics:

- (a) efficiency
- (b) output
- (c) capacity
- (d) steam temperature/control range
- (e) exit flue gas and entering air temperature
- (f) excess air
- (g) water/steam pressure drop
- (h) air/flue gas pressure drop
- (i) air infiltration
- (j) sulfur capture/retention
- (k) calcium-to-sulfur molar ratio
- (l) fuel, air, and flue gas flow rates
- (m) unburned carbon and unburned carbon loss

It is not necessary that all of these parameters be determined simultaneously for each and every test.

#### 1-1.2 Purpose of Performance Characteristics

These performance characteristics are typically required for the following purposes:

- (a) comparing actual performance to guaranteed performance

- (b) comparing actual performance to a reference
- (c) comparing different conditions or methods of operation
- (d) determining the specific performance of individual parts or components
- (e) comparing performance when firing an alternate fuel
- (f) determining the effects of equipment modifications

This Code also provides methods for converting certain performance characteristics at test conditions to those that would exist under specified operating conditions.

### 1-2 SCOPE

#### 1-2.1 General Scope

The rules and instructions presented in this Code apply to fired steam generators. These include coal-, oil-, and gas-fired steam generators as well as steam generators fired by other hydrocarbon fuels. The scope also includes steam generators with integral fuel-sulfur capture utilizing chemical sorbents.

Steam generators that are not fired by coal, oil, or gas may be tested using the concepts of this Code, but it should be noted that the uncertainty caused by variability of the fuel may be difficult to determine and is likely to be greater than the uncertainties in sampling and analysis of coal, oil, or gas.

Gas turbine heat recovery and other heat recovery steam generators designed to operate with supplemental firing should be tested in accordance with ASME Performance Test Code (PTC) 4.4, Gas Turbine Heat Recovery Steam Generators.

This Code does not apply to nuclear steam supply systems, which are specifically addressed in ASME PTC 32.1, Nuclear Steam Supply Systems. This Code does not apply to the performance testing of chemical heat recovery steam generators, municipal-waste-fired steam generators, pressurized steam generators with gas side pressure greater than 5 atm, or incinerators. Municipal-waste-fired steam generators can be tested in accordance with ASME PTC 34, Waste Combustors With Energy Recovery.