

ASME PTC 51-2011

Gas Turbine Inlet Air-Conditioning Equipment

Performance Test Codes

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Copyright © 2012 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



INTENTIONALLY LEFT BLANK



ASME PTC 51-2011

Gas Turbine Inlet Air-Conditioning Equipment

Performance Test Codes

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Three Park Avenue • New York, NY • 10016 USA

Copyright © 2012 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



Date of Issuance: February 29, 2012

This Code will be revised when the Society approves the issuance of a new edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this document. Periodically certain actions of the ASME PTC Committee may be published as Code Cases. Code Cases and interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2012 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

Copyright © 2012 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



CONTENTS

Notice	vi
Foreword	vii
Acknowledgments	viii
Committee Roster	ix
Correspondence With the PTC Committee	x
Section 1 Object and Scope	1
1-1 Object	1
1-2 Scope	1
1-3 Uncertainty	1
1-4 Other Requirements and References	2
Section 2 Definitions and Description of Terms	3
2-1 Symbols	3
2-2 Definitions	5
Section 3 Guiding Principles	11
3-1 Preparations for Testing	11
3-2 Tests	13
3-3 Operation of Test	13
3-4 Records	16
3-5 Calculation and Reporting of Results	16
Section 4 Instruments and Methods of Measurement	18
4-1 General Requirements	18
4-2 Pressure Measurement	22
4-3 Temperature Measurement	26
4-4 Humidity Measurement	32
4-5 Liquid and Steam Flow Measurement	35
4-6 Air-Flow Measurement	41
4-7 High-Voltage Electrical Measurement	51
4-8 Intermediate- and Low-Voltage Electrical Measurement	55
4-9 Droplet Carryover and Droplet Size	56
4-10 Data Collection and Handling	59
Section 5 Computation of Results	62
5-1 General Calculation Methodology	62
5-2 Common Parameters and Variables	62
5-3 General Correction Methodology	68
5-4 Inlet Cooling Using Evaporative Media	69
5-5 Inlet Cooling Using Fogging	70
5-6 Inlet Cooling Using Chillers (Multiple Arrangements)	74
5-7 Inlet Heating Using Closed-Loop Systems (Coils)	86
5-8 Inlet Heating Using Open-Loop Heating Systems (Compressor Bleed)	88
Section 6 Report of Results	90
6-1 General Requirements	90
6-2 Executive Summary	90
6-3 Introduction	90
6-4 Calculations and Results	90
6-5 Instrumentation and Measurements	90
6-6 Conclusion	91
6-7 Appendices	91



Section 7	Test Uncertainty	92
7-1	Introduction	92
7-2	Inputs for an Uncertainty Analysis	92
7-3	Error Sources	92
7-4	Calculation of Uncertainty	92
7-5	Correlated and Noncorrelated Approaches to Uncertainty Measurement	93
7-6	Measurements	93
7-7	Estimated Uncertainties	93
7-8	Posttest Uncertainty Analysis	93
7-9	Repeatability	93
7-10	Spatial Systematic Uncertainty	93
Section 8	References	95
8-1	References	95
8-2	Additional Referenced ASME Documents	95
Figures		
3-1.2-1	Sample Test Boundary	12
3-3.7-1	Three Posttest Cases	15
4-2.6.2-1	Five-Way Manifold	26
4-2.6.2-2	Water Leg Correction for Flow Measurement	26
4-3.3.2.1-1	Four-Wire Resistance Temperature Detector (RTD)	29
4-3.3.2.2-1	Three-Wire Resistance Temperature Detector (RTD)	29
4-3.6.2-1	Flow-Through Well	31
4-6.3.1-1	Five-Hole Probe	44
4-6.3.1-2	Three-Hole Probe	45
4-6.3.3-1	Directional Thermal Anemometer: Triaxial Probe (Three-Wire)	46
4-6.4-1	Free-Stream Flow Nozzle Jet	47
4-6.4-2	ASME Flow Chamber	47
4-6.4-3	Wind Tunnel	49
4-6.4.1-1	Typical Calibration Curve for a Five-Hole Probe	50
5-2-1	Generic Test Boundary Diagram	63
5-4.1-1	Evaporative Cooler Test Boundary Diagram	70
5-5.1-1	Inlet Fogger Test Boundary Diagram	71
5-5.2.2-1	Sample Fogging System Design Curve for System Cooling Capability vs. Potential Cooling Level	72
5-5.2.4-1	Sample Fogging System Design Curve for Water Flow vs. Expected Inlet Air Cooling	73
5-6.2.1-1	Inlet Chiller Test Boundary Diagram: Coils Only	76
5-6.3.1-1	Inlet Chiller Test Boundary Diagram: Coils and Primary Cooling Loop	78
5-6.4.1-1	Inlet Chiller Test Boundary Diagram: Coils, Primary Cooling Loop, and Chiller Loop	81
5-6.5.1-1	Inlet Chiller Test Boundary Diagram: Entire Chiller System	84
5-7.1-1	Inlet Heater Test Boundary Diagram	86
5-8.1-1	Compressor Air Heater Test Boundary Diagram	88
7-10-1	Outlet Air Temperature Distribution at the Outlet of an Evaporative Condenser	94
Tables		
1-3-1	Representative Test Uncertainties	2
2-1-1	Symbols	3
2-1-2	Subscripts	5
3-3-1	Maximum Permissible Deviation From Base Reference Conditions and Minimum and Maximum Requirements	13
3-3.3-1	Maximum Permissible Variation in Test-Run Conditions	15
4-5.3.1-1	Units and the Conversion Factor for Mass Flow Through a Differential Pressure Class Meter	37
4-5.3.1-2	Summary Uncertainty of Discharge Coefficient and Expansion Factor	38



4-6.3-1	Air-Velocity Measurement Devices.....	43
4-8.4-1	Electrical Horsepower.....	56
4-8.4-2	Properties of Conductors.....	57
4-8.4-3	Multiplying Factors for Converting DC Resistance to 60-Hz AC Resistance.....	58
7-10-1	Spatial Systematic Uncertainty Calculation (Step-by-Step)	94
Nonmandatory Appendices		
A	Method of Testing Atomizing Nozzles.....	97
B	Sample Uncertainty Analyses.....	110

Currently in preview, click buy full version

NOTICE

All Performance Test Codes must adhere to the requirements of ASME PTC 1, General Instructions. The following information is based on that document and is included here for emphasis and for the convenience of the user of the Code. It is expected that the Code user is fully cognizant of Sections 1 and 3 of ASME PTC 1 and has read them prior to applying this Code.

ASME Performance Test Codes provide test procedures that yield results of the highest level of accuracy consistent with the best engineering knowledge and practice currently available. They were developed by balanced committees representing all concerned interests and specify procedures, instrumentation, equipment-operating requirements, calculation methods, and uncertainty analysis.

When tests are run in accordance with a Code, the test results themselves, without adjustment for uncertainty, yield the best available indication of the actual performance of the tested equipment. ASME Performance Test Codes do not specify means to compare those results to contractual guarantees. Therefore, it is recommended that the parties to a commercial test agree before starting the test and preferably before signing the contract on the method to be used for comparing the test results to the contractual guarantees. It is beyond the scope of any Code to determine or interpret how such comparisons shall be made.



FOREWORD

ASME Performance Test Codes (PTCs) have long existed for determining the performance of gas turbine units and for gas-turbine-based overall plant performance in electric power production facilities. These codes have advised the user to conduct testing of gas turbines and gas-turbine-based plants with inlet conditioning out of service and to correct the results of the test with results of a subsequent test of the inlet conditioning system. Yet users of the test codes were without a test code to provide guidance of the performance of such a test since a Performance Test Code has heretofore not existed to determine the performance of gas turbine inlet air-conditioning equipment. With the growing use of gas turbine inlet air-conditioning equipment in the electric power generation industry, the need for a code addressing gas turbine inlet air-conditioning equipment became very apparent. In response to these needs, the ASME Board on Performance Test Codes approved the formation of a committee (PTC 51) in September 2002 with the charge of developing a code for the determination of inlet air-conditioning equipment performance. The organizational meeting of this Committee was held in March 2003. The resulting Committee included experienced and qualified users, manufacturers, and general interest category personnel from both the regulated and nonregulated electric power generating industry.

In developing the first issue of this Code, the Committee reviewed common industry practice with regard to inlet air-conditioning equipment testing. The Committee was not able to identify any general consensus testing methods, and discovered many conflicting philosophies, approaches, and performance definitions. For some inlet air-conditioning equipment, correction approaches to standard conditions did not exist. The Committee aspired to develop an objective code that addresses the multiple needs for explicit testing methods and procedures, while attempting to provide maximum flexibility in recognition of the wide range of inlet air-conditioning designs and the multiple needs for this Code.

This Code was approved by the PTC 51 Committee on November 17, 2010. It was then approved and adopted by the Performance Test Code Standards Committee on December 9, 2010. It was also approved as an American National Standard by the ANSI Board of Standards Review on March 30, 2011.

ACKNOWLEDGMENTS

The PTC 51 Committee wishes to acknowledge the contribution of the following individuals to the development of Nonmandatory Appendix A: Kevin Kosiak, Joseph Shakal, Paul Sojka, and especially Robert Burgess, who served as Chair of the developmental group.



ASME PTC COMMITTEE

Performance Test Codes

(The following is the roster of the Committee at the time of approval of this Code.)

STANDARDS COMMITTEE OFFICERS

J. R. Friedman, *Chair*
J. W. Milton, *Vice Chair*
J. H. Karian, *Secretary*

STANDARDS COMMITTEE PERSONNEL

P. G. Albert, General Electric Co.
R. P. Allen, Consultant
J. M. Burns, Burns Engineering, Inc.
W. C. Campbell, Southern Company Services, Inc.
M. J. Dooley, Alstom Power, Inc.
J. R. Friedman, Siemens Energy, Inc.
G. J. Gerber, Consultant
P. M. Gerhart, University of Evansville
T. C. Heil, Consultant
R. E. Henry, Sargent & Lundy, Inc.
J. H. Karian, The American Society of Mechanical Engineers
D. R. Keyser, Survice Engineering
S. J. Korellis, Electric Power Research Institute
M. P. McHale, McHale & Associates, Inc.
P. M. McHale, McHale & Associates, Inc.
J. W. Milton, Genon Energy, Inc.
S. P. Nuspl, Consultant
R. R. Priestley, Consultant

J. A. Silvaggio, Siemens Demag Delaval, Inc.
W. G. Steele, Mississippi State University
T. L. Toburen, T2E3, Inc.
G. E. Weber, Midwest Generation EME LLC
J. C. Westcott, Mustan Corp.
W. C. Wood, Duke Energy, Inc.
T. K. Kirpatrick, *Alternate*, McHale & Associates, Inc.
S. A. Scavuzzo, *Alternate*, Babcock & Wilcox Co.

Honorary Members

R. L. Bannister, Consultant
W. O. Hays, Consultant
R. Jorgensen, Consultant
F. H. Light, Consultant
G. H. Middleton, Jr., Consultant
J. W. Siemens, Consultant
R. Sommerlad, Consultant

PTC 51 COMMITTEE — GAS TURBINE INLET AIR-CONDITIONING EQUIPMENT

T. K. Kirpatrick, *Chair*, McHale & Associates, Inc.
M. P. Giampetro, *Vice Chair*, SAIC Energy, Environment,
and Infrastructure, LLC
G. Osolsobe, *Secretary*, The American Society
of Mechanical Engineers
J. C. Boevink-Walsh, GE Power Systems, Inc.
S. T. Cloyd, Mitsubishi Power Systems America, Inc.
C. R. Cortes, Siemens Power Generation, Inc.
P. T. Graef, Munters Corp.
K. W. Hennon, Clean Air Engineering, Inc.
S. Jolly, Eco Power Solutions, Inc.
D. McDeed, Mitsubishi Power Systems America, Inc.
B. J. Pastorik, McHale & Associates, Inc.
T. B. Sullivan, Siemens Power Generation, Inc.
T. L. Toburen, T2E3, Inc.

Contributing/Corresponding Members

R. P. Allen, Consultant
L. C. Angello, Electric Power Research Institute
D. C. Brenner, Pneumafil Corp.
D. Delesdernier, Bete Fog Nozzle, Inc.
A. Lakshmanarao, General Electric Corp.
P. Levine, Consultant
W. J. McAuliffe, York International, Inc.
S. J. Molis, Cape Engineering Consulting, Inc.
W. M. Newland, McHale & Associates, Inc.
A. Singh, GE Energy, Inc.
J. B. Stuart, Rohm & Haas, Inc.

CORRESPONDENCE WITH THE PTC COMMITTEE

General. ASME Codes are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Code may interact with the Committee by requesting interpretations, proposing revisions, and attending Committee meetings. Correspondence should be addressed to

Secretary, PTC Standards Committee
The American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990

Proposing Revisions. Revisions are made periodically to the Code to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Code. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Code. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Code, the paragraph, figure or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Code to which the proposed Case applies.

Interpretations. Upon request, the PTC Standards Committee will render an interpretation of any requirement of the Code. Interpretations can only be rendered in response to a written request sent to the Secretary of the PTC Standards Committee.

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format:

- Subject:** Cite the applicable paragraph number(s) and the topic of the inquiry.
- Edition:** Cite the applicable edition of the Code for which the interpretation is being requested.
- Question:** Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format will be rewritten in this format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not approve, certify, rate, or endorse any item, construction, proprietary device, or activity.

Attending Committee Meetings. The PTC Standards Committee and PTC Committees hold meetings regularly, which are open to the public. Persons wishing to attend any meeting should contact the Secretary of the PTC Committee.



INTENTIONALLY LEFT BLANK



GAS TURBINE INLET AIR-CONDITIONING EQUIPMENT

Section 1 Object and Scope

1-1 OBJECT

This Code provides procedures for in situ testing of inlet air-conditioning systems (cooling/heating) as they apply to gas turbines in simple, cogeneration, and combined-cycle applications.

The intent of this Code is to provide results with the lowest reasonably achievable uncertainty consistent with the best engineering knowledge and practice in the industry, such that appropriate instrumentation and measurement techniques and procedures be used to determine the following performance variables, as applicable:

- performance factor
- carryover
- auxiliary consumption (power/thermal)
- temperature change
- water discharge
- water consumption
- distribution/stratification
- pressure drop

This Code also provides procedures for the calculation of the results, and for the correction of the results to reference conditions, as a measure of gas turbine inlet air-conditioning systems performance.

1-2 SCOPE

This Code may be used for in situ testing of inlet air-conditioning systems (cooling/heating) as they apply to gas turbines in simple, cogeneration, and combined-cycle applications. Cooling systems covered by this Code include evaporative systems (foggers and media-based evaporative coolers) and mechanical/thermal refrigeration systems. Heating systems covered by this Code include compressor-bleed type systems and heating-coil systems.

This Code is limited to gas turbine inlet air-conditioning systems and does not apply to the following:

- building heating, cooling, or refrigeration systems
- gas turbine compressor intercoolers
- wet compression, overspray, deluge, overfogging, and similar technologies

- other power plant applications such as air-cooled electrical generators
- gas turbine performance

In addition, this Code does not apply to the testing of individual atomizing nozzles. However, the Committee recognizes that carryover is a critical characteristic of fogging systems. As such, there may be situations that require the quantification of water droplet size. To address this need, the Code further provides the procedures for determining water droplet size associated with laboratory bench testing of atomizing nozzles; please see Nonmandatory Appendix A.

This Code contains rules and procedures for conducting and reporting tests of gas turbine inlet air-conditioning systems, including requirements for pretest arrangements, testing techniques, instrumentation, methods of measurement, and methods for calculating test results and uncertainty.

1-3 UNCERTAINTY

A pretest uncertainty analysis is required to demonstrate that the proposed instrumentation and measurement techniques meet the requirements of this Code; this analysis shall include an estimate of the random uncertainty based on experience. A posttest uncertainty analysis is required to evaluate overall test uncertainty, including the actual random uncertainty and spatial uncertainties associated with the test result. To accomplish testing with reasonable accuracy, limits for both the test instrument uncertainty and the variation for each required measurement are established in this Code.

Limits on uncertainty and variations for each measurement were set in recognition of the fact that there is a diverse range of inlet air-conditioning system designs covered by this Code. Each unique system has corresponding uncertainty levels that are dependent on the system type, specific design complexity, and consistency of operation during a test and cannot be generally categorized for purposes of establishing uncertainty limits on the test results achievable from testing in accordance with this Code.