

ASME QME-1–2023
(Revision of ASME QME-1–2017)

Qualification of Active Mechanical Equipment Used in Nuclear Facilities

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers

ASME QME-1-2023
(Revision of ASME QME-1-2017)

Qualification of Active Mechanical Equipment Used in Nuclear Facilities

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: February 10, 2023

The next edition of this Standard is scheduled for publication in 2027.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark

“ASME” and the above ASME symbols are registered trademarks of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2023 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved

CONTENTS

Foreword	vi
Committee Roster	vii
Correspondence With the QME Committee	x
Organization of ASME QME-1	xii
Summary of Changes	xiv
Section QR	
QR-1000	1
QR-2000	1
QR-3000	1
QR-4000	3
QR-5000	5
QR-6000	6
QR-7000	6
QR-8000	8
Mandatory Appendix QR-I	
QR-I-1000	10
Nonmandatory Appendix QR-A	
QR-A-1000	12
QR-A-2000	12
QR-A-3000	12
QR-A-4000	12
QR-A-5000	14
QR-A-6000	16
QR-A-7000	19
QR-A-8000	28
Nonmandatory Appendix QR-B	
QR-B-1000	31
QR-B-2000	31
QR-B-3000	31
QR-B-4000	31
QR-B-5000	31
QR-B-6000	33
QR-B-7000	36
Nonmandatory Appendix QR-C	
Sample Certifying Engineer Certification Statements	37
Section QDR	
QDR-1000	41
QDR-2000	41
QDR-3000	41

QDR-4000	Qualification Principles and Philosophy	42
QDR-5000	Qualification Specification	44
QDR-6000	Qualification Program	44
QDR-7000	Documentation Requirements	49
Mandatory Appendix QDR-I	Qualification Specification for Dynamic Restraints	52
QDR-I-1000	Scope	52
QDR-I-2000	Purpose	52
QDR-I-3000	References	52
QDR-I-4000	Definitions	52
QDR-I-5000	Qualification Specification Contents	52
QDR-I-6000	Filing Requirements	54
Nonmandatory Appendix QDR-A	Restraint Similarity	55
QDR-A-1000	Scope	55
QDR-A-2000	Examples of Design Similarity	55
Nonmandatory Appendix QDR-B	Typical Values of Restraint Functional Parameters	57
QDR-B-1000	Scope	57
QDR-B-2000	Functional Parameters	57
QDR-B-3000	Aging and Service Condition Simulation Qualification Program	58
Section QP	Qualification of Active Pump Assemblies	59
QP-1000	Scope	59
QP-2000	Purpose	59
QP-3000	References	59
QP-4000	Definitions	59
QP-5000	Qualification Principles and Philosophy	60
QP-6000	Qualification Specification	60
QP-7000	Qualification Program	60
QP-8000	Documentation	65
Mandatory Appendix QP-I	Qualification Specification for Active Pump Assemblies	67
QP-I-1000	Scope	67
QP-I-2000	Purpose	67
QP-I-3000	References	67
QP-I-4000	Definitions	67
QP-I-5000	Qualification Specification Contents	67
Nonmandatory Appendix QP-D	Pump Similarity Checklist	72
QP-D-1000	Scope	72
QP-D-2000	Pump Design	72
QP-D-3000	Process Design	72
Nonmandatory Appendix QP-E	Guidelines for Shaft-Seal System Material and Design Consideration	73
QP-E-1000	Scope	73
QP-E-2000	Purpose	73
QP-E-3000	Definition	73
QP-E-4000	Material Considerations	73
QP-E-5000	Design Considerations	73

Section QV	Qualification Requirements for Active Valve Assemblies for Nuclear Facilities	76
QV-1000	Scope	76
QV-2000	Purpose	76
QV-3000	References	76
QV-4000	Definitions	76
QV-5000	Qualification Principles and Philosophy	77
QV-6000	Qualification Specification	77
QV-7000	Qualification Program	77
QV-8000	Documentation Requirements	89
Mandatory Appendix QV-I	Qualification Specification for Active Valves	91
QV-I-1000	Scope	91
QV-I-2000	Purpose	91
QV-I-3000	References	91
QV-I-4000	Definitions	91
QV-I-5000	Qualification Specification Contents	91
QV-I-6000	Actuator Requirements	92
QV-I-7000	Self-Operated Check Valve Characteristics	92
QV-I-8000	Pressure Relief Valve Characteristics	93
QV-I-9000	Special Material Requirements	93
QV-I-10000	Installation Requirements	93
QV-I-11000	Maintenance Requirements	93
QV-I-12000	Qualification Requirements	93
QV-I-13000	Inservice Testing	93
QV-I-14000	Filing Requirements	93
Nonmandatory Appendix QV-B	Static Side Load Testing for Power-Actuated and Relief Valve Assemblies	94
QV-B-1000	Scope	94
QV-B-2000	Purpose	94
QV-B-3000	Definitions	94
QV-B-4000	General Requirements	94
QV-B-5000	Test Method	95
QV-B-6000	Evaluation of Results	96
QV-B-7000	Extrapolation of Results for Power-Operated Valves	97
Section QVG	Guide to Section QV: Determination of Valve Assembly Performance Characteristics	98
QVG-1000	Scope	98
QVG-2000	Introduction	98
QVG-3000	References	98
QVG-4000	Definitions	98
QVG-5000	Valve Assembly Performance Characteristic Requirements	98
QVG-6000	General Considerations	99
QVG-7000	Power-Actuated Valve Assembly Considerations	101
QVG-8000	Valve Considerations	102

Tables

QR-3100-1	Reference Standards	2
QR-A-6210-1	Damping Values: Percent of Critical Damping	16
QR-A-7422-1	Reduction Factors	25
QP-E-4200-1	Shaft-Seal System Specification	74
QP-E-5300-1	Limits for Unbalanced Seals	75
QV-7300-1	Valve Assembly Qualification Requirement Matrix	79

Forms

QR-C-1	Sample Qualification Specification (QP, QV) Certification Statement	38
QR-C-2	Sample Qualification Specification (QDR) Certification Statement	38
QR-C-3	Sample Qualification Report (QP, QV) Certification Statement	39
QR-C-4	Sample Qualification Report (QDR) Certification Statement	39
QR-C-5	Sample Application Report (QP, QV) Certification Statement	40
QR-C-6	Sample Application Report (QDR) Certification Statement	40

Currently in preview, click buy full version

FOREWORD

Federal regulations applicable to nuclear power plants require that measures be established to ensure that certain equipment operates as specified. This Standard sets forth requirements and guidelines that may be used to ensure that active mechanical equipment is qualified for specified service conditions. As determined by federal regulators and, or nuclear power plant licensees, this Standard may be applied to future nuclear power plants or existing operating nuclear power plant component replacements, modifications, or additions.

In the early 1970s, initial development of qualification standards was assigned to the N45 Committee of the American National Standards Institute (ANSI). The N45 Committee in turn established a task force to prepare two series of standards to ensure that pumps and valves used in nuclear plant systems would function as specified. The N45 Committee's valve task force (N278) was reassigned in 1974 to the American National Standards Committee B16 and designated Subcommittee H. The first qualification standard to be issued for valves was ANSI N278.1-1975, which covered the preparation of functional specifications. In 1982, the task force was reassigned to The American Society of Mechanical Engineers (ASME) Committee on Qualification of Mechanical Equipment Used in Nuclear Power Plants (QME) and designated the Subcommittee on Qualification of Valve Assemblies. As an interim measure, in 1983, ANSI B16.41 was issued to cover functional qualification requirements for power-operated active valve assemblies for nuclear power plants.

The N45 Committee's pump task force (N551), established in 1973, was assigned to ASME Nuclear Power Codes and Standards along with N278 as part of the Subcommittee QNPE, Qualification of Nuclear Plant Equipment. Both N551 and N278 operated as Subcommittee QNPE until 1982, when they were reassigned to the QME Committee and designated as, respectively, the Subcommittee on Qualification of Pump Assemblies and the Subcommittee on Qualification of Valve Assemblies. In June 1977, an agreement between the Institute of Electrical and Electronics Engineers (IEEE) and ASME was formulated, giving primary responsibility for qualification standards to IEEE and for quality assurance standards to ASME. This arrangement remained in effect until ASME established the Committee on Qualification of Mechanical Equipment Used in Nuclear Power Plants, now known as the Committee on Qualification of Mechanical Equipment Used in Nuclear Facilities.

The various parts of ASME QME-1-1994 were approved by ANSI on the following dates: [Section QP](#), September 22, 1992; [Section QR](#), June 8, 1993; [Section QR](#), Nonmandatory Appendix A, October 7, 1993; [Section QR](#), Nonmandatory Appendix B, May 14, 1993; and [Section QV](#) and [Section QV](#), Nonmandatory Appendix A, February 17, 1994. [Section QV](#) was a revision and redesignation of ANSI B16.41-1975.

ASME QME-1-2002 was published in 2003. In September 2003, it was recognized that the Standard had aspects, such as the process for valve qualification, that could better use new computer analytical techniques and that were proscriptive in nature. In addition, seismic qualification needed to be updated to recognize new industry guidance. New sections were needed on standardization of experience-based seismic equipment qualification and the qualification of dynamic restraints. At the time, industry experience had demonstrated that qualification to ASME QME-1 was required without the specification of the parameters for which equipment needed to be qualified. The use of this Standard requires that a Qualification Specification be provided.

ASME QME-1-2007 was endorsed by the Nuclear Regulatory Commission (NRC) and was the first edition of ASME QME-1 to be so endorsed. It was approved as an American National Standard on June 25, 2007.

The 2012 edition of this Standard was approved as an American National Standard on September 17, 2012.

The 2017 edition of this Standard was approved as an American National Standard on March 21, 2017.

Following approval by the ASME QME Committee, ASME QME-1-2023 was approved by ANSI as an American National Standard on January 13, 2023.

COMMITTEE ON QUALIFICATION OF MECHANICAL EQUIPMENT USED IN NUCLEAR FACILITIES

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

S. Norman, *Chair*
S. M. Jones, *Vice Chair*
R. Rahaman, *Secretary*
D. Wiener, *Secretary*

STANDARDS COMMITTEE PERSONNEL

T. Apelian, Curtiss-Wright
R. W. Barnes, Anric Enterprises, Inc.
A. Cardillo, Nuscale Power, LLC
D. P. Crane, Westinghouse Electric Co.
J. R. Holstrom, Val-Matic Valve and Manufacturing Corp.
S. M. Jones, Fisher Controls
I. T. Kisel, Retired
H. S. Koski, Jr., Altran Solutions
A. M. Kouvolov, Consultant
J. P. Lambin, Crane Nuclear
K. A. Manoly, U.S. Nuclear Regulatory Commission
S. Norman, Enercon Services, Inc.
M. A. Pressburger, Sargent & Lundy, LLC
R. Rahaman, The American Society of Mechanical Engineers
T. P. Ruggiero, Consultant
M. S. Shutt, Duke Energy Co.
W. Velkoff, Curtiss-Wright, Target Rock
D. Wiener, The American Society of Mechanical Engineers
R. D. Yeardley, National Technical Systems — Huntsville Operations
K. DeWall, *Contributing Member*, Adjunct Faculty at Idaho State University
H. Meares, *Contributing Member*, DHS/ST/CSAC
N. Paterson, *Contributing Member*, Rolls-Royce
D. Jagannathan, *Contributing Member*, Neles India Private, Ltd.
H. R. Sonderegger, *Contributing Member*, Fluoroseal Valves USA
D. C. Stanze, *Contributing Member*, Fisher Controls
T. Adams, *Honorary Member*, Jensen Hughes

SUBCOMMITTEE ON QUALIFICATION OF VALVE ASSEMBLIES

S. M. Jones, *Chair*, Fisher Controls
R. Rahaman, *Secretary*, The American Society of Mechanical Engineers
A. Cardillo, Nuscale Power, LLC
D. P. Crane, Westinghouse Electric Co.
S. G. Harris, Nuscale Power, LLC
J. R. Holstrom, Val-Matic Valve and Manufacturing Corp.
I. T. Kisel, Retired
A. M. Kouvolov, Consultant
J. P. Lambin, Crane Nuclear
M. Laney, Flowserve
W. K. Roit, General Electric Hitachi Nuclear Energy
T. P. Ruggiero, Consultant
T. G. Scarbrough, U.S. Nuclear Regulatory Commission
H. R. Sonderegger, Fluoroseal Valves USA
P. W. Turrentine, National Technical Systems — Huntsville Operations Nuclear Engineering and Test Services
W. Velkoff, Curtiss-Wright, Target Rock
R. Viswanathan, Bray Controls India Private, Ltd.
R. D. Yeardley, National Technical Systems — Huntsville Operations
K. DeWall, *Contributing Member*, Adjunct Faculty at Idaho State University
D. C. Stanze, *Contributing Member*, Fisher Controls

SUBCOMMITTEE ON QUALIFICATION OF ACTIVE DYNAMIC RESTRAINTS

S. Norman, *Chair*, Enercon Services, Inc.

T. Canter, *Vice Chair*, Duke Energy

N. B. Frank, *Secretary*, American Electric Power

R. Rahaman, *Secretary*, The American Society of American Engineers

G. Bedi, U.S. Nuclear Regulatory Commission

D. C. Boes, Consultant

O. Cable, Basic-PSA, Inc.

D. Dutrow, LISEGA, Inc.

H. S. Koski, Jr., Altran Solutions

M. Palmer, Anvil EPS

L. A. Phares, National Technical Systems — Huntsville Operations
Nuclear Engineering and Test Services

M. A. Pressburger, Sargent & Lundy, LLC

D. K. Shetler, Bechtel

M. S. Shutt, Duke Energy Corp.

R. L. Portmann, Jr., *Contributing Member*, Duke Energy Corp.

V. H. Salcedo, *Contributing Member*, GERB Vibration Control, Inc.

SUBCOMMITTEE ON QUALIFICATION OF PUMP ASSEMBLIES

D. P. Crane, Westinghouse Electric Co.

A. M. Kouvolos, Consultant

CORRESPONDENCE WITH THE QME COMMITTEE

General. ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Standard should be sent to the staff secretary noted on the committee's web page, accessible at <https://go.asme.org/QMEcommittee>.

Revisions and Errata. The committee processes revisions to this Standard on a continuous basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published in the next edition of the Standard.

In addition, the committee may post errata on the committee web page. Errata become effective on the date posted. Users can register on the committee web page to receive e-mail notifications of posted errata.

This Standard is always open for comment, and the committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

Cases

(a) The most common applications for cases are

(1) to permit early implementation of a revision based on an urgent need

(2) to provide alternative requirements

(3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Standard

(4) to permit the use of a new material or process

(b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Standard.

(c) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:

(1) a statement of need and background information

(2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)

(3) the Standard and the paragraph, figure, or table number(s)

(4) the edition(s) of the Standard to which the proposed case applies

(d) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Approved cases are posted on the committee web page.

Interpretations. Upon request, the committee will issue an interpretation of any requirement of this Standard. An interpretation can be issued only in response to a request submitted through the online Interpretation Submittal Form at <https://go.asme.org/InterpretationRequest>. Upon submitting the form, the inquirer will receive an automatic e-mail confirming receipt.

ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the information submitted, it is the opinion of the committee that the inquirer should seek assistance, the request will be returned with the recommendation that such assistance be obtained. Inquirers can track the status of their requests at <https://go.asme.org/Interpretations>.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Interpretations are published in the ASME Interpretations Database at <https://go.asme.org/Interpretations> as they are issued.

Committee Meetings. The QME Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the committee. Information on future committee meetings can be found on the committee web page at <https://go.asme.org/QMEcommittee>.

ORGANIZATION OF ASME QME-1

1 GENERAL

ASME QME-1 is divided into sections that are designated by capital letters: the letter “Q,” which stands for *qualification*, followed by one or more letters that generally indicate the subject matter of the section. This Standard consists of four major sections as follows:

- (a) **Section QR:** Qualification Requirements
- (b) **Section QDR:** Qualification of Dynamic Restraints
- (c) **Section QP:** Qualification of Active Pump Assemblies
- (d) **Section QV:** Qualification Requirements for Active Valve Assemblies for Nuclear Facilities

2 SECTIONS

Sections are divided into articles, subarticles, subsubarticles, paragraphs, and, where necessary, subparagraphs and subsubparagraphs.

3 ARTICLES

Articles are designated by the applicable letters indicated above for the sections, followed by Arabic numbers in units of 1,000, such as **QR-1000**, **QP-2000**, or **QV-6000**. Whenever possible, articles dealing with the same topic are given the same number in each section in accordance with the general scheme that follows:

Article Number	Title
1000	Scope
2000	Purpose
3000	References
4000	Definitions
5000	Qualification Principles and Philosophy
6000	Qualification Specification Criteria
7000	Qualification Program
8000	Documentation

The numbering of the articles and the material contained in the articles may not, however, be consecutive. Due to the fact that the complete outline may cover phases not applicable to a particular section or article, the rules have been prepared to allow gaps in the numbering.

4 SUBARTICLES

Subarticles are numbered in units of 100, such as **QR-7100** or **QV-7200**. When more than nine subarticles are required, numbering is done by paragraph and units of 1 starting with 10.

5 SUBSUBARTICLES

Subsubarticles are numbered in units of 10, such as QR-8310 or QR-8320.

6 PARAGRAPHS

Paragraphs are numbered in units of 1, such as QR-8321 or QV-8322.

7 SUBPARAGRAPHS

Subparagraphs, when they are major subdivisions of a paragraph, are designated by adding a decimal followed by one or more digits to the paragraph number, such as QR-8321.1 or QV-8321.2. When they are minor subdivisions of a paragraph, subparagraphs may be designated by lowercase letters in parentheses, such as QR-8321(a) or QV-8321(b).

8 SUBSUBPARAGRAPHS

Subsubparagraphs are designated by adding lowercase letters in parentheses to the major subparagraph numbers, such as QR-8321.1(a) or QV-8321.1(b). When further subdivisions of minor subparagraphs are necessary, subsubsubparagraphs are designated by adding Arabic numbers in parentheses to the subsubparagraph designation, such as QR-8321.1(a)(1) or QV-8321.1(a)(2).

9 REFERENCES

(23)

References used within this Standard generally fall into one of the following three categories:

(a) *References to Other Portions of This Standard.* When a reference is made to another article, subarticle, or paragraph, all numbers subsidiary to that reference shall be included. For example, reference to **QR-5000** includes all material in **article QR-5000**; reference to **QR-7300** includes all material in **subarticle QR-7300**; reference to **QR-7320** includes all material in **subsubarticle QR-7320**.

(b) *References to the Boiler and Pressure Vessel Code (ASME BPVC) and to Other Standards.* When a reference is made to any section of the BPVC, or to other standards, it

shall be understood to mean the designated article, paragraph, figure, or table in the designated document. All such references shall be identified in the text of this Standard by the document's issuing source and the document's unique identification number, e.g., ASME BPVC, Section III, Subsection NF; IEEE Std 627; or 10CFR50 Part A. If required, further reference to unique articles or paragraphs of the referenced document may also be described, e.g., ASME BPVC, Section III, Subsection NF, subpara. NF-3211.1(a). Each short reference made in the text shall be described in more complete detail in Article 3000 by issuing source, unique identification number, year of publication being referenced, and full title, e.g., IEEE Std 382-1980, Standard for Qualification of Safety Related Valve Operators. It should be noted by users of this Standard that regulatory requirements and

Codes of Record for a particular nuclear power plant may take precedence over references used within this Standard. [Article QR-3000](#) lists the references applicable for all sections.

(c) References to Appendices. Two types of appendix are included in this Standard, designated Mandatory and Nonmandatory. Both types of appendix are designated by the prefix Q. This is followed by letter(s), which are the same used by the section to which the appendix applies, e.g., QR. Mandatory appendices contain requirements that must be followed in qualification; such references are uniquely identified by a roman numeral, e.g., [Mandatory Appendix QR-I](#), and its specific title. Nonmandatory appendices provide information or guidance; such references are designated by a capital letter, e.g., [Nonmandatory Appendix QR-A](#), and its specific title.

ASME QME-1-2023

SUMMARY OF CHANGES

Following approval by the ASME QME Committee and ASME, and after public review, ASME QME-1–2023 was approved by the American National Standards Institute on January 13, 2023.

Throughout this Standard, the phrase “Registered Professional Engineer” has been changed to “Certifying Engineer.” In addition, ASME QME-1–2023 includes the following changes identified by a margin note, **(23)**.

<i>Page</i>	<i>Location</i>	<i>Change</i>
xii	Organization of ASME QME-1	Paragraph 9(b) revised
1	QR-3000	Updated in its entirety
3	QR-4000	Definition of <i>significant aging mechanism</i> added
5	QR-5310	Revised
8	QR-8000	In QR-8200, QR-8300, QR-8400, and QR-8500, lists reformatted
10	QR-I-1120	Revised in its entirety
11	QR-I-1300	Added
12	QR-A-3000	Revised
15	QR-A-5610	Reference in last sentence updated
15	QR-A-5620	Reference in last sentence updated
21	QR-A-7210	Revised
26	QR-A-7500	Added
30	QR-A-8340	Added, and subsequent paragraph redesignated
30	QR-A-8350	Formerly QR-A-8340, first sentence revised
31	QR-B-3000	Revised
41	QDR-3000	(1) Definition of <i>activation</i> revised (2) Definitions of <i>fatigue failure</i> and <i>fatigue life</i> added
42	QDR-4110	Revised
43	QDR-4210	Revised
43	QDR-4310	Revised
43	QDR-4410	Revised
45	QDR-6223.1	Subparagraphs (a), (b), and (g) revised
46	QDR-6223.2	Subparagraphs (a), (b), (f), and (g) revised
46	QDR-6223.3	Subparagraphs (b) and (c) revised
47	QDR-6223.4	(1) Subparagraph (b) revised (2) Subparagraphs (d) through (f) added
47	QDR-6223.4.2	Subparagraph (a) revised
47	QDR-6224	Revised
47	QDR-6226	First paragraph revised
52	QDR-I-5300	Revised
53	QDR-I-5320	Subparagraph (f) added, and the subsequent subparagraph redesignated

<i>Page</i>	<i>Location</i>	<i>Change</i>
53	QDR-I-5400	(1) Subparagraphs (a)(2) and (b)(2) revised (2) Subparagraph (c)(5) added and subsequent subparagraph redesignated
55	Nonmandatory Appendix QDR-A	Revised
57	Nonmandatory Appendix QDR-B	Revised
59	QP-3000	Revised
65	QP-8310	In subpara. (c), cross-reference updated
65	QP-8320	In subpara. (e), cross-reference updated
79	Table QV-7300-1	Note (6) revised
85	QV-7561	Last sentence added
87	QV-7660	Last sentence added
91	QV-I-2000	Last sentence added
98	QVG-3000	Revised
100	QVG-6500	Example (3) added
105	QVG-8400	Added
107	QVG-8500	Added

INTENTIONALLY LEFT BLANK

Section QR

General Requirements

QR-1000 SCOPE

This Standard provides the requirements and guidelines for the qualification of active mechanical equipment whose function is required to ensure the safe operation or safe shutdown of a nuclear facility. In addition to requirements and guidelines put forth in this Standard, the active mechanical equipment shall comply with the requirements of the applicable design and construction codes and standards.

This Standard does not apply to electric components such as motors, electric valve actuators, instrumentation, and controls, which are qualified by conformance with appropriate IEEE standards.

QR-2000 PURPOSE

The purpose of this Standard is to provide the requirements and recommended practices to qualify active mechanical equipment to meet specified functional requirements during operation and during or after any postulated abnormal or accident conditions.

(23) QR-3000 REFERENCES

This article lists reference documents from which guidance, concepts, principles, practices, criteria, and parameters have been carried forward into this Standard.

[QR-3100](#) provides the industry standards and applicable editions referenced in ASME QME-1 and [QR-3200](#) provides general reference documents used in ASME QME-1.

QR-3100 Qualification Requirement

[Table QR-3100-1](#) lists the current industry standards referenced by ASME QME-1 and earlier editions considered acceptable for use with ASME QME-1. It is the responsibility of the user to select an edition of an industry standard that has been accepted by the Regulatory Authority having jurisdiction over the Nuclear Facility to which the ASME QME-1 standard is to be applied.

QR-3200 General Reference Documents

Listed below are general reference documents discussed and used in the development of this Standard.

QR-3210 Applicable in Mandatory Appendix QR-I

Asia-Pacific Economic Cooperation (APEC) agreement (www.apec.org)
 Fédération Européenne d'Associations Nationales d'Ingénieurs (European Federation of National Engineering Associations) (FEANI) (www.feani.org)
 International Professional Engineers Agreement (IPEA), formerly known as the Engineering Mobility Forum (www.ieagreements.org/agreements/ipea)
 The Washington Accord (www.ieagreements.org/accords/washington)

QR-3220 Applicable in Nonmandatory Appendix QR-A

Advanced Light Water Reactor (ALWR) First-of-a-Kind Engineering (FOAKE) Project on Equipment Seismic Qualification, Advanced Reactor Corporation (ARC), April 1995
 Publisher: U.S. Nuclear Regulatory Commission (NRC), One White Flint North, 11555 Rockville Pike, Rockville, MD 20852-2738 (www.nrc.gov)
 EPRI NP-5228-V1R1, Addendum to Seismic Verification of Nuclear Plant Equipment Anchorage: Volume 1: Development of Anchorage Guidelines, Revision 1, June 30, 1994
 Publisher: Electric Power Research Institute (EPRI), 3420 Hillview Avenue, Palo Alto, CA 94304 (www.epri.com)
 NRC Regulatory Guide (RG) 1.60, Design Response Spectra for Seismic Design of Nuclear Power Plants, Revision 2, dated July 2014
 NRC RG 1.61, Damping Values for Seismic Design of Nuclear Power Plants, Revision 1, dated March 2007
 NRC Supplemental Safety Evaluation Reports on the GIP, Revision 2, Corrected 2/14/92 (SSER No. 2), the GIP, Revision 3, Updated 5/16/97 (SSER No. 3), and the GIP, Revision 3A, dated December 2001
 NRC NUREG-0800, Standard Review Plan, Section 3.7.2, Seismic Systems Analysis, Revision 4, September 2013
 NRC NUREG-0800, Standard Review Plan, Section 3.7.3, Seismic Subsystem Analysis, Revision 4, September 2013