

ASME VVUQ 30.1-2024

Scaling Methodologies for Nuclear Power Systems Responses

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers

ASME VVUQ 30.1-2024

Scaling Methodologies for Nuclear Power Systems Responses

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: June 28, 2024

This Standard will be revised when the Society approves the issuance of a new edition.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark

All rights reserved. “ASME” and the above ASME symbol are registered trademarks of The American Society of Mechanical Engineers. No part of this document may be copied, modified, distributed, published, displayed, or otherwise reproduced in any form or by any means, electronic, digital, or mechanical, now known or hereafter invented, without the express written permission of ASME. No works derived from this document or any content therein may be created without the express written permission of ASME. Using this document or any content therein to train, create, or improve any artificial intelligence and/or machine learning platform, system, application, model, or algorithm is strictly prohibited.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2024 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS

CONTENTS

Foreword	v
Committee Roster	vi
Correspondence With the VVUQ Committee	vii
1 Purpose, Scope, Introduction, and Nomenclature	1
2 Creation of the Adequacy Matrix and Validation Matrix Using Scaled Experimental Facilities	7
3 Scaling History and Types	8
4 Overview and Comparison of H2TS and FSA System Decomposition and Hierarchy	10
5 Concept of Time-Scale Modeling — Dimensionless Groups in Terms of Time Ratios	14
 Mandatory Appendix	
I References	20
 Nonmandatory Appendix	
A Examples of Equations and Dimensionless Groups Used for Scaling Analysis	22
 Figures	
1.3-1 Determination of Model Adequacy	2
2-1 Process for Creating Assessment Basis for Licensing Purposes: Flowchart	8
3.2-1 Comparison of Elongated Representations of Volumes in LOFT and Semiscale Mod-2A Test Facilities	11
4-1 System Decomposition and Hierarchy for Processes Applied in H2TS	12
4-2 Four Stages of H2TS	13
5.2-1 Subvolumes, V_b , and Control Volume, V_c	16
5.3.2-1 Changes of System Matrix for FSA During the Duration of NPP Transient	19
A-1.1-1 Control Volume, Transfer Area, Surface and Volume Effects, and State Variable	23
A-3-1 PWR Vessel Pressure Responses for Various Test Facilities in Dimensional Form	29
A-3-2 PWR Vessel Pressure Responses for Various Test Facilities in Dimensionless Form	29
A-5.2-1 Dimensionless Temperature and Its Relationship to Biot Number and the Decay Fractional Change Metric	36
A-5.2-2 Normalized PCT for $0.015 < \Pi_{Bi} < 0.03$	37
 Tables	
A-1.1-1 Examples of Derivations of H2TS Dimensionless Groups (Time Ratios)	23
A-2-1 State Variables, Agents of Change, FRCs, and Fractional Changes (Effect Metrics)	26
A-3-1 Definition of Dimensionless Agents of Change and Fractional Rates of Change for Pressure Response Equation	28
A-4-1 Definition of Dimensionless Agents of Change and Fractional Rates of Change for Void Fractions Equation	31

A-5.1-1 Definition of Fractional Rates of Change and Fractional Change Metric for Peak Cladding
Temperature Equation

34

Currently in preview, click buy full version

FOREWORD

The ASME Codes and Standards Committee for verification, validation, and uncertainty quantification in computational modeling and simulation (VVUQ Committee) is responsible for coordinating, promoting, and fostering the development of standards that provide procedures for verification, validation, and uncertainty quantification of computational models and simulations. One of the subcommittees of the VVUQ Committee is the VVUQ 30 Subcommittee, which is focused on verification, validation, and uncertainty quantification in computational simulation of nuclear system thermal fluids behavior. The VVUQ 30 Subcommittee's charter is to provide the practices and procedures for verification and validation of software used to calculate nuclear system thermal fluids behavior. While a single model may have many uses, complex systems such as nuclear power plants require a collection of multiple models to be adequately represented. Thus, the focus of the VVUQ 30 Subcommittee is not on a single model, but a specific collection of coupled models (CCM).

Historically, one of the most challenging aspects of determining the credibility of the software has been ensuring that the validation is applicable to the particular scenario in the real-world system. Many features including size, operating conditions, and a heating source from fission often make it infeasible to obtain prototypical experimental data for nuclear system thermal fluid behavior. Due to cost and safety reasons, experimental facilities are usually scaled down from the real-world plant. Thus, performing validation based on such facilities has the additional complexity (and task) of needing to ensure that the results from validation are applicable to the real-world system. ASME VVUQ 1 defines "applicability" as the relevance of the evidence from the verification, validation, and uncertainty quantification activities to support the use of the computational model for a context of use. However, this is a relatively new definition. In the nuclear industry, applicability, specifically as it relates to ensuring the experimental data is relevant with respect to the behavior of the real-world system, has been called scaling analysis. Scaling has been a major focus in the nuclear industry almost since its inception and has major ramifications in determining if the computational models used to simulate nuclear system thermal fluids behavior can be useful or useless. One of the challenges in obtaining appropriate experimental data for nuclear reactor systems is ensuring that the experiment contains the appropriate physical behavior. Such behavior is often directly impacted by pressures and temperatures, heat fluxes, local geometries (e.g., lengths, areas, volumes), and local fluid properties. However, it is impossible to perform an experiment where all factors can be maintained exactly as would be found in a real-world nuclear reactor.

This Standard, in its first edition, is intended to provide practices and procedures for scaling analysis methodologies. Future revisions will be published as necessary.

Following approval by the ASME VVUQ Standards Committee, ASME VVUQ 30.1-2024 was approved by the American National Standards Institute on June 17, 2024.

* In many other engineering communities, "software" is often used to refer to generic packages, such as commercial off-the-shelf programs, and a specific collection of coupled models used to simulate a specific system would still be considered a model. However, the term "software" is used here to mean the specific collection of couple models (CCM) in order to distinguish between the entire collection of models and a specific model (SM), providing a solution based on geometric configurations and initial and boundary conditions.

ASME VVUQ COMMITTEE

Verification, Validation, and Uncertainty Quantification in Computational Modeling and Simulation

(The following is the roster of the committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

D. M. Moorcroft, *Chair*
J. S. Kaizer, *Vice Chair*
M. Pagano, *Secretary*

STANDARDS COMMITTEE PERSONNEL

G. Banyay, Pennsylvania State University
M. D. Benedict, U.S. Air Force Research Laboratory
J. Bischoff, Consultant
D. Cheng, Fluor Corp.
D. Datye, SIMULIA
K. Dowding, Sandia National Laboratories
L. Eca, Instituto Superior Técnico
C. J. Freitas, Southwest Research Institute, Inc.
Y. Hassan, Texas A&M University
M. Horner, ANSYS, Inc.
J. S. Kaizer, U.S. Nuclear Regulatory Commission

S. L. Kieweg, Sandia National Laboratories
B. Kolade, Fitla Technology
S. Mahadevan, Vanderbilt University
D. M. Moorcroft, Federal Aviation Administration
M. Pagano, The American Society of Mechanical Engineers
S. Rachuri, CESMU
V. Sharma, Engineering Systems, Inc.
B. H. Thacker, Southwest Research Institute
T. M. Morris, *Contributing Member*, Food and Drug Administration
J. Smith, *Contributing Member*, Consultant

ASME VVUQ 30 SUBCOMMITTEE — VERIFICATION, VALIDATION, AND UNCERTAINTY QUANTIFICATION IN COMPUTATIONAL SIMULATION OF NUCLEAR SYSTEM THERMAL FLUIDS BEHAVIOR

Y. Hassan, *Chair*, Texas A&M University
R. Schultz, *Vice Chair*, Consultant
M. Pagano, *Secretary*, The American Society of Mechanical Engineers
M. B. Dzodzo, Westinghouse Electric Co.
C. J. Freitas, Southwest Research Institute, Inc.
J. S. Kaizer, U.S. Nuclear Regulatory Commission
M. Kimber, Texas A&M University
A. Krueger, Consultant
E. Merzari, Pennsylvania State University
U. Rohatgi, Brookhaven National Laboratory
S. Treasure, Rolls-Royce PLC
A. V. Lozada, Defense Nuclear Facilities Safety Board
J. Adams, *Contributing Member*, Rolls-Royce, PLC
Y. Addad, *Contributing Member*, Khalifa University
A. M. F. Alwafi, *Contributing Member*, KACST
P. Balestrino, *Contributing Member*, Idaho National Laboratory
D. Datye, *Contributing Member*, SIMULIA

F. D'Auria, *Contributing Member*, Universita Degli Studi Di Pisa
M. D. DeHart, *Contributing Member*, Idaho National Laboratory
N. Dinh, *Contributing Member*, North Carolina State University —
Department of Nuclear Engineering
R. B. Jackson, *Contributing Member*, Consultant
L. Lommers, *Contributing Member*, Kairos Power
K. Okamoto, *Contributing Member*, The University of Tokyo —
Department of Nuclear Engineering
S. Pal, *Contributing Member*, Lawrence Livermore National
Laboratory
A. Ruggles, *Contributing Member*, University of Tennessee
F. Sinan Sarikurt, *Contributing Member*, Terra Power
B. Woods, *Contributing Member*, Oregon State University
M. A. Yildiz, *Contributing Member*, X-energy
R. Zanino, *Contributing Member*, Dipartimento Energia, Politecnico Di
Torino
A. Zigh, *Contributing Member*, U.S. Nuclear Regulatory Commission

CORRESPONDENCE WITH THE VVUQ COMMITTEE

General. ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Standard should be sent to the staff secretary noted on the committee's web page, accessible at <https://go.asme.org/VnVcommittee>.

Revisions and Errata. The committee processes revisions to this Standard on a periodic basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published in the next edition of the Standard.

In addition, the committee may post errata on the committee web page. Errata become effective on the date posted. Users can register on the committee web page to receive e-mail notifications of posted errata.

This Standard is always open for comment, and the committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number, the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

Cases

(a) The most common applications for cases are

(1) to permit early implementation of a revision based on an urgent need

(2) to provide alternative requirements

(3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Standard

(4) to permit the use of a new material or process

(b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Standard.

(c) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:

(1) a statement of need and background information

(2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)

(3) the Standard and the paragraph, figure, or table number

(4) the editions of the Standard to which the proposed case applies

(d) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Approved cases are posted on the committee web page.

Interpretations. Upon request, the committee will issue an interpretation of any requirement of this Standard. An interpretation can be issued only in response to a request submitted through the online Inquiry Submittal Form at <https://go.asme.org/InterpretationRequest>. Upon submitting the form, the inquirer will receive an automatic e-mail confirming receipt.

ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the information submitted, it is the opinion of the committee that the inquirer should seek assistance, the request will be returned with the recommendation that such assistance be obtained. Inquirers can track the status of their requests at <https://go.asme.org/Interpretations>.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Interpretations are published in the ASME Interpretations Database at <https://go.asme.org/Interpretations> as they are issued.

Committee Meetings. The VVUQ Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the committee. Information on future committee meetings can be found on the committee web page at <https://go.asme.org/VnVcommittee>.

Currently in preview, click buy full version

SCALING METHODOLOGIES FOR NUCLEAR POWER SYSTEMS RESPONSES

1 PURPOSE, SCOPE, INTRODUCTION, AND NOMENCLATURE

1.1 Purpose

When determining the credibility of a model, a key question is what the accuracy of the computational model is for the real-world conditions where the system will operate. This accuracy is called predictive capability and is often based on the model validation. To estimate the model's predictive capability, first the error of the model needs to be determined under conditions where empirical data is available. This is referred to as the validation error. Often, based on the similarity of the test facilities and real-world systems, the validation error is used as an estimate of the model's error when making predictions on the real-world system. Thus, a key assumption is that the model's predictive capability of the real-world system is similar to the model's accuracy in predicting the empirical (experimental) data. If both systems have similar physical behavior, it is expected that the model's accuracy will be similar in both systems (the real-world system and the experiment).

There can be many reasons why the model's validation error may be very different from the model's predictive capability. While experimentalists strive to ensure that the experiment is similar to the real-world system, some sacrifices often need to be made. For example, due to the large size and inherent complexity, experimental facilities used to provide data to validate models for nuclear power plant scenarios often must be scaled down from the true nuclear power plant dimensions and operational conditions (such as pressure, temperature, and flow rates). This may include operating the experiment at lower powers and pressures, at a reduced size, or using other fluid. While these changes may not directly impact the model validation (since validation is based on the comparison of the empirical data to the model's predictions), these changes certainly impact the applicability of the model for the real-world system. For example, if a specific system was influenced by behavior that was sensitive to a characteristic length (e.g., hydraulic diameter), area (e.g., flow area), and volume, the scaled system (e.g., experiment) could not be scaled in all three values at once. Consider liquid flow through a tube. If the diameter is reduced by a factor of 2, the flow cross-section area and volume must be reduced by a factor of 4 while the wall heat transfer area is still decreased (as diameter) by a factor of 2. Thus, a phenomenon such as boiling, in which all of these geometry factors could be important, requires a method to determine if the scaled system can provide useful data, or if the scaled system is not similar to the particular scenario in the real-world system. In nuclear thermal fluid systems, the relevance of the empirical (experimental) data to the real-world system is determined through scaling analysis. Scaling is not focused on how well the computational model predicts the empirical data (i.e., validation). Instead, scaling is focused on if a model validated with the empirical data will be relevant to the real-world system. In other words, scaling formalizes the connection between the test facility and real-world system.

This Standard provides practices and procedures for determining if experimental data (used to validate models) is applicable to the real-world system. Historically, such analysis has been unique for nuclear reactor applications where conditions of fluid, both single- and two-phase, are highly size dependent due to surface-to-volume ratio, size-dependent interfacial shape (flow regimes), and interfacial area density. However, it is hoped that the presented scaling analyses methodologies developed for the nuclear community can be used to benefit other fields of engineering and science or combined with other methodologies already developed.

1.2 Scope

This Standard is focused on the scaling analysis that is used to evaluate the effects of differences (e.g., distortions) in the phenomenological behavior of experimental facilities compared to the phenomenological behavior of the real-world system. This includes scaling analysis methodologies for supporting the design of facilities and experiments capable of generating data that characterize the phenomena present in an entire system [such facilities are known as integral effects test (IET) facilities] and in components of the system (e.g., the nuclear core or the steam generator) [such facilities are known as separate effects test (SET) facilities].