

Australian/New Zealand Standard™

Interior and workplace lighting

Part 2.3: Specific applications—  
Educational and training facilities



### **AS/NZS 1680.2.3:2008**

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee LG-001, Interior and Workplace Lighting. It was approved on behalf of the Council of Standards Australia on 26 February 2008 and on behalf of the Council of Standards New Zealand on 11 March 2008. This Standard was published on 6 June 2008.

---

The following are represented on Committee LG-001:

Association of Consulting Engineers Australia  
Australian Chamber of Commerce and Industry  
Australian Electrical and Electronic Manufacturers Association  
Energy Efficiency & Conservation Authority of New Zealand  
Engineers Australia  
IES: The Lighting Society  
Institution of Professional Engineers New Zealand  
Ministry of Economic Development, New Zealand  
NSW Department of Commerce  
Property Council of Australia  
The University of Sydney

Additional Interests:

Photometric Testing Laboratories

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at [www.standards.com.au](http://www.standards.com.au) or Standards New Zealand website at [www.standards.co.nz](http://www.standards.co.nz) and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

---

# Australian/New Zealand Standard

## Interior and workplace lighting

### Part 2.3: Specific applications— Educational and training facilities

Originally as part of AS(E) CA501—1942.  
Previous edition AS 1680.2.3—1994.  
Completely revised and designated AS/NZS 1680.2.3:2008.

#### **COPYRIGHT**

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 8715 0

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee LG-001, Interior and Workplace Lighting to supersede AS 1680.2.3—1994, *Interior lighting—Educational and training facilities*.

The objective of this Standard is to provide those involved with the lighting of educational and training facilities, whether knowledgeable in lighting design or not, with understanding of the various aspects involved in creating strong visual conditions by the choice of lighting appropriate to the task and relevant surface colours and finishes. However precise lighting arrangements are not specific and it is envisaged that creating a design to provide such conditions will typically require the knowledge and expertise of a qualified lighting designer.

This Standard forms Part 2.3 of the AS/NZS 1680 series, which covers lighting of interiors and work places. It is intended to be read in conjunction with the general recommendations and requirements of AS/NZS 1680.1, and the structures of the two Standards are closely aligned to facilitate this. It is also noted that, in many cases, parts of various other Standards in the AS/NZS 1680 series will also be applicable, depending on the nature of the building and the visual tasks involved.

The AS/NZS 1680 series currently consists of the following:

### AS/NZS

|          |                                                                                        |
|----------|----------------------------------------------------------------------------------------|
| 1680     | Interior and workplace lighting                                                        |
| 1680.0   | Part 0: Safe movement                                                                  |
| 1680.1   | Part 1: General principles and recommendations                                         |
| 1680.2.1 | Part 2.1: Specific applications—Circulation spaces and other general areas             |
| 1680.2.2 | Part 2.2: Specific applications—Office and screen-based tasks                          |
| 1680.2.3 | Part 2.3: Specific applications—Educational and training facilities<br>(this Standard) |
| 1680.2.4 | Part 2.4: Industrial tasks and processes                                               |
| 1680.2.5 | Part 2.5: Hospital and medical tasks                                                   |
| 1680.3   | Part 3: Measurement, calculation and presentation of photometric data                  |
| 1680.4   | Part 4: Maintenance of electric lighting systems                                       |

NOTE: Until the revision of this series is complete, some of the above Standards might have, as a main title, 'Interior lighting'.

The significant changes that have been made in this Standard in relation to the previous publication include the following:

- Updating of recommendations in relation to lighting for the vision impaired.
- Upgrading of advice on various types of projection tasks.
- Significant revision of the information provided in relation to theatre and stage lighting.
- Alteration of the recommended maximum glare index from 16 to 19 in all applicable areas (Appendix D).

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

## CONTENTS

|                                                                 | <i>Page</i> |
|-----------------------------------------------------------------|-------------|
| FOREWORD.....                                                   | 5           |
| SECTION 1 SCOPE AND GENERAL                                     |             |
| 1.1 SCOPE .....                                                 | 6           |
| 1.2 APPLICATION .....                                           | 6           |
| 1.3 REFERENCED DOCUMENTS .....                                  | 6           |
| 1.4 DEFINITIONS .....                                           | 6           |
| SECTION 2 GENERAL REQUIREMENTS OF GOOD LIGHTING                 |             |
| 2.1 INTRODUCTION .....                                          | 7           |
| 2.2 GENERAL .....                                               | 7           |
| 2.3 SPECIAL CONSIDERATIONS .....                                | 7           |
| SECTION 3 TASK VISIBILITY                                       |             |
| 3.1 GENERAL .....                                               | 8           |
| 3.2 SPECIAL CONSIDERATIONS FOR VERY YOUNG OBSERVERS.....        | 8           |
| 3.3 DIVERSITY OF TASKS.....                                     | 8           |
| 3.4 NEED FOR FLEXIBILITY.....                                   | 8           |
| 3.5 SPECIAL CONSIDERATIONS FOR THE VISUALLY IMPAIRED .....      | 8           |
| 3.6 SPECIAL CONSIDERATIONS FOR SCREEN BASED TASKS.....          | 9           |
| 3.7 SPECIAL CONSIDERATIONS FOR OVERHEAD PROJECTION TASKS.....   | 9           |
| 3.8 SPECIAL CONSIDERATIONS FOR VIDEO PROJECTION TASKS .....     | 9           |
| 3.9 SPECIAL CONSIDERATIONS FOR VIDEO MONITOR TASKS .....        | 9           |
| 3.10 SPECIAL CONSIDERATIONS FOR SLIDE AND CINE PROJECTION ..... | 9           |
| 3.11 SPECIAL CONSIDERATIONS FOR VERY SMALL TASKS.....           | 10          |
| 3.12 RECOMMENDED ILLUMINANCES .....                             | 10          |
| SECTION 4 DIRECTIONAL EFFECTS OF LIGHTING .....                 |             |
| SECTION 5 UNWANTED REFLECTIONS                                  |             |
| 5.1 GENERAL .....                                               | 11          |
| 5.2 SPECIAL ADVICE ON TASKS .....                               | 11          |
| SECTION 6 SURFACES                                              |             |
| 6.1 GENERAL .....                                               | 12          |
| 6.2 SPECIAL CONSIDERATIONS FOR SCREEN-BASED TASKS.....          | 12          |
| 6.3 SPECIAL CONSIDERATIONS FOR SINGLE-SIDE LIT CLASSROOMS ..... | 12          |
| 6.4 SPECIAL CONSIDERATIONS FOR LECTURE ROOMS .....              | 12          |
| SECTION 7 LIGHT SOURCE COLOUR                                   |             |
| 7.1 GENERAL .....                                               | 13          |
| 7.2 LAMP COLOUR APPEARANCE AND COLOUR RENDERING PROPERTIES ...  | 13          |
| SECTION 8 GLARE AND RELATED EFFECTS                             |             |
| 8.1 GENERAL .....                                               | 13          |
| 8.2 MAXIMUM GLARE INDEX VALUES .....                            | 13          |
| SECTION 9 LIGHT SOURCES, LUMINAIRES AND CONTROL SYSTEMS         |             |
| 9.1 GENERAL .....                                               | 13          |
| 9.2 SELECTION OF LIGHTING EQUIPMENT.....                        | 13          |

## SECTION 10 LIGHTING SYSTEMS

|       |                                                    |    |
|-------|----------------------------------------------------|----|
| 10.1  | GENERAL .....                                      | 14 |
| 10.2  | SPECIAL CONSIDERATIONS FOR SCREEN-BASED TASKS..... | 14 |
| 10.3  | DIVERSITY OF TASKS.....                            | 14 |
| 10.4  | INTEGRATION OF DAYLIGHT AND ELECTRIC LIGHT.....    | 14 |
| 10.5  | GENERAL PURPOSE CLASSROOMS.....                    | 14 |
| 10.6  | ART ROOMS.....                                     | 15 |
| 10.7  | CLASSROOMS FOR THE VISION IMPAIRED.....            | 15 |
| 10.8  | CLASSROOMS FOR THE HEARING IMPAIRED .....          | 15 |
| 10.9  | DRAFTING ROOMS.....                                | 15 |
| 10.10 | LABORATORIES.....                                  | 15 |
| 10.11 | SEWING ROOMS.....                                  | 15 |
| 10.12 | INDUSTRIAL ARTS AND CRAFTS WORKSHOPS .....         | 16 |
| 10.13 | COMPUTER TRAINING ROOMS.....                       | 16 |
| 10.14 | LECTURE THEATRES .....                             | 16 |
| 10.15 | AUDITORIUMS AND GENERAL PURPOSE HALLS .....        | 17 |
| 10.16 | VIDEOCONFERENCING ROOMS.....                       | 19 |
| 10.17 | CORRIDORS AND STAIRS.....                          | 19 |
| 10.18 | FOOD SERVICE FACILITIES .....                      | 19 |
| 10.19 | LIBRARIES AND LEARNING RESOURCE CENTRES.....       | 19 |
| 10.20 | FIRST AID FACILITIES .....                         | 20 |
| 10.21 | OFFICES.....                                       | 20 |
| 10.22 | PHYSICAL EDUCATION SPACES.....                     | 20 |
| 10.23 | SAFETY LIGHTING .....                              | 20 |

|            |                                 |    |
|------------|---------------------------------|----|
| SECTION 11 | LIGHTING DESIGN PROCEDURE ..... | 20 |
|------------|---------------------------------|----|

|            |                                                     |    |
|------------|-----------------------------------------------------|----|
| SECTION 12 | MAINTENANCE OF LIGHTING SYSTEMS AND EQUIPMENT ..... | 20 |
|------------|-----------------------------------------------------|----|

## APPENDICES

|   |                                                                              |    |
|---|------------------------------------------------------------------------------|----|
| A | MEASUREMENT OF ILLUMINANCE .....                                             | 22 |
| B | NOTES ON THE USE OF UTILIZATION FACTOR TABLES BY THE LIGHTING DESIGNER ..... | 23 |
| C | NOTES ON CHANGES TO ILLUMINANCE RECOMMENDATIONS .....                        | 24 |
| D | SPECIFIC RECOMMENDATIONS FOR EDUCATIONAL AND TRAINING FACILITIES .....       | 25 |
| E | BIBLIOGRAPHICAL REFERENCES.....                                              | 30 |

## FOREWORD

The aim of this Standard is to create a visual environment in which essential task details are made easy to see and adverse features which may cause visual fatigue are either excluded or appropriately controlled. The Committee is of the view that the greatest scope for achieving this lies with improvements in lighting quality rather than in the provision of higher illuminances.

While the provision of sufficient illuminance on the task is necessary in many instances task visibility depends more on the way in which the light is applied. Furthermore, the creation of the comfortable visual conditions required in order to maintain efficiency throughout the whole work period depends less on the quantity of light than on factors such as the distribution of light throughout the workplace; the use of suitable finishes on the walls, ceiling and equipment; the choice of luminaries with adequate glare control, and the elimination of unwanted reflections.

This is not a code to be followed rigidly, allowing no room for individual choice. It is a Standard that indicates paths to be followed and gives reasons for the advisability of following them. In some cases, it mentions limits within which lighting systems should be kept. Within these limits designers and engineers have great latitude in creating energy efficient and pleasing lighting designs.

## STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

**Australian/New Zealand Standard**  
**Interior and workplace lighting**

**Part 2.3: Specific applications—Educational and training facilities**

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE**

This Standard sets out recommendations for the creation of good seeing conditions in educational and training facilities by means of appropriate lighting and interior colour treatment. This Standard contains material that adds to or amends the recommendations in AS/NZS 1680.1:2006 and is intended to be read in conjunction with that Standard and with any applicable specific recommendations in other Standards in the AS/NZS 1680.2 series.

The use of this Standard without reference to AS/NZS 1680.1:2006 is a misapplication of the Standard.

**1.2 APPLICATION**

If any recommendation in this Standard differs from the general recommendations of AS/NZS 1680.1, the recommendation in this Standard should prevail apart from departures from the illuminance recommendations in this Standard where it should be in accordance with the clauses specifically addressing this matter in Section 3 of AS/NZS 1680.1:2006.

**1.3 REFERENCED DOCUMENTS**

The following documents are referred to in this Standard:

## AS/NZS

- |          |                                                                            |
|----------|----------------------------------------------------------------------------|
| 1680     | Interior and workplace lighting                                            |
| 1680.1   | Part 1: General principles and recommendations                             |
| 1680.2.1 | Part 2.1: Specific applications—Circulation spaces and other general areas |
| 1680.2.2 | Part 2.2: Specific applications—Office and screen-based tasks              |

## AS

- |          |                                                          |
|----------|----------------------------------------------------------|
| 2293     | Emergency escape lighting and exit signs for buildings   |
| 2293.1   | Part 1: System design, installation and operation        |
| 2560     | Guide to sports lighting                                 |
| 2560.2.2 | Part 2.2: Lighting of multipurpose indoor sports centres |

**1.4 DEFINITIONS**

For the purpose of this Standard, the definitions given in AS/NZS 1680.1:2006 and those below apply.

**1.4.1 Educational and training facilities**

An interior space or building complex comprising many such spaces, which provides facilities for structured learning or training programs for applications that may range from pre-school to tertiary levels.

NOTE: Throughout this Standard, educational and training facilities are referred to as 'educational facilities'.