

Australian/New Zealand Standard™

**Air-handling and water systems of
buildings—Microbial control**

**Part 3: Performance-based
maintenance of cooling water systems**



AS/NZS 3666.3:2011

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee ME-062, Ventilation and Airconditioning. It was approved on behalf of the Council of Standards Australia on 20 July 2011 and on behalf of the Council of Standards New Zealand on 25 July 2011.

This Standard was published on 14 November 2011.

The following are represented on Committee ME-062:

Air Conditioning and Mechanical Contractors Association
Australasian Fire and Emergency Service Authorities Council
Australian Building Codes Board
Australian Institute of Refrigeration Air Conditioning and Heating
Chartered Institution of Building Services Engineers
Climate Control Companies Association
Consumer Electronics Suppliers Association
Department of Health and Human Services, Tas.
Engineers Australia
Facility Management Association of Australia
Institute of Refrigeration Heating & AirConditioning Engineers of New Zealand
NSW Health Department
Plastics and Chemicals Industries Association
Plumbing Industry Commission

Keeping standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

**Air-handling and water systems of
buildings—Microbial control**

**Part 3: Performance-based
maintenance of cooling water systems**

Original was AS/NZS 3666.3(Int):1998.
Previous edition AS/NZS 3666.3:2000.
Third edition 2011.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

ISBN 978 0 7337 9919 8

PREFACE

This Standard was prepared by Joint Standards Australia/Standards New Zealand Committee ME-062, Ventilation and Airconditioning, to supersede AS/NZS 3666.3:2000.

This Standard forms Part 3 of a series of Standards for microbial control of air-handling and water systems of buildings, as follows:

AS/NZS

- 3666 Air-handling and water systems of buildings — Microbial control
- 3666.1 Part 1: Design, installation and commissioning
- 3666.2 Part 2: Operation and maintenance
- 3666.3 Part 3: Performance-based maintenance of cooling water systems
- 3666.4 Part 4: Performance-based maintenance of air-handling systems (ducts and components)

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
FOREWORD.....	4
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	6
1.2 OBJECTIVE.....	6
1.3 NORMATIVE REFERENCES.....	6
1.4 FUNCTIONAL STATEMENT.....	7
1.5 PERFORMANCE REQUIREMENTS.....	7
1.6 DEFINITIONS.....	7
1.7 TESTING.....	7
SECTION 2 IDENTIFICATION AND ASSESSMENT OF RISK FACTORS	
2.1 SCOPE OF SECTION.....	8
2.2 RISK FACTORS.....	8
2.3 RISK ASSESSMENT.....	8
2.4 WATER TREATMENT.....	8
SECTION 3 PERFORMANCE MONITORING AND CONTROL	
3.1 SCOPE OF SECTION.....	10
3.2 PRESENCE OF <i>LEGIONELLAE</i>	10
3.3 PRESENCE OF OTHER HETEROTROPHIC MICROORGANISMS.....	10
3.4 WATER QUALITY MANAGEMENT.....	10
3.5 WATER TEMPERATURE.....	11
3.6 START UP.....	13
3.7 RESULTS AND RECORDS.....	13
3.8 EVIDENCE OF COMPLIANCE.....	13
APPENDICES	
A COOLING WATER SAMPLING PROCEDURE.....	16
B ON-LINE DISINFECTION PROCEDURE FOR COOLING WATER SYSTEMS ...	18
C DECONTAMINATION PROCEDURES FOR COOLING WATER SYSTEMS	19
D GUIDELINES FOR THE USE OF PERSONAL PROTECTIVE EQUIPMENT DURING INSPECTION AND MAINTENANCE OF COOLING WATER SYSTEMS.....	21
BIBLIOGRAPHY.....	22

FOREWORD

AS/NZS 3666.2, *Air-Handling and water systems of buildings—Microbial control*, Part 2: *Operation and maintenance*, requires shutdown of cooling water systems for periodic cleaning. This is impracticable for many systems, such as the large industrial types serving power stations, co-generation plants, oil refineries and chemical manufacturing plants. However, microbiological control at these plants is usually effective and no reported outbreaks of Legionnaires' disease have been attributed to such sources. The continuous engineering attention they receive means they are generally well maintained. However, it became apparent that the AS/NZS 3666 series should provide for a performance-based alternative to the prescriptive maintenance requirements set out in Clause 2.5 of AS/NZS 3666.2. This performance-based alternative can be applied to any cooling water system for which the specific requirements of this Standard can be met.

This Standard provides such an alternative option. It follows risk management principles including—

- (a) context;
- (b) risk identification;
- (c) assessment;
- (d) control; and
- (e) monitoring and corrective actions.

These principles are applied to the key causal factors, understood to lead to a risk of multiplication of legionellae within a system, as set out in the Foreword to AS/NZS 3666.1.

A central issue in the management of health risk arising from microorganisms is the degree of scientific certainty about the underlying causes of growth, dissemination and infection. Control strategies adopted may need to change as new knowledge becomes available.

Sampling for legionellae is not required by AS/NZS 3666.2 but is considered to be a relevant monitoring activity in a performance-based approach. Although the sample taken may not accurately represent the microbial distribution and variety within the system, it is presently the most direct means of assessing the effectiveness of maintenance regimes on the multiplication of legionellae. Such specific tests need to be complemented with other assessments such as total bacterial count (also called heterotrophic colony count) and system water quality characteristics to provide reassurance that the system is well maintained and operating in a hygienic condition.

The concentration level of legionellae required to cause infection has not been established at this time. The risk of disease depends substantially on the susceptibility of the person exposed. However, it is reasonable to assume that increased risk is associated with exposure to increased concentrations of microorganisms. Available data suggest that most outbreaks are associated with a concentration of 1000 cfu/mL or greater, although lower levels may well be associated with sporadic cases of disease. It is the intention of this Standard that cooling water systems operate with non-detectable concentrations of legionellae. This Standard requires corrective actions to be carried out whenever a 'detectable' concentration of legionellae is found (10 cfu/mL or greater) in order to provide confidence that the system is hostile to these microorganisms. More demanding and prompt actions are required when a higher concentration is detected.

The primary aim is to avoid conditions that may allow microorganisms, including legionellae to multiply in the cooling water system thus creating a health risk.

An important strategy in minimizing health risks associated with cooling water systems involves the management of system water quality. Water treatment is designed to preserve the cooling tower and the cooling water system of which it is a part, maintain heat transfer efficiency and help ensure an acceptable standard of occupational and public health. These factors interact so that properly implemented microbial control, for reasons of disease prevention, should also assist in system longevity and efficiency. The water treatment program for microbial control needs to be well managed, and be more comprehensive than a program for those systems that are routinely cleaned in accordance with AS/NZS 3666.2. Water treatment program management approaches may differ in detail from site to site and, therefore, need to be documented in a specific plan for each site.

This Standard addresses only the maintenance of cooling water systems and is to be read in conjunction with Part 1 and the relevant clauses of Part 2. Aspects such as maintenance manuals, records, log books, safety procedures and the like, are as important for the application of this Standard, as they are for a prescriptive approach to maintaining a clean system.

Further explanatory information regarding the subject of microbial control of cooling water systems can be found in the Standards Australia/Standards New Zealand Handbook HB 32:1995, *Control of microbial growth in air-handling and water systems of buildings*, and the National Environmental Health Forum Monograph, *Guidance for the control of Legionella*, published by the South Australian Health Commission (1996) on behalf of the Commonwealth Department of Health and Aged Care, and the *Application Manual No. DA18, Water Treatment*, which is published by the Australian Institute of Refrigeration Air-conditioning and Heating (AIRAH).

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard
Air-handling and water systems of
buildings—Microbial control

Part 3: Performance-based maintenance of cooling water systems

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard outlines a performance-based approach to the maintenance of cooling water systems with respect to the control of microorganisms, including legionellae, within such systems. This approach combines automatically regulated water treatment with monitoring, assessment and control strategies to help create a low risk environment within the cooling water system.

The provisions of this Standard are an alternative to the prescriptive requirements of AS/NZS 3666.2 for the maintenance of cooling water systems.

NOTE: This Standard addresses only the performance of maintenance programs for cooling water systems and is to be read in conjunction with AS/NZS 3666.1 and the relevant clauses of AS/NZS 3666.2. Aspects such as maintenance manuals, records, log books, safety procedures, and the like, are as important for the application of this Standard as they are for a prescriptive approach to maintaining a clean system.

1.2 OBJECTIVE

The objective of this Standard is to provide a performance-based approach to cooling water system maintenance to assist users in the control of microorganisms, including legionellae, within such systems.

1.3 NORMATIVE REFERENCES

The following are the normative documents referenced in this Standard:

NOTE: Documents referenced for informative purposes are listed in the Bibliography.

AS/NZS	
2031	Selection of containers and preservation of water samples for microbiological analysis
3666	Air-handling and water systems of buildings—Microbial control
3666.1	Part 1: Design, installation and commissioning
3666.2	Part 2: Operation and maintenance
2296	Waters—Examination for <i>Legionella spp.</i> including <i>Legionella pneumophila</i>
4276	Water microbiology
4276.3.1	Method 3.1: Heterotrophic colony count methods—Pour plate method using yeast extract agar
4276.3.2	Method 3.2: Heterotrophic colony count methods—Plate count of water containing biocides