

Australian/New Zealand Standard™

**Performance of electrical appliances—
Air conditioners and heat pumps**

**Part 1.5: Non-ducted portable air-cooled
air conditioners and air-to-air heat
pumps having a single exhaust duct—
Testing and rating for performance**



AS/NZS 3823.1.5:2015

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-056, Room Air Conditioners. It was approved on behalf of the Council of Standards Australia on 24 July 2015 and on behalf of the Council of Standards New Zealand on 24 July 2015.

This Standard was published on 24 August 2015.

The following are represented on Committee EL-056:

Airconditioning and Refrigeration Equipment Manufacturers Association of Australia
Australian Building Codes Board
Australian Industry Group
CHOICE
Clean Energy Regulator
Consumer Electronics Association of New Zealand
Consumer Electronics Suppliers Association
CSIRO
Department of Industry and Science
Electrical Compliance Testing Association
Energy Efficiency and Conservation Authority of New Zealand
Energy Safe Victoria
Institute of Refrigeration Heating and AirConditioning Engineers of New Zealand
Institution of Professional Engineers New Zealand
University of New South Wales

Keeping standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

**Performance of electrical appliances—
Air conditioners and heat pumps**

**Part 1.5: Non-ducted portable air-cooled
air conditioners and air-to-air heat
pumps having a single exhaust duct—
Testing and rating for performance**

First published as AS/NZS 3823.1.5:2015.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

ISBN 978 1 76035 220 2

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-056, Room Air Conditioners.

This Standard follows the testing procedures set out in AS/NZS 3823.1.1:2012, *Performance of electrical appliances—Airconditioners and heat pumps*, Part 1.1: *Non-ducted airconditioners and heat pumps—Testing and rating for performance (ISO 5151:2010, MOD)*, apart from the following fundamental differences:

- (a) This Standard only describes a test setup using calorimeter rooms.
- (b) In the preparation of this Standard, reference was made to EN 14511-2 *Air Conditioners, Liquid Chilling Packages And Heat Pumps With Electrically Driven Compressors For Space Heating And Cooling*, Part 2: *Test Conditions*, for testing non-ducted portable air-cooled air conditioners and air-to-air heat pumps having a single exhaust duct by which both the indoor and outdoor test chambers are kept at the same rating conditions.
- (c) In the preparation of this Standard, reference was also made to EN 15218 *Air conditioners and liquid chilling packages with evaporatively cooled condenser and with electrically driven compressors for space cooling—Terms, definitions, test conditions, test methods and requirements* for testing and rating non-ducted portable air-cooled air conditioners and air-to-air heat pumps having a single exhaust duct that utilise an evaporatively cooled condenser.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

Statements expressed in mandatory terms in footnotes to tables are deemed to be requirements of this Standard.

CONTENTS

	<i>Page</i>
1 SCOPE.....	4
2 NORMATIVE REFERENCES	4
3 DEFINITIONS.....	5
4 NOTATION.....	8
5 COOLING TESTS	10
6 HEATING TESTS	11
7 TEST METHODS AND UNCERTAINTIES OF MEASUREMENTS.....	18
8 TEST RESULTS.....	21
9 MARKING PROVISIONS.....	25
10 PUBLICATION OF RATINGS	25
APPENDICES	
A TEST REQUIREMENTS.....	26
B UNITS WITH A SUPPLEMENTARY WATER TANK — DETERMINING THE DURATION OF SUPPLEMENTARY WATER EVAPORATION FEATURE	29
C AIRFLOW MEASUREMENT.....	31
D CALORIMETER TEST METHOD	37
E COOLING CONDENSATE MEASUREMENTS.....	46
F AN EXAMPLE OF MULTIPLE POINT AIR SAMPLING APPARATUS	47

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Performance of electrical appliances—Air conditioners and heat pumps****Part 1.5: Non-ducted portable air-cooled air conditioners and air-to-air heat pumps having a single exhaust duct—Testing and rating for performance****1 SCOPE**

This Standard specifies the standard conditions for capacity and efficiency ratings of non-ducted portable air-cooled air conditioners and air-to-air heat pumps having a single exhaust duct. Such air conditioners and heat pumps may include an evaporatively cooled condenser cooled by air and the evaporation of—

- (a) condensate collected from the evaporator;
- (b) external supplementary water stored in a supplementary water tank; or
- (c) both (a) and (b).

This Standard also specifies the test methods for determining the capacity and efficiency ratings.

The Standard applies to equipment that is factory-made, electrically driven and uses mechanical compression. This Standard is applicable to equipment utilizing one or more refrigeration systems.

This Standard is not applicable to the rating and testing of the following:

- (i) Water-source heat pumps or water-cooled air conditioners.
- (ii) Multi-split-system air conditioners and air-to-air heat pumps (see AS/NZS 3823.1.4 for the testing of such equipment).
- (iii) Individual assemblies not constituting a complete refrigeration system.
- (iv) Equipment using the absorption refrigeration cycle.
- (v) Ducted equipment (see AS/NZS 3823.1.2 for the testing of such equipment).
- (vi) Non-ducted air conditioners and heat pumps, including dual-duct ‘balanced type’ portable air conditioners (see AS/NZS 3823.1.1 for the testing of such equipment).
- (vii) Evaporative coolers or any other cooling systems that are not of the vapour compression type.
- (viii) Dehumidifiers.
- (ix) Spot coolers.

2 NORMATIVE REFERENCES

The following are the normative documents referenced in this Standard:

NOTE: Documents that are referenced for informative purposes are listed in the Bibliography.

ISO	
817	Refrigerants—Designation and safety classification