

Australian/New Zealand Standard™

Cold-formed steel structures



AS/NZS 4600:2018

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee BD-082, Cold-formed Steel Structures. It was approved on behalf of the Council of Standards Australia on 27 April 2018 and by the New Zealand Standards Approval Board on 2 May 2018.

This Standard was published on 15 May 2018.

The following are represented on Committee BD-082:

Australian Building Codes Board
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Steel Association
Australian Steel Institute
Bureau of Steel Manufacturers of Australia
Engineers Australia
National Association of Steel Framed Housing, Australia
National Association of Steel Framed Housing, New Zealand
Queensland University of Technology
University of Auckland
University of Sydney
University of Tasmania
Welding Technology Institute of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia Web Site at www.standards.org.au or Standards New Zealand web site at www.standards.govt.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of Standards Australia or the New Zealand Standards Executive at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 4600:2017.

Australian/New Zealand Standard™

Cold-formed steel structures

Originated in Australia as AS 1538—1974.

AS 1538—1988 jointly revised and redesignated AS/NZS 4600:1996.
Previous edition 2005.

Third edition 2018.

COPYRIGHT

© Standards Australia Limited

© The Crown in right of New Zealand, administered by the New Zealand Standards Executive

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee BD-082, Cold-formed Steel Structures. AS/NZS 4600:2005 will also remain current for 12 months after the date of publication of this Standard and after this time it will be superseded by AS/NZS 4600:2018. Regulatory authorities that reference this Standard in regulation may apply these requirements at a different time. Users of this Standard are advised to consult with these authorities to confirm their requirements.

The objective of this Standard is to provide designers of cold-formed steel structures with specifications for cold-formed steel structural members used for load-carrying purposes in buildings and other structures.

This edition incorporates the following major changes to the previous edition:

- (a) Inclusion of G500 and G550 steels in Clause 1.5.1.3 for steels where the effects of welding do not need to be tested.
- (b) Inclusion of reference to first order elastic, second order elastic and advanced analyses in Clause 1.6.2.
- (c) Earthquake design for Australia in Clause 1.6.4.1 based on structural ductility index and structural performance factor to align with latest edition of AS 1170.4.
- (d) Earthquake design for New Zealand in Clause 1.6.4.2 allows structural ductility factors up to 6.
- (e) Non-circular holes added to uniformly compressed stiffened elements in Clause 2.2.2.
- (f) New Clause 2.2.5 on intermittent connections in uniformly compressed elements.
- (g) Elastic buckling moments in Clause 3.3 moved to Paragraph D2.1, Appendix D, for members subject to bending.
- (h) Elastic buckling stresses in Clause 3.4 moved to Paragraph D1.1, Appendix D, for concentrically loaded compression members.
- (i) New Clause 3.7 for sections subject to combined bending and torsional loading.
- (j) New Clause 4.1.2 for compression members composed of two sections in contact.
- (k) Old Clause 4.3.3.5 on bracing of cleatless roof systems under gravity load deleted.
- (l) Revised Clause 4.3.3.3 (old Clause 4.3.3.4) for neither flange connected to sheeting has improved equations and a new diagram.
- (m) New equation for net section tension in Clause 5.3.3 has improved shear lag factor.
- (n) Bolted connections in bearing in Clause 5.3.4 now includes oversize and short-slotted holes.
- (o) Screws in shear and tension now allow the limit state based on testing of the screws.
- (p) Screwed connections in tension in Clause 5.4.3.2 now include round head, hex head, pancake screw washer head, hex washer head and domed head.
- (q) New rules in Clause 5.4.3.2 for screwed connections attaching roof battens.
- (r) New rules for screwed connections in combined bending and tension.
- (s) Design of power-actuated fasteners (PAFs) now included in Clause 5.5.
- (t) Revised equations for block shear rupture in Clause 5.7.3 based on active shear planes.

- (u) Range of prequalified members in Clause 7.1.1 (Table 7.1) for the direct strength method (DSM) extended to a wider range of sections with multiple intermediate stiffeners and return lips.
- (v) Compression and flexural members with holes and flexural members with inelastic reserve capacity now included in the DSM Clauses 7.2.1 and 7.2.2.
- (w) Shear and combined bending and shear added to the DSM in Clause 7.2.3.
- (x) Combined compression/tension and bending added to the DSM in Clause 7.2.4.5 respectively.
- (y) Design values based on prototype testing in Clause 8.4.1 can now use the average test value.
- (z) Strength prediction model from testing based on verification model BV1 of National Construction Code (NCC).
- (aa) New Section 9, Fire design, added for steel sections made from AS 1397, Steel and with a fire resistant barrier.
- (bb) New Appendix B, Paragraph B2, First order elastic analysis, Paragraph B3, Second order elastic analysis and Paragraph B4, Advanced analysis, added.
- (cc) Appendix D extended to buckling stresses and actions for sections in compression, bending and shear including sections with holes.
- (dd) Informative Appendix G added for members subject to non-uniform temperature distribution.

Notes to the text contain information and guidance. They are not an integral part of the Standard.

Sections of this Standard have been reproduced from AISI S100, *North American Specification for the Design of Cold-Formed Steel Structural Members*, with permission from the American Iron and Steel Institute.

Standards Australia thanks NASH (National Association of Steel-framed Housing) for permission to reproduce sections of NASH Standard—*Residential and Low-rise Steel Framing, Part 1: Design Criteria* in Clause 1.6 and Clause 8.4 of this Standard.

A statement expressed in mandatory terms in a note to a table is deemed to be a requirement of this Standard.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	6
1.2 NORMATIVE REFERENCES	6
1.3 DEFINITIONS.....	6
1.4 NOTATION.....	13
1.5 MATERIALS.....	5
1.6 DESIGN REQUIREMENTS.....	29
SECTION 2 ELEMENTS	
2.1 SECTION PROPERTIES	35
2.2 EFFECTIVE WIDTHS OF STIFFENED ELEMENTS.....	37
2.3 EFFECTIVE WIDTHS OF UNSTIFFENED ELEMENTS.....	45
2.4 EFFECTIVE WIDTHS OF UNIFORMLY COMPRESSED ELEMENTS WITH AN EDGE STIFFENER	48
2.5 EFFECTIVE WIDTHS OF UNIFORMLY COMPRESSED STIFFENED ELEMENTS WITH ONE INTERMEDIATE STIFFENER	50
2.6 EFFECTIVE WIDTHS OF UNIFORMLY COMPRESSED STIFFENED ELEMENTS WITH MULTIPLE INTERMEDIATE STIFFENER	52
2.7 EFFECTIVE WIDTHS OF UNIFORMLY COMPRESSED EDGE-STIFFENED ELEMENTS WITH INTERMEDIATE STIFFENERS	55
2.8 ARCHED COMPRESSION ELEMENTS	56
SECTION 3 MEMBERS	
3.1 GENERAL.....	57
3.2 MEMBERS SUBJECT TO AXIAL TENSION.....	57
3.3 MEMBERS SUBJECT TO BENDING.....	59
3.4 CONCENTRICALLY LOADED COMPRESSION MEMBERS.....	76
3.5 COMBINED AXIAL COMPRESSION OR TENSION, AND BENDING	78
3.6 CYLINDRICAL TUBULAR MEMBERS	80
3.7 COMBINED BENDING AND TORSIONAL LOADING.....	82
SECTION 4 STRUCTURAL ASSEMBLIES	
4.1 BUILT-UP SECTIONS	83
4.2 MIXED SYSTEMS.....	85
4.3 LATERAL RESTRAINTS.....	85
4.4 WALL STUDS AND WALL STUD ASSEMBLIES.....	88
SECTION 5 CONNECTIONS	
5.1 GENERAL.....	89
5.2 WELDED CONNECTIONS	89
5.3 BOLTED CONNECTIONS	101
5.4 SCREWED CONNECTIONS.....	107
5.5 POWER-ACTUATED FASTENERS (PAFs).....	112
5.6 BLIND RIVETED CONNECTIONS	117
5.7 RUPTURE.....	119
5.8 OTHER CONNECTIONS USING ANY TYPE OF FASTENERS.....	120

SECTION 6 FATIGUE	
6.1	GENERAL..... 121
6.2	CALCULATION OF MAXIMUM STRESSES AND STRESS RANGE 124
6.3	DETAIL CATEGORIES FOR CLASSIFIED DETAILS 125
6.4	FATIGUE ASSESSMENT 127
SECTION 7 DIRECT STRENGTH METHOD	
7.1	GENERAL..... 129
7.2	MEMBERS..... 130
SECTION 8 TESTING	
8.1	TESTING FOR DETERMINING MATERIAL PROPERTIES 141
8.2	TESTING FOR ASSESSMENT OR VERIFICATION..... 142
8.3	COEFFICIENT OF VARIATION OF STRUCTURAL CHARACTERISTICS 143
8.4	DESIGN VALUES 144
SECTION 9 FIRE DESIGN	
9.1	REQUIREMENTS..... 146
9.2	DEFINITIONS..... 146
9.3	DETERMINATION OF THE PERIOD OF STRUCTURAL ADEQUACY 146
9.4	ELEVATED TEMPERATURE MECHANICAL PROPERTIES 147
9.5	DETERMINATION OF MEMBER CAPACITIES AT ELEVATED TEMPERATURES 150
9.6	DETERMINATION OF LIMITING TEMPERATURE 151
9.7	DETERMINATION OF TEMPERATURE-TIME RELATIONSHIPS FOR PROTECTED MEMBERS 151
9.8	DETERMINATION OF PSA FROM THE STANDARD FIRE TEST 151
9.9	CONNECTIONS 151
APPENDICES	
A	NORMATIVE REFERENCES..... 152
B	METHODS OF ANALYSIS 154
C	PROTECTION..... 159
D	BUCKLING STRESSES AND MOMENTS AND SHEARS FOR SECTIONS IN COMPRESSION, BENDING AND SHEAR..... 161
E	SECTION PROPERTIES 177
F	STANDARD TESTS FOR SINGLE-POINT FASTENER CONNECTIONS 180
G	MEMBERS SUBJECT TO NON-UNIFORM TEMPERATURE DISTRIBUTIONS 185
BIBLIOGRAPHY 191	

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard
Cold-formed steel structures

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out minimum requirements for the design of structural members cold-formed to shape from carbon or low-alloy steel sheet, strip, plate or bar not more than 25 mm in thickness and used for load-carrying purposes in buildings. It is also applicable for structures other than buildings, provided appropriate allowances are made for dynamic effects.

This Standard does not apply to the design of structures subject to brittle fracture.

1.2 NORMATIVE REFERENCES

Normative documents referenced in this Standard are listed in Appendix A.

NOTE: Documents referenced for informative purposes are listed in the Bibliography.

1.3 DEFINITIONS

For the purpose of this Standard, the definitions below apply. Definitions peculiar to a particular clause or section are also given in that clause or section.

1.3.1 Action

Set of concentrated or distributed forces acting on a structure (direct action), or deformation imposed on a structure or constrained within it (indirect action).

1.3.2 Action effect (internal effects of actions, load effects)

Internal forces and bending moments due to actions (stress resultants).

1.3.3 Arched compression element

A circular or parabolic arch-shaped compression element having an inside radius-to-thickness ratio greater than 8, stiffened at both ends by edge stiffeners. See Figure 1.3(C).

1.3.4 Assemblage of elements

A system of interconnected cold-formed steel elements that act together to resist earthquake action in such a way that the strength and deformation capacity of the system is not adversely affected by the buckling or crippling of any one element of the assemblage.

1.3.5 Bend

Portion adjacent to flat elements and having a maximum inside radius-to-thickness ratio (r_i/t) of 8. See Figure 1.3(A).

1.3.6 Braced member

Member for which the transverse displacement of one end of the member relative to the other is effectively prevented.