

Australian/New Zealand Standard™

Accessories for electric cables—Test requirements

Part 1: Power cables with extruded insulation for rated voltages from 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV



AS/NZS 4805.1:2007

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-003, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 5 September 2007 and on behalf of the Council of Standards New Zealand on 13 July 2007.

This Standard was published on 20 December 2007.

The following are represented on Committee EL-003:

Australasian Railway Association
Australian Electrical and Electronic Manufacturers Association
Australian Industry Group
Canterbury Manufacturers Association, New Zealand
Department of Primary Industries, Mine Safety, NSW
Electrical Contractors Association of New Zealand
Electrical Regulatory Authorities Council
Energy Networks Association
Engineers Australia
Ministry of Economic Development, New Zealand

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

Accessories for electric cables—Test requirements

Part 1: Power cables with extruded insulation for rated voltages from 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV

Originally as AS/NZS 4805.1:2001.
Second edition 2007.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 8498 4

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-003, Electric Wires and Cables to supersede AS/NZS 4805.1:2001.

The objective of this Standard is to specify the type test requirements on accessories for power cables with extruded insulation and with rated voltages from 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV.

This Standard is published in two parts. These are:

AS/NZS

4805 Accessories for electric cables—Test requirements

4805.1 Part 1: Power cables with extruded insulation for rated voltages from 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV (this Standard)

4805.2 Part 2: Impregnated paper-insulated metal-sheathed cables for rated voltages from 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV (excluding gas-pressure and oil-filled cables)

In the preparation of these Standards IEC 60502-4, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) Part 4: Test requirements on accessories for cables with rated voltages from 6 kV ($U_m = 7,2$ kV) up to 30 kV ($U_m = 36$ kV)*, and IEC 60055-1, *Paper-insulated metal-sheathed cables for rated voltages up to 18/30 kV (with copper or aluminium conductors and excluding gas-pressure and oil-filled cables) Part 1: Tests on cables and their accessories* were considered.

The structure of these IEC Standards did not lend itself to straight adoption so the production of a two part Australian/New Zealand Standard was considered appropriate.

This first part of AS/NZS 4805 adopts the content of IEC 60502-4. The second part adopts only part of the content of IEC 60055-1. This IEC Standard covers tests on cables as well as accessories.

This edition differs from the previous edition in the following significant ways:

- (a) References to transition points have been removed.
- (b) Definitions have been provided for tracking, erosion and metallic housing.
- (c) A requirement for the identification of dimensions of phase-to-phase and phase-to-earth separations for testing of terminations has been included.
- (d) The range of approval has been revised.
- (e) Test sequences have been simplified by removing initial heating cycles.
- (f) Additional information has been provided for testing separable connectors with a metallic housing.
- (g) A examination has been added to all test sequences for information only.
- (h) A more detailed definition of substantial damage following the humidity and salt fog tests has been provided.
- (i) All test methods, except the hydraulic pressure test, have been referenced to IEC 61442.
- (j) Test sequences and requirements for loadbreak connectors have been deleted and their status has been designated 'under consideration'.

Separable connectors are also addressed in AS 2629, *Separable insulated connectors for power distribution systems above 1 kV*, but they were not considered during the preparation of this Standard. It is planned for AS 2629 to be revised and appropriately changed or assimilated into this Standard.

The term 'normative' has been used in this Standard to define the application of an appendix to which it applies. A normative appendix is an integral part of a Standard.

Statements expressed in mandatory terms in notes and footnotes to tables and figures are deemed to be requirements of this Standard.

Currently in preview, click buy full version

CONTENTS

	Page
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 REFERENCED DOCUMENTS	5
1.3 DEFINITIONS	6
1.4 VOLTAGE DESIGNATIONS AND TEMPERATURE RATING.....	7
SECTION 2 ASSEMBLY OF ACCESSORIES TO BE TESTED	
2.1 CABLES.....	8
2.2 CONNECTORS.....	8
2.3 ACCESSORIES.....	8
2.4 INSTALLATION AND CONNECTIONS.....	8
SECTION 3 CONDITIONS AND RANGE OF APPROVAL	
3.1 RANGE OF APPROVAL.....	10
3.2 CONDUCTOR MATERIAL	10
3.3 FORM OF CONDUCTOR	10
3.4 INSULATION MATERIAL	10
3.5 INSULATION SCREEN	11
3.6 WATER BLOCKING.....	11
3.7 NUMBER OF CORES.....	11
3.8 CLEARANCES	11
SECTION 4 TESTS	
4.1 CATEGORY OF TESTS	12
4.2 TEST METHODS.....	12
4.3 TEST ARRANGEMENTS	12
4.4 TEST SEQUENCES.....	12
4.5 TEST RESULTS	13
APPENDIX A IDENTIFICATION OF TEST CABLE.....	33

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard
Accessories for electric cables—Test requirements

Part 1: Power cables with extruded insulation for rated voltages from
 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies the requirements for type testing of accessories for power cables with extruded insulation with rated voltages from 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV, complying with AS/NZS 1429.1 or IEC 60502-2.

The accessories covered by this Standard are listed below:

- (a) Indoor and outdoor terminations of all designs, including those designed for installation in terminal boxes.
- (b) Straight joints, branch joints and stop-ends of all designs, suitable for use underground or in air.
- (c) Screened or unscreened plug-in type or bolted type separable connectors.

NOTE: Joints connecting cables with extruded insulation to paper-insulated cables are not included. The requirements for these accessories are dealt with in AS/NZS 4805.2.

Accessories for special applications, such as aerial cables, submarine or ship cables or hazardous situations (explosive environments, fire resistant cables or seismic conditions) are not included.

Approval to this Standard is obtained by satisfying the requirements of the appropriate tests as specified in Section 4.

1.2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS/NZS	
1429	Electric cables—Polymeric insulated
1429.1	Part 1: For working voltages 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV
1325	Compression and mechanical connectors for power cables with copper or aluminium conductors
4235.1	Part 1: Test methods and requirements
4805	Accessories for electric cables—Test requirements
4805.2	Part 2: Impregnated paper-insulated metal-sheathed cables for rated voltages from 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV (excluding gas-pressure and oil-filled cables)
IEC	
60050	International Electrotechnical Vocabulary (IEV)
60050-461	Chapter 461: Electric cables
60183	Guide to the selection of high-voltage cables