

Australian/New Zealand Standard™

**Performance of close control  
airconditioners**

**Part 2: Minimum energy performance  
standard (MEPS) requirements**



## **AS/NZS 4965.2:2008**

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-015, Quality and Performance of Household Electrical Appliances. It was approved on behalf of the Council of Standards Australia on 15 September 2008 and on behalf of the Council of Standards New Zealand on 24 September 2008.

This Standard was published on 14 November 2008.

---

The following are represented on Committee EL-015:

Australian Association of Certification Bodies  
Australian Consumers' Association  
Australian Electrical and Electronic Manufacturers Association  
Australian Industry Group  
Australian Retailers Association  
Business New Zealand  
Consumer Electronic Suppliers Association  
Department of Energy, Utilities and Sustainability, New South Wales  
Department of Industrial Relations, Queensland  
Department of Minerals and Energy, Queensland  
Electrical Compliance Testing Association  
Energy Efficiency and Conservation Authority, New Zealand  
Energy Safe, Victoria  
Institution of Professional Engineers, New Zealand  
National Appliance and Equipment Energy Efficiency Committee  
New Zealand Manufacturers Federation  
Office of the Chief Electrical Inspector, Victoria  
Office of the Technical Regulator, South Australia

Additional Interests:

Air Conditioning and Refrigeration Equipment Manufacturers Association  
Institute of Refrigeration, Heating and Air Conditioning Engineers, New Zealand  
Institution of Professional Engineers, New Zealand  
Primary Industries and Resources South Australia  
Testing Interest Australia

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at [www.standards.com.au](http://www.standards.com.au) or Standards New Zealand web site at [www.standards.co.nz](http://www.standards.co.nz) and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

---

*This Standard was issued in draft form for comment as DR 08026.*

---

Australian/New Zealand Standard™

**Performance of close control  
airconditioners**

**Part 2: Minimum energy performance  
standard (MEPS) requirements**

First published as AS/NZS 4965.2:2008.

**COPYRIGHT**

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 8939 0

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-015, Quality and Performance of Household Electrical Appliances.

The overall objective of the AS/NZS 4965 series of Standards is to promote high levels of performance and energy efficiency in close control airconditioners.

The AS/NZS 4965 series of Standards consists of the following:

### AS/NZS

4965 Performance of close control airconditioners

4965.1 Part 1: Testing for rating

4965.2 Part 2: Minimum energy performance standard (MEPS) requirements  
(this Standard)

This Standard is published with the approval of the combined state and territory regulatory authorities and is structured to be suitable for reference in legislation calling up minimum energy performance standards and also for reference in energy labelling regulatory legislation.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to figures are deemed to be requirements of this Standard.

## CONTENTS

	<i>Page</i>
<b>SECTION 1 SCOPE AND GENERAL</b>	
1.1 SCOPE .....	4
1.2 EXCLUSIONS .....	4
1.3 APPLICATION .....	4
1.4 OBJECTIVE.....	4
1.5 REFERENCED DOCUMENTS .....	5
1.6 DEFINITIONS .....	5
1.7 MEASURED QUANTITIES .....	6
1.8 ROUNDING.....	6
<b>SECTION 2 PERFORMANCE CRITERIA</b>	
2.1 GENERAL .....	7
2.2 MINIMUM ENERGY PERFORMANCE STANDARD.....	7
2.3 TEST CONDITIONS FOR DETERMINING MINIMUM ENERGY PERFORMANCE STANDARD.....	7
2.4 NUMBER OF TESTS AND PROCESSING OF DATA.....	7
2.5 MINIMUM ENERGY PERFORMANCE STANDARD REQUIREMENTS COMPLIANCE .....	7
2.6 STANDBY POWER AND CRANKCASE HEATERS .....	8
2.7 POWER FACTOR.....	8
<b>SECTION 3 APPLICATION AND TEST RESULT FORMATS</b>	
3.1 APPLICATION FOR REGISTRATION .....	9
3.2 PRODUCT LISTING .....	9
3.3 DATE OF MANUFACTURE INFORMATION.....	10
<b>APPENDICES</b>	
A FORMAT OF APPLICATION FOR REGISTRATION OF AN AIRCONDITIONER FOR ENERGY LABELLING AND MEPS.....	11
B FORMAT OF SUMMARY TEST RESULTS FOR MEPS APPLICATION .....	17

## STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

**Australian/New Zealand Standard  
Performance of close control airconditioners****Part 2: Minimum energy performance standard (MEPS) requirements**

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE**

This Standard specifies the minimum energy performance standard (MEPS) requirements for close control airconditioners that fall in the scope of AS/NZS 4965.1.

This Standard does not specify electrical safety requirements.

This Standard specifies the following values for cooling, as applicable:

- (a) Rated power (input).
- (b) Rated capacity (output).
- (c) Energy efficiency ratio (EERS) for cooling.
- (d) Minimum energy performance standard requirements.

**1.2 EXCLUSIONS**

The following equipment is excluded from the scope of this Standard:

- (a) All airconditioners except for close control airconditioners, including—
  - (i) ducted and ductless split systems, and
  - (ii) ducted packaged units.
- (b) Multi-split systems (i.e. those having more than one indoor unit with an independent control for each indoor unit), pending the development of a suitable test method.
- (c) Evaporative cooling or any other cooling systems that are not of the vapour compression type.
- (d) Ground-water-sourced or ground-loop-sourced heat pumps.
- (e) Unbalanced airconditioners and spot coolers (these include many portable types).
- (f) Commercial chillers used in commercial buildings to provide chilled water for space-cooling equipment.

**1.3 APPLICATION**

This Standard shall be read in conjunction with AS/NZS 4965.1:200X.

**1.4 OBJECTIVE**

The objective of this Standard is to—

- (a) provide detailed information on the performance requirements that a close control airconditioner has to meet in order to meet minimum energy performance standard requirements; and