

AS/NZS 5368:2025



Australian/New Zealand Standard™

Electrical equipment in mines and quarries

Currently in preview, click buy full version

AS/NZS 5368:2025

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee EL-023, Electrical Equipment in Mines and Quarries. It was approved on behalf of Standards Australia's Standards Development and Accreditation Committee on 24 April 2025 and by the New Zealand Standards Approval Board on 07 May 2025.

This Standard was published on 27 June 2025.

The following are represented on Committee EL-023:

Australian Cablemakers Association
Australian Industry Group
Aviation and Marine Engineers Association
Construction Forestry Miners and Energy Union
Department of Energy, Mines, Industry Regulation and Safety, Western Australia
Department of Primary Industries and Regional Development (NSW)
Engineering New Zealand
Engineers Australia
Engineers Australia/Mining Electrical and Mining Mechanical Engineering Society
Minerals Council of Australia
National Association of Testing Authorities Australia
Resources Safety & Health Queensland
SafeWork NSW
University of Newcastle
WorkSafe New Zealand

This Standard was issued in draft form for comment as DR AS/NZS 5368:2024.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

ISBN 978 1 76175 166 0

Australian/New Zealand Standard™

Electrical equipment in mines and quarries

Originated as AS/NZS 3007:2013, AS/NZS 4871.1:2012, AS/NZS 4871.2:2010, AS/NZS 4871.3:2010, AS/NZS 4871.4:2010, AS/NZS 4871.5:2010 and AS/NZS 4871.6:2013. Jointly revised, amalgamated and redesignated as AS/NZS 5368:2025.

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2025

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

How to read this Standard

This page explains the meaning of the language and structure of this Standard.

Refer to Standards Australia's Standardisation Guide 006 for more details about drafting rules.

Australian and Australian/New Zealand Standards are voluntary unless they are referenced in legislation or called up in contracts.

Requirements

To conform to a Standard, all requirements in the Standard need to be met.

A requirement is any statement in the Standard which uses the word "shall".

Recommendations, permissions and possibilities

The following words are commonly used in Standards, but statements using them do not have to be followed to conform to the Standard:

- (a) "should" means that something is recommended.
- (b) "may" means that something is permitted.
- (c) "can" means that something is possible.

Structure of Standards

A Standard always has the following parts:

- (i) The Preface states who developed the Standard, what the Standard is aiming to do, and how it relates to other documents.
- (ii) The Scope states what the Standard is about, what it covers and what it does not cover.
- (iii) The Normative references clause lists other documents that are referenced in the Standard as part of requirements.
- (iv) The Terms and definitions clause defines important terms to help with understanding the Standard.

A Standard may also include other parts, such as the following:

- (1) A normative appendix sets additional requirements that need to be conformed to.
- (2) An informative appendix provides additional information or guidance. They usually do not contain requirements. If an informative appendix does contain requirements, the Standard will explain when those requirements apply.
- (3) A Bibliography lists documents referenced in the Standard but not as part of requirements.

Many Standards include notes. Notes provide recommendations and/or guidance only. They never contain requirements.

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-023, Electrical Equipment for Mines and Quarries, to supersede AS/NZS 3007:2013 and all parts of the AS/NZS 4871 series.

The objective of this document is to set out requirements and recommendations for the design, installation, operation and maintenance of electrical equipment in mines and quarries to ensure the safety of persons, livestock and property, and the proper functioning of plant.

Mining operations typically involve most aspects of electrical engineering, ranging from such areas as high voltage transmission to the control of undesirable static electricity. A substantial number of standards therefore apply to such work. This document consolidates updated requirements relating to these areas of application together into the one document.

The terms “normative” and “informative” are used in Standards (and other publications) to define the application of the appendices to which they apply. A “normative” appendix is an integral part of a standard, whereas an “informative” appendix is only for information and guidance.

Contents

Preface	iii
Section 1 Scope and general	1
1.1 Scope.....	1
1.2 Application.....	1
1.2.1 General.....	1
1.2.2 General requirements.....	1
1.2.3 Requirements for fixed equipment and installations.....	2
1.2.4 Requirements for transportable and mobile plant and equipment.....	2
1.2.5 Requirements for electrical equipment located in hazardous areas.....	3
1.2.6 Relationship with other industry standards.....	3
1.3 Normative references.....	3
1.4 Terms and definitions.....	5
1.5 Equipment life cycle.....	14
1.6 Risk management.....	14
1.7 Change management.....	14
1.8 Safe work locations.....	15
1.8.1 General.....	15
1.8.2 Controlled work area.....	15
1.8.3 No standing zone.....	15
1.8.4 No entry zone.....	16
1.8.5 Remote-controlled equipment.....	16
1.8.6 Autonomous equipment.....	16
1.8.7 Proximity detection.....	16
1.8.8 Proximity awareness.....	16
1.9 Power system design.....	17
1.9.1 General.....	17
1.9.2 Earthing.....	17
1.9.3 Protection.....	20
1.9.4 Harmonic sources.....	26
1.9.5 Emergency stop devices and associated circuitry.....	26
1.10 Equipment design and installation.....	26
1.10.1 General.....	26
1.10.2 Earthing.....	27
1.10.3 Design and manufacture.....	28
1.10.4 Cabling and control requirements.....	43
1.10.5 Fire detection and protection for electrical areas.....	45
1.10.6 Labels and signage.....	48
1.10.7 Safety critical plant.....	52
1.10.8 Specific power supplies.....	55
1.10.9 Redundant plant.....	56
1.10.10 Blasting near electrical assets.....	56
1.11 Testing.....	56
1.11.1 General.....	56
1.11.2 Modification of type tested equipment.....	56
1.11.3 Testing of devices and self-contained components incorporated in the assembly.....	57
1.12 Operational requirements.....	57
1.12.1 General.....	57
1.12.2 Information requirements.....	57
1.12.3 Oil filled electrical equipment.....	57
1.12.4 Restrictions on access by personnel.....	57
1.12.5 Personnel working on or near exposed live parts.....	58
1.12.6 Battery charging.....	58
1.12.7 Static electricity.....	58
1.12.8 Hazards from electrical coupling.....	59

1.12.9	Radioactive sources.....	59
1.13	Documentation.....	59
1.13.1	Plant safety file (verification dossier).....	59
1.13.2	Technical maintenance and operational manuals.....	59
1.13.3	Manuals and supporting documentation.....	59
Section 2	Fixed equipment and installations.....	61
2.1	Overhead lines.....	61
2.1.1	General.....	61
2.1.2	Easements and corridors.....	61
2.1.3	Mine owned/operated OHLs.....	62
2.1.4	Work near OHLs.....	63
2.1.5	Decommissioning overhead lines.....	66
2.1.6	Moving of OHLs.....	66
2.1.7	Precautions during lightning storms.....	66
2.1.8	Operations involving long metallic structures.....	66
2.1.9	Clearing vegetation near OHLs.....	66
2.1.10	Emergency response plan for contact with OHLs.....	66
2.2	Conveyors — Fixed.....	67
2.2.1	General provisions for conveyors.....	67
2.2.2	Belt splicing equipment.....	67
2.3	Gas drainage plant.....	68
2.4	Coal mine reclaim tunnels.....	68
2.4.1	General.....	68
2.4.2	Automatic gas monitoring system.....	69
2.4.3	Reclaim or transfer tunnel emergency lighting.....	69
2.4.4	Stockpiles above reclaim or transfer tunnels.....	69
2.5	Powered winding systems.....	70
2.5.1	Availability of exits from the mine.....	70
2.5.2	Gravity winding.....	70
2.5.3	Testing of auxiliary pony drive and gravity winding systems.....	70
2.5.4	Diesel-driven emergency generators.....	71
Section 3	Transportable and mobile plant and equipment.....	72
3.1	Safety systems.....	72
3.1.1	Warning devices.....	72
3.1.2	Plant shutdown.....	72
3.2	Mobile machines.....	72
3.2.1	Isolator for electrical access.....	72
3.2.2	Automatic gas monitoring system.....	73
3.2.3	Electrical braking.....	73
3.3	Battery powered equipment.....	73
3.3.1	General.....	73
3.3.2	Lithium batteries.....	73
3.3.3	Battery container design.....	74
3.3.4	Electrical protection.....	74
3.3.5	Enclosure interlocking.....	75
3.3.6	Battery cells.....	75
3.3.7	Battery switching device.....	75
3.4	Machine controls.....	76
3.4.1	Dual operating stations.....	76
3.4.2	Machine interconnection.....	76
3.4.3	Emergency stop device.....	76
3.5	Machine interlocks.....	76
3.5.1	General.....	76
3.5.2	Doors.....	76
3.5.3	Water flow.....	76
3.5.4	Roof bolting.....	76
3.5.5	Control mode.....	77

3.5.6	Conveyor reversing.....	77
3.5.7	Cable interlock.....	77
3.5.8	Pilot control.....	77
3.6	Marking and labelling.....	77
3.6.1	Battery isolator.....	77
3.6.2	Jump-start receptacle.....	77
3.7	Mobile machinery lighting systems.....	77
3.8	Protection of cables and cable harness.....	78
3.8.1	General.....	78
3.9	Restraint of cables and cable harnesses.....	78
3.10	Circuits utilizing machine frame.....	78
3.11	Transportable/mobile substations.....	79
3.11.1	Transportable substations.....	79
3.11.2	Transportable buildings and IT earthing systems.....	79
3.12	Trailing, reeling and feeder cables.....	80
3.12.1	Cable requirements.....	80
3.12.2	Moving cables.....	81
3.12.3	Installation of cables.....	82
3.12.4	Cable towers and high wall gantries.....	83
3.12.5	Manual handling of cable couplers.....	83
3.12.6	Additional protection requirements for trailing cables.....	83
3.12.7	Cable repair.....	84
3.12.8	Precautions during lightning storms.....	84
3.12.9	Cable termination boxes.....	84
3.12.10	Reeling and trailing cable attachments.....	84
3.13	Cable reels.....	84
3.13.1	General.....	84
3.13.2	Cable rating factors.....	85
3.13.3	Cable reel bearings.....	85
3.13.4	Cable reel dimensions.....	85
3.13.5	Cable reel interlock limit.....	85
3.14	Conveyors.....	85
3.14.1	General.....	85
3.14.2	Cables of conveyors.....	85
3.15	Underground high voltage section isolators.....	86
3.15.1	General.....	86
3.15.2	Isolation and indication.....	86
3.15.3	Positioning of outlets.....	86
3.16	Distribution control boxes.....	86
3.16.1	General.....	86
3.16.2	Positioning of outlets.....	86
3.16.3	Lighting.....	86
3.17	Underground ventilation fans.....	87
3.18	Underground coal fire protected diesel vehicles.....	87
3.18.1	General.....	87
3.18.2	General arrangement, control and protection.....	87
3.18.3	Engine safety shutdown system.....	89
3.18.4	Electrical protection.....	90
3.18.5	Alternator voltage regulation.....	90
3.18.6	Type of cable and conductors.....	90
3.18.7	Cables for engine safety shutdown systems.....	90
3.19	Underground coal flameproof diesel vehicles.....	91
3.19.1	Methane monitoring system.....	91
Section 4	Electrical equipment located in hazardous areas.....	93
4.1	Aluminium or light metal alloy parts.....	93
4.2	Protection.....	93
4.2.1	Earth leakage protection.....	93
4.2.2	Interlocking.....	93

4.2.3	Pilot protection of restrained receptacles.....	93
4.2.4	Earth fault lockout.....	94
4.2.5	Earth continuity and earth fault lockout protection.....	94
4.3	Enclosures.....	94
4.3.1	Explosion-protected enclosures.....	94
4.3.2	Isolation.....	94
4.3.3	Stored energy devices other than batteries.....	94
4.3.4	High-energy arcing faults.....	94
4.3.5	Surface temperature.....	95
4.4	Batteries and energy storage devices.....	95
4.5	Cable protection.....	95
4.6	Machine cables.....	95
4.6.1	General.....	95
4.6.2	Intrinsically safe cables.....	95
4.6.3	Light alloy screening.....	96
4.7	Battery powered mobile machines — Connections to the battery.....	96
4.8	Hazardous area ventilation fans installed underground.....	96
4.9	Power supplies to de-watering and methane drainage plant and equipment.....	97
Appendix A (informative) Plant safety file (verification dossier).....		98
Appendix B (Informative) Earthing in Underground Mines.....		100
Appendix C (informative) Guidance on earth fault protection of trailing cable and reeling cable fed machinery.....		101
Appendix D (informative) TN, TT and IT systems description.....		108
Appendix E (informative) Earth fault limited protection systems.....		115
Appendix F (informative) Protection devices and their uses.....		120
Appendix G (informative) Installation and use of earth fault current limitation devices.....		131
Appendix H (informative) Installation and use of earth continuity protection systems.....		133
Appendix I (informative) Installation and use of earth fault lockout protection systems.....		135
Appendix J (informative) Installation and use of NER integrity protection systems.....		136
Appendix K (informative) Installation and use of frozen contact protection systems.....		137
Appendix L (informative) Guidelines for low signal level systems and communication systems.....		138
Appendix M (informative) Variable speed drives.....		143
Appendix N (informative) Information to be supplied by the purchaser.....		151
Appendix O (informative) Integrated control system.....		153
Appendix P (informative) Arcing faults in flameproof enclosures.....		154
Appendix Q (informative) Test methods.....		155
Appendix R (informative) Documentation of methane levels.....		160
Appendix S (informative) Functional safety in a mining environment.....		161
Appendix T (informative) Emergency action in the event of an OHL accident.....		163
Appendix U (informative) Testing intervals for electrical plant.....		164
Appendix V (informative) Intervals for training.....		166
Bibliography.....		167

NOTES

Currently in preview, click buy full version

Australian/New Zealand Standard

Electrical equipment in mines and quarries

Section 1 Scope and general

1.1 Scope

This document sets out requirements and recommendations for the design, installation, operation and maintenance of electrical plant and equipment located at mining and quarrying operations. It includes specific requirements and recommendations for the following:

- (a) Fixed plant and installations.
- (b) Transportable and mobile plant and equipment.
- (c) Electrical equipment in hazardous areas.

NOTE This document does not provide guidance on hand-held and portable equipment.

1.2 Application

1.2.1 General

Mining operations typically involve most aspects of electrical engineering, ranging from high voltage transmission to the control of undesirable static electricity. This document consolidates requirements that apply to such work. The requirements for particular electrical installation applications are as specified in [Clauses 1.2.2](#) to [1.2.5](#).

1.2.2 General requirements

[Section 1](#) provides general requirements that apply to the design, installation and maintenance of electrical plant and equipment located at mining and quarrying operations.

Issues commonly associated with the use of this type of equipment are as follows:

- (a) The movement of the equipment around the site.
- (b) The verification of the installation after relocation.
- (c) The control of touch voltages.
- (d) The control of transfer voltages due to earth potential rise.
- (e) Lightning protection.
- (f) The operation of switchgear in a confined area.
- (g) The change of operating location and the resulting impact on system characteristics including verification of the electrical protection devices settings under the new conditions and location within the network.
- (h) Potential variability in the voltage at the point of connection and/or in the equipment being supplied.
- (i) The emergency removal of power.
- (j) Access to high voltage equipment.
- (k) Proximity to shot firing operations with respect to direct damage from overpressure waves, fly rock and excessive vibration.