

Australian/New Zealand Standard™

Explosive atmospheres

**Part 15: Equipment protection by type
of protection "n" (IEC 60079-15:2017
(ED.5.0) MOD)**

STANDARDS
Australia



STANDARDS®
NEW ZEALAND
PAEREWĀ AOTEAROA



AS/NZS 60079.15:2020

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee EL-014, Equipment for Explosive Atmospheres. It was approved on behalf of the Council of Standards Australia on 12 November 2019 and by the New Zealand Standards Approval Board on 18 December 2019.

This Standard was published on 24 January 2020.

The following are represented on Committee EL-014:

Auckland Business Chamber
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Institute of Petroleum
Australian Petroleum Production and Exploration Association
Australian Pipelines and Gas Association
Aviation & Marine Engineers Association
Bureau of Steel Manufacturers of Australia
Business New Zealand
Communications, Electrical and Plumbing Union — Electrical Trades Division
Queensland Department of Natural Resources, Mines and Energy
Electrical Compliance Testing Association (Australia)
Electrical Regulatory Authorities Council (Australia)
Electrical Safety New Zealand
Engineering New Zealand
Engineers Australia
Institute of Electrical Inspectors (Australia)
Institute of Instrumentation, Control and Automation Australia
Master Electricians (New Zealand)
Mining Electrical and Mining Mechanical Engineering Society
NSW Department of Planning, Industry and Environment
SafeWork NSW
University of Newcastle
WorkSafe New Zealand

This Standard was issued in draft form for comment as DR AS/NZS 60079.15:2019.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

ISBN 978 1 76072 714 7

Australian/New Zealand Standard™

Explosive atmospheres

Part 15: Equipment protection by type of protection "n" (IEC 60079-15:2017 (ED.5.0) MOD)

Originates as AS/NZS 60079.15:2006.
Previous edition 2011.
Third edition 2020.

COPYRIGHT

© IEC 2020 — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2020

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-014, Equipment for Explosive Atmospheres to supersede AS/NZS 60079.15:2011 *Explosive atmospheres, Part 15: Equipment protection by type of protection 'n'*.

The objective of this Standard is to specify requirements for the construction, testing and marking for Group II electrical equipment with type of protection “n” which includes sealed devices “nC”, hermetically sealed devices “nC”, non-incendive components “nC” and restricted breathing enclosures “nR” intended for use in explosive gas atmospheres.

This Standard applies to electrical equipment where the rated input voltage does not exceed 15 kV a.c.s. AC or DC including where the internal working voltages of the Ex product exceeds 15 kV, for example starters for HID luminaires.

This Standard supplements and modifies the general requirements of AS/NZS 60079.0, except as indicated in [Table 1](#). Where a requirement of this Standard conflicts with a requirement of AS/NZS 60079.0, the requirement of this Standard takes precedence.

Table 1 — Relationship of AS/NZS 60079.15 to AS/NZS 60079.0

Clause of AS/NZS 60079.0			AS/NZS 60079.0 clause application to AS/NZS 60079.15	
Ed. 6.0 (2011) (informative)	Ed. 7.0 (future edition) (informative)	Clause/Subclause title (normative)	Protected sparking “nC”	Restricted breathing “nR”
3	3	Definitions	Applies	Applies
4	4	Equipment grouping		
4.1	4.1	Group I	Excluded	Excluded
4.2	4.2	Group II	Applies	Applies
4.3	4.3	Group III	Excluded	Excluded
4.4	4.4	Equipment for a particular explosive atmosphere	Applies	Applies
5	5	Temperatures		
5.1	5.1	Environmental influences	Applies	Applies
5.2	5.2	Service temperature	Applies	Applies
5.3	5.3	Maximum surface temperature		
5.3.1	5.3.1	Determination of maximum surface temperature	Applies	Applies
5.3.2	5.3.2	Limitation of maximum surface temperature		
5.3.2.1	5.3.2.1	Group I equipment	Excluded	Excluded
5.3.2.2	5.3.2.2	Group II equipment	Applies	Applies
5.3.2.3	5.3.2.3	Group III equipment	Excluded	Excluded
5.3.3	5.3.3	Small component temperature for Group I and Group II equipment	Applies	Excluded

Table 1 (continued)

Clause of AS/NZS 60079.0			AS/NZS 60079.0 clause application to AS/NZS 60079.15	
Ed. 6.0 (2011) (informative)	Ed. 7.0 (future edition) (informative)	Clause/Subclause title (normative)	Protected sparking "nC"	Restricted breathing "nR"
-	5.3.4	Component temperature of smooth surfaces for Group I or Group II equipment (Applies for smaller than 10 000 mm ² only)	Applies	Excluded
6	6	Requirements for all electrical apparatus		
6.1	6.1	General	Applies	Applies
6.2	6.2	Mechanical strength	Applies	Applies
6.3	6.3	Opening times	Excluded	Applies
6.4	6.4	Circulating currents	Applies	Applies
6.5	6.5	Gasket retention	Applies	Applies
6.6	6.6	Electromagnetic and ultrasonic radiating equipment	Applies	Applies
7	7	Non-metallic enclosures and non-metallic parts of enclosures		
7.1	7.1	General		
7.1.1	7.1.1	Applicability	Applies	Applies
7.1.2	7.1.2	Specification of materials	Applies	Applies
7.2	7.2	Thermal endurance		
7.2.1	7.2.1	Tests for thermal resistance	Applies	Applies
7.2.2	-	Material selection	Modified	Modified
-	7.2.2	Material selection	Applies	Applies
7.2.3	7.2.3	Alternative qualification for elastomeric sealing O-rings	Applies	Applies
7.3	7.3	Resistance to ultraviolet light	Applies	Applies
7.4	7.4	Electrostatic charges on external non-metallic materials		
7.4.1	7.4.1	Applicability	Applies	Applies
7.4.2	7.4.2	Avoidance of build-up of electrostatic charge on Group I or Group II electrical equipment	Applies	Applies
7.4.3	7.4.3	Avoidance of build-up of electrostatic charge on equipment for Group III	Excluded	Excluded

Table 1 (continued)

Clause of AS/NZS 60079.0			AS/NZS 60079.0 clause application to AS/NZS 60079.15	
Ed. 6.0 (2011) (informative)	Ed. 7.0 (future edition) (informative)	Clause/Subclause title (normative)	Protected sparking "nC"	Restricted breathing "nR"
7.5	7.5	External conductive parts	Applies	Applies
8	8	Metallic enclosures and metallic parts of enclosures		
8.1	8.1	Material composition	Applies	Applies
8.2	8.2	Group I	Excluded	Excluded
8.3	8.3	Group II	Applies	Applies
8.4	8.4	Group III	Excluded	Excluded
NR	8.5	Copper alloys	Applies	Applies
9	9	Fasteners		
9.1	9.1	General	Applies	Applies
9.2	9.2	Special fasteners	Excluded	Excluded
9.3	9.3	Holes for special fasteners	Excluded	Excluded
9.3.3	-	Hexagon socket set screws	Excluded	Excluded
-	9.4	Hexagon socket set screws	Excluded	Excluded
10	10	Interlocking devices	Excluded	Excluded
11	11	Bushings	Applies	Applies
12	-	Materials used in cementing	Modified	Modified
-	12	Reserved for future use	Excluded	Excluded
13	13	Access components	Applies	Applies
14	14	Connection facilities	Applies	Applies
15	15	Connection facilities for earthing and bonding conductors	Applies	Applies
16	16	Entries into enclosures	Applies	Applies
17	17	Supplementary requirements for electric machines	Excluded	Excluded
18	18	Supplementary requirements for switchgear	Excluded	
18.1	18.1	Flammable dielectric	Excluded	Applies
18.2	18.2	Disconnectors	Excluded	Applies
18.3	18.3	Group I – Provisions for locking	Excluded	Excluded
18.4	18.4	Doors and covers	Excluded	Applies
19	-	Supplementary requirements for fuses	Excluded	Excluded

Table 1 (continued)

Clause of AS/NZS 60079.0			AS/NZS 60079.0 clause application to AS/NZS 60079.15	
Ed. 6.0 (2011) (informative)	Ed. 7.0 (future edition) (informative)	Clause/Subclause title (normative)	Protected sparking "nC"	Restricted breathing "nR"
-	19	Reserved for future use.	Excluded	Excluded
20	20	Supplementary requirements for plugs and sockets		
20.1	20.1	General	Applies	Applies
20.2	20.2	Explosive gas atmospheres	Excluded	Excluded
20.3	20.3	Explosive dust atmospheres	Excluded	Excluded
20.4	20.4	Energized plugs	Applies	Applies
21	21	Supplementary requirements for luminaires		
21.1	21.1	General	Applies	Applies
21.2	21.2	Covers for luminaires of EPL Mb, EPL Gb or EPL Db	Excluded	Excluded
21.3	21.3	Covers for luminaires of EPL Gc or EPL Lc	Applies	Applies
21.4	21.4	Sodium lamps	Applies	Applies
22	22	Supplementary requirements for caplights and handlights		
22.1	22.1	Group I caplights	Excluded	Excluded
22.2	22.2	Group II and Group III caplights and handlights	Excluded	Applies
23	23	Equipment incorporating cells and batteries	Applies	Applies
23.12	23.12	Replacement battery pack	Applies	Applies
24	24	Documentation	Modified	Modified
25	25	Compliance of prototype or sample with documents	Applies	Applies
26	26	Type tests	Applies	Applies
26.4	26.4	Tests of enclosures		
26.4.1	26.4.1	Order of tests		
26.4.1.1	26.4.1.1	Metallic enclosures, metallic parts of enclosures and glass or ceramic parts of enclosures	Applies	Applies

Table 1 (continued)

Clause of AS/NZS 60079.0			AS/NZS 60079.0 clause application to AS/NZS 60079.15	
Ed. 6.0 (2011) (informative)	Ed. 7.0 (future edition) (informative)	Clause/Subclause title (normative)	Protected sparking "nC"	Restricted breathing "nR"
26.4.1.2	26.4.1.2	Non-metallic enclosures or non-metallic parts of enclosures		
26.4.1.2.1	26.4.1.2.1	General	Applies	Applies
26.4.1.2.2	26.4.1.2.2	Group I electrical equipment	Excluded	Excluded
26.4.1.2.3	-	Group II and Group III electrical equipment	Modified	Modified
-	26.4.1.2.3	Group II and Group III electrical equipment	Applies	Applies
26.4.2	26.4.2	Resistance to impact	Applies	Applies
26.4.3	26.4.3	Drop test	Applies	Applies
26.4.4	26.4.4	Acceptance criteria	Applies	Applies
26.4.5	26.4.5	Degree of protection by enclosure	Applies	Applies
26.5	26.5	Thermal tests		
26.5.1	26.5.1	Temperature measurement	Applies	Applies
26.5.1.1	26.5.1.1	General	Applies	Applies
26.5.1.2	26.5.1.2	Service Temperature	Applies	Applies
26.5.2	26.5.2	Thermal shock test	Applies	Applies
26.5.3	26.5.3	Small component ignition test (Group I and Group II)	Applies	Excluded
26.6	26.6	Torque test for bushings	Applies	Applies
26.7	26.7	Non-metallic enclosures or non-metallic parts of enclosures		
26.7.1	26.7.1	General	Applies	Applies
26.7.2	-	Test temperatures	Modified	Modified
-	26.7.2	Test temperatures	Applies	Applies
26.8	-	Thermal endurance to heat	Modified	Modified
-	26.8	Thermal endurance to heat	Applies	Applies
26.9	26.9	Thermal endurance to cold	Applies	Applies
26.10	26.10	Resistance to light		
26.10.1	26.10.1	General	Applies	Applies
26.10.2	26.10.2	Light exposure	Applies	Applies
26.10.3	26.10.3	Acceptance criteria	Applies	Applies

Table 1 (continued)

Clause of AS/NZS 60079.0			AS/NZS 60079.0 clause application to AS/NZS 60079.15	
Ed. 6.0 (2011) (informative)	Ed. 7.0 (future edition) (informative)	Clause/Subclause title (normative)	Protected sparking "nC"	Restricted breathing "nR"
26.11	26.11	Resistance to chemical agents for Group I electrical equipment	Excluded	Excluded
26.12	26.12	Earth continuity	Applies	Applies
26.13	26.13	Surface resistance test of parts of enclosures of non-metallic materials	Applies	Applies
26.14	26.14	Measurement of capacitance		
26.14.1	26.14.1	General	Applies	Applies
26.14.2	26.14.2	Test procedure	Applies	Applies
26.15	26.15	Verification of ratings of ventilating fans	Excluded	Excluded
26.16	26.16	Alternative qualification of elastomeric sealing O-rings	Applies	Applies
-	26.17	Transferred charge test	Applies	Applies
27	27	Routine tests	Applies	Applies
28	28	Manufacturers responsibility	Applies	Applies
29	29	Marking		
29.1	29.1	Approved symbols	Applies	Applies
29.2	29.2	Location	Applies	Applies
29.3	29.3	General	Applies	Applies
29.4	29.4	Ex marking for explosive gas atmospheres	Applies	Applies
29.5	29.5	Ex marking for explosive dust atmospheres	Excluded	Excluded
29.6	29.6	Combined types (or levels) of protection	Applies	Applies
29.7	29.7	Multiple types of protection	Applies	Applies
29.8	29.8	Ga equipment using two independent Gb types (or levels) of protection	Excluded	Excluded
-	29.9	Boundary wall	Excluded	Excluded
29.9	29.10	Ex Components	Applies	Applies
29.10	29.11	Small Ex Equipment and small Ex Components	Applies	Applies

Table 1 (continued)

Clause of AS/NZS 60079.0			AS/NZS 60079.0 clause application to AS/NZS 60079.15	
Ed. 6.0 (2011) (informative)	Ed. 7.0 (future edition) (informative)	Clause/Subclause title (normative)	Protected sparking "nC"	Restricted breathing "nR"
29.11	29.12	Extremely small equipment and extremely small Ex Components	Applies	Applies
29.12	29.13	Warning markings	Applies	Applies
29.13	-	Alternate marking of equipment protection levels (EPLs)	Applies	Applies
29.13.1	-	Alternate marking of type of protection for explosive gas atmospheres	Applies	Applies
29.13.2	-	Alternate marking of type of protection for explosive dust atmospheres	Excluded	Excluded
29.14	29.14	Cells and batteries	Applies	Applies
29.15	29.15	Electrical machines operated with a converter	Applies	Applies
29.16	29.16	Examples of marking	Examples only	Examples only
30	30	Instructions		
30.1	30.1	General	Applies	Applies
30.2	30.2	Cells and batteries	Applies	Applies
30.3	30.3	Electric machines	Excluded	Excluded
30.4	30.4	Ventilating fans	Excluded	Excluded
-	30.5	Cable glands	Applies	Applies
Annex A	Annex A	Supplementary requirements for Ex cable glands	Applies	Applies
Annex B	Annex B	Requirements for Ex components	Applies	Applies
Annex C	Annex C	Example of rig for resistance to impact test	Informative Annex	Informative Annex
Annex D	Annex D	Motors supplied by converters	Informative Annex	Informative Annex
Annex E	Annex E	Temperature evaluation of electric machines	Informative Annex	Informative Annex
Annex F	Annex F	Guideline flowchart for tests of non-metallic enclosures or non-metallic parts of enclosures (26.4)	Informative Annex	Informative Annex
-	Annex G	Guidance flowchart for tests of cable glands	Informative Annex	Informative Annex

Table 1 (continued)

Clause of AS/NZS 60079.0			AS/NZS 60079.0 clause application to AS/NZS 60079.15	
Ed. 6.0 (2011) (informative)	Ed. 7.0 (future edition) (informative)	Clause/Subclause title (normative)	Protected sparking "nC"	Restricted breathing "nR"
-	Annex H	Shaft voltages resulting in motor bearing or shaft brush sparking. Discharge energy calculation	Informative Annex	Informative Annex
Applies – This requirement of AS/NZS 60079.0 is applied without change.				
Excluded – This requirement of AS/NZS 60079.0 does not apply.				
Modified – This requirement of AS/NZS 60079.0 is modified as detailed in this standard.				
NOTE 1 The clause number in the above table is shown for information only. The applicable requirements of AS/NZS 60079.0 are identified by the clause title which is normative. This document was written against the specific requirements of IEC 60079-0 (ed. 7.0). The clause numbers for the previous edition are shown for information only. This is to enable the general requirements of AS/NZS 60079.0 to be used where necessary with this Standard. Where there is a conflict between requirements, the later edition requirements take precedence.				
NOTE 2 In cases where the applicability is the same for all of the sub-clauses the 'Applies' or 'Excluded' is listed in the heading row and the sub-clauses are not expanded. Where the application of the individual sub-clauses may be different, these are expanded in the above table and the applicability for each is listed.				
NOTE 3 A non-incendive component is limited in use to the particular circuit for which it has been shown to be non-ignition capable and, therefore, cannot be separately assessed as complying with this standard.				

This Standard is an adoption with national modifications, and has been reproduced from, IEC 60079-15:2017, *Explosive atmospheres — Part 15: Equipment protection by type of protection "n"*. The modifications are additional requirements and are set out in Appendix ZZ, which has been added at the end of the source text.

Appendix ZZ lists the variations to IEC 60079-15:2017 for the application of this Standard in Australia and New Zealand.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text "this part of IEC 60079" should read "this Australian/New Zealand Standard".
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms "normative" and "informative" are used in Standards to define the application of the appendices or annexes to which they apply. A "normative" appendix or annex is an integral part of a Standard, whereas an "informative" appendix or annex is only for information and guidance.

CONTENTS

FOREWORD	4
1 Scope	9
2 Normative references	15
3 Terms and definitions	16
4 General	17
4.1 Equipment grouping and temperature classification	17
4.2 Potential ignition sources	17
4.3 Equipment requirements	17
5 Maximum surface temperatures	17
6 Requirements for electrical equipment	18
6.1 General	18
6.2 Electric strength insulation from earth or frame	18
7 Requirements for non-incendive components	18
7.1 Type testing	18
7.2 Circuit limitations	18
8 Requirements for hermetically sealed devices	18
9 Requirements for sealed devices	19
9.1 Non-metallic materials	19
9.2 Opening	19
9.3 Internal spaces	19
9.4 Handling	19
9.5 Gasket and seals	19
9.6 Type tests	19
10 Requirements for restricted-breathing enclosures	19
10.1 General	19
10.2 Constructional requirements	20
10.2.1 Type of equipment	20
10.2.2 Cells and batteries	20
10.2.3 Cable glands and conduit entries	20
10.2.4 Operating rods, spindles and shafts	21
10.2.5 Windows	21
10.2.6 Gasket and seal requirements	21
10.2.7 Non-resilient seals	21
10.2.8 Test port	22
10.2.9 Internal fans	23
10.3 Temperature limitation	23
10.4 Additional requirements for restricted-breathing luminaires	23
10.4.1 Mounting arrangement	23
10.4.2 Reflectors	23
10.4.3 Surface temperatures of restricted-breathing luminaires	23
11 Type Tests	24
11.1 Tests for non incendive components	24
11.1.1 Preparation of non-incendive component samples	24
11.1.2 Test conditions for non-incendive components	24
11.2 Tests for sealed devices	25

11.2.1	Conditioning	25
11.2.2	Voltage test	25
11.2.3	Leakage tests on sealed devices	25
11.3	Type test requirements for restricted-breathing enclosures	26
11.3.1	General	26
11.3.2	Equipment where the volume of the enclosure will be unchanged due to pressure	26
11.3.3	Alternative type test for equipment where the volume of the enclosure changes due to pressure	26
12	Routine verifications and tests	27
12.1	Electric strength test	27
12.2	Routine test requirements for restricted-breathing enclosures	27
12.2.1	General	27
12.2.2	Test procedure	27
12.3	Routine temperature rise test	28
12.4	Temperature calculation	28
13	Marking	29
13.1	General	29
13.2	Examples of marking	29
13.3	Warning markings	29
14	Documentation	29
15	Instructions	30
	Bibliography	31
	Table 1 – Relationship of IEC 60079-15 to IEC 60079-0	9
	Table 2 – Text of warning markings	29

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –

Part 15: Equipment protection by type of protection "n"

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-15 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This fifth edition cancels and replaces the fourth edition, published in 2010, and constitutes a technical revision.

This edition includes the following significant changes with respect to the previous edition:

The text of this International Standard is based on the following documents:

FDIS	Report on voting
31/1339/FDIS	31/1355/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This International Standard is to be read in conjunction with IEC 60079-0.

A list of all parts of the IEC 60079 series, under the general title: *Explosives atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

Changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Requirements for enclosed break devices have been removed	-			C1
Requirements for type of protection "nA" has been removed	-			C2
Scope has been updated to allow equipment with internal working voltages over 15 kV such as starters for HID luminaires	1		X	
Definition for cable sealing box removed	3	X		
Definitions for creepage distance and clearance removed as they are now in 60079-0	3	X		
Definition of non-sparking device "nA" removed, as the concept has been transferred to 60079-7	3			C2
Definition of duty cycle removed	3	X		
Definition of enclosed break device moved as the concept has been transferred to 60079-1	3			C1
Definition of hermetically sealed device revised	3	A1		
Definition for normally sparking device added	3.2	X		
Small component temperature clause removed, part of moving type of protection "nA" to 60079-7	5			C2
Minimum degree of protection requirements; clearance, creepage and separation requirements; determination of working voltage; conformal coating; CTI requirement; Insulation between conductive parts and measurement of creepage and clearance requirements have been removed.	6			C2
Connection facilities and terminal compartment requirements have been removed	-			C2
Supplementary requirements for non-sparking electrical rotating machines have been removed	-			C2
Supplementary requirements for non-sparking fuses and fuse assemblies have been removed	-			C2
Supplementary requirements for non-sparking plugs and sockets have been removed	-			C2
Supplementary requirements for non-sparking luminaires have been removed	-			C2
Supplementary requirements for equipment incorporating non-sparking cells and batteries have been removed	-			C2
Supplementary requirements for non-sparking low power equipment have been removed	-			C2
Supplementary requirements for non-sparking current transformers have been removed	-			C2
Requirements for other non-sparking electrical equipment have been removed	-			C2
General supplementary requirements for equipment producing arcs, sparks or hot surfaces have been removed	-			C2
Requirements for enclosed break devices have been removed	-			C1
Voltage and current limitations added for non-incendive components.	7.2			C6

Changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
The requirements for sealed devices have been extended to require more documentation,	9.1		X	
The +20K requirement for luminaire materials has been removed	9.5			C2
Notes 1-3 have been removed, as this information is covered elsewhere	10.1	X		
Entry device requirements added	10.1		X	
Industrial standard compliance and battery requirements added	10.2.1.2		X	
The exemption for manually operated sparking devices moved to here, creepage and clearance requirements in industrial standards added for switching devices, and cell and battery requirements added	10.2.1.2		X	
Requirements for cable glands and conduit entries have been clarified	10.2.3	X		
Requirements for gasketed windows expanded to allow a removable window mounted in a frame.	10.2.5.2		X	
Requirement to include documentation on the thermal stability of gaskets or seals added	10.2.6			C4
Requirements reworded for clarity	10.2.7	X		
Requirements for "nR" enclosures fitted with fans added.	10.2.9			C5
Type test requirements for enclosed break "nC" and "nA" equipment removed	-			C1, C2
The dielectric test after the leakage test for sealed devices has been eliminated unless the results of the leakage test are uncertain.	11.2.2		X	
Tests for sealed devices, screw lampholders, starters, lamps, ignitors, and ignitor pulses for luminaires have been removed	-			C2
All testing for batteries has been removed.	-			C2
All testing for electrical machines removed	-			C2
Routine test requirements re-written for sealed components, non-incendive components and restricted breathing equipment to take out the testing for enclosed break and nA equipment	12			C1, C2
Preparation of non-incendive component samples	11.1.1			C3
Marking requirements modified to remove labelling requirements for enclosed break components, nA equipment, and batteries.	-			C1, C2
Documentation requirements modified to remove to remove labelling requirements for enclosed break components, nA equipment, and batteries.	14			C1, C2
The instruction section has been expanded to include new requirements	15		X	
Annex A has been removed.	-			C2

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version.

Explanation of the types of changes:

A) Definitions

1) **Minor and editorial changes:**

- Clarification
- Decrease of technical requirements
- Minor technical change
- Editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

2) **Extension:** Addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

3) **Major technical changes:**

- addition of technical requirements
- increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in Clause B below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of changes

- A1 – It was determined that this was already covered by the sealed device definition
- C1 – Enclosed break devices “nC” are now designated as “dc” and the requirements are located in IEC 60079-1:2014.
- C2 – Type of protection “nA” is now designated as type of protection “ec” and the requirements for “ec” equipment are located in IEC 60079-7:2015.
- C3 – Test time for the preparation of non-incendive component samples has been specified.
- C4 – Additional documentation requirements for seals and gaskets.
- C5 – As the pressure inside an enclosure fitted with fans can be affected by the operation of the fan, it is now specified that the restricted breathing test is conducted with fans operating and stationary.
- C6 – The limitations from IEC 60079-15 Ed 3 were added.

EXPLOSIVE ATMOSPHERES –

Part 15: Equipment protection by type of protection "n"

1 Scope

This part of IEC 60079 specifies requirements for the construction, testing and marking for Group II electrical equipment with type of protection "n" which includes; sealed devices "nC", hermetically sealed devices "nC", non-incendive components "nC" and restricted breathing enclosures "nR" intended for use in explosive gas atmospheres. This part of IEC 60079 applies to electrical equipment where the rated input voltage does not exceed 15 kV r.m.s. AC or DC including where the internal working voltages of the Ex product exceeds 15 kV, for example starters for HID luminaires.

This part of IEC 60079 supplements and modifies the general requirements of IEC 60079-0, except as indicated in Table 1. Where a requirement of this part of IEC 60079 conflicts with a requirement of IEC 60079-0, the requirement of this part of IEC 60079 takes precedence.

Table 1 – Relationship of IEC 60079-15 to IEC 60079-0

Clause of IEC 60079-0			IEC 60079-0 clause application to IEC 60079-15	
Ed. 6.0 (2011) (informative)	Ed. 7.01 (future edition) (informative)	Clause / Subclause title (normative)	Protected sparking "nC"	Restricted breathing "nR"
3	3	Definitions	Applies	Applies
4	4	Equipment grouping		
4.1	4.1	Group I	Excluded	Excluded
4.2	4.2	Group II	Applies	Applies
4.3	4.3	Group III	Excluded	Excluded
4.4	4.4	Equipment for a particular explosive atmosphere	Applies	Applies
5	5	Temperatures		
5.1	5.1	Environmental influences	Applies	Applies
5.2	5.2	Service temperature	Applies	Applies
5.3	5.3	Maximum surface temperature		
5.3.1	5.3.1	Determination of maximum surface temperature	Applies	Applies
5.3.2	5.3.2	Limitation of maximum surface temperature		
5.3.2.1	5.3.2.1	Group I equipment	Excluded	Excluded
5.3.2.2	5.3.2.2	Group II equipment	Applies	Applies
5.3.2.3	5.3.2.3	Group III equipment	Excluded	Excluded

¹ Under preparation. Stage at the time of publication: IEC/FDIS 60079-0:2017.