

Australian/New Zealand Standard™

Explosive atmospheres

Part 29.4: Gas detectors—Performance requirements of open path detectors for flammable gases



AS/NZS 60079.29.4:2011

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-014, Explosive Atmospheres. It was approved on behalf of the Council of Standards Australia on 1 June 2011 and on behalf of the Council of Standards New Zealand on 13 May 2011.
This Standard was published on 20 June 2011.

The following are represented on Committee EL-014:

Auckland Regional Chamber of Commerce
Australian Chamber of Commerce and Industry
Australian Coal Association
Australian Industry Group
Australian Institute of Petroleum
Australian Institute of Refrigeration Air Conditioning and Heating
Australian Petroleum Production and Exploration Association
Australian Pipeline Industry Association
Bureau of Steel Manufacturers of Australia
Consult Australia
Department of Industry and Investment NSW
Department of Mines and Energy, Qld
Electrical Compliance Testing Association
Electrical Contractors Association of New Zealand
Electrical Regulatory Authorities Council
Energy Networks Association
Engineers Australia
Environmental Protection Authority New Zealand
Institute of Electrical Inspectors
Institute of Instrumentation, Control and Automation Australia
Institution of Professional Engineers New Zealand
Mining Electrical and Mining Mechanical Engineering Society
Ministry of Economic Development (New Zealand)
National Electrical and Communications Association
New Zealand Employers and Manufacturers Association (Central)
The Aviation and Marine Engineers Association
WorkCover New South Wales

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 60079.29.4.

Australian/New Zealand Standard™

Explosive atmospheres

Part 29.4: Gas detectors—Performance requirements of open path detectors for flammable gases

First published as AS/NZS 60079.29.4:2011.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

ISBN 978 0 7337 9877 1

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-014, Explosive Atmospheres.

The objective of this Standard is to establish the specific requirements for design, construction and performance testing of electrical equipment for open path detection of flammable gases and vapours. It is complementary to AS/NZS 60079.29.1, which applies to the other detection techniques available for this purpose. It is intended to be read in conjunction with AS/NZS 60079.0 for its electrical protection.

This Standard is identical with, and has been reproduced from, IEC 60079-29-4 Ed.1.0 (2009), *Explosive atmospheres, Part 29-4: Gas detectors—Performance requirements of open path detectors for flammable gases*.

As this Standard is reproduced from an international standard, the following applies:

- (a) Its number appears on the cover and title page while the international standard number appears only on the cover.
- (b) In the source text ‘this part of IEC 60079-29’ should read ‘this part of AS/NZS 60079.29’.
- (c) A full point substitutes for a comma when referring to a decimal number.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
IEC		AS/NZS	
60079	Explosive atmospheres	60079	Explosive atmospheres
60079-0	Part 0: Equipment—General requirements	60079.0	Part 0: Equipment—General requirements
60079-29-1	Part 29-1: Gas detectors—Performance requirements of detectors for flammable gases	60079.29.1	Part 29.1: Gas detectors—Performance requirements of detectors for flammable gases

Only normative references that have been adopted as Australian or Australian/New Zealand Standards have been listed.

It should be noted that many other parts of IEC 60079 are now published as identically-numbered parts of AS/NZS 60079. The latter should be referenced when necessary.

The term ‘informative’ has been used in this Standard to define the application of the annex to which it applies. An ‘informative’ annex is only for information and guidance.

CONTENTS

1	Scope	6
2	Normative references	7
3	Terms and definitions	7
3.1	Equipment	7
3.2	Alarms	8
3.3	Signals and indications	8
3.4	Gaseous atmospheres	8
3.5	Optical equipment	9
3.6	Performance characteristics	10
4	General requirements	11
4.1	Detection equipment	11
4.1.1	Components	11
4.1.2	Electrical assemblies and components	11
4.1.3	Optical radiation	11
4.2	Construction	11
4.2.1	General	11
4.2.2	Indicating devices	11
4.2.3	Alarm or output functions	12
4.2.4	Fault signals	12
4.2.5	Adjustments	12
4.3	Software-controlled equipment	12
4.3.1	Conversion errors	13
4.3.2	Software	13
4.3.3	Data transmission	13
4.3.4	Self-test routines	13
4.3.5	Functional concept	14
5	Test requirements	14
5.1	Introduction	14
5.2	General requirements for tests	15
5.2.1	Sample and sequence of tests	15
5.2.2	Conformity checks	15
5.2.3	Preparation of samples	15
5.2.4	Equipment for calibration and test	16
5.3	Normal conditions for test	18
5.3.1	General	18
5.3.2	Operating distance for laboratory tests	18
5.3.3	Test gases	18
5.3.4	Test gas integral concentrations	18
5.3.5	Voltage	19
5.3.6	Ambient temperature	19
5.3.7	Ambient humidity	19
5.3.8	Ambient atmosphere	19
5.3.9	Preparation of equipment	19
5.3.10	Stabilization	19
5.3.11	Communications options	20

5.3.12	Gas detection equipment as part of systems.....	20
5.4	Test methods	20
5.4.1	Initial preparation and procedure	20
5.4.2	Unpowered storage	20
5.4.3	Calibration curve (not applicable to alarm only equipment with fixed settings)	20
5.4.4	Stability	21
5.4.5	Alarm reliability.....	21
5.4.6	Temperature variation	22
5.4.7	Water vapour interference	23
5.4.8	Vibration.....	23
5.4.9	Drop test for portable and transportable equipment	24
5.4.10	Alignment.....	24
5.4.11	Time of response.....	25
5.4.12	Minimum time to operate (spot-reading equipment)	25
5.4.13	Battery capacity.....	25
5.4.14	Power supply variations (externally powered equipment).....	26
5.4.15	Power supply interruptions and transients	27
5.4.16	Recovery from power supply interruption.....	27
5.4.17	Electromagnetic compatibility (EMC)	27
5.4.18	Beam block fault.....	28
5.4.19	Partial obscuration.....	28
5.4.20	Long range operation	29
5.4.21	Direct solar radiation (applicable for equipment intended for outdoor use).....	29
6	Field verification equipment.....	30
7	Information for use	30
7.1	Labelling and marking	30
7.2	Instruction manual.....	30
	Annex A (informative) Water vapour test apparatus	32
	Bibliography.....	33
	Figure 1 – Equipment for gas calibration and speed of response test.....	17
	Figure A. – Water vapour test apparatus.....	32

AUSTRALIAN/NEW ZEALAND STANDARD

Explosive atmospheres

Part 29.4:

Gas detectors—Performance requirements of open path detectors for flammable gases**1 Scope**

This part of IEC 60079-29 specifies performance requirements of equipment for the detection and measuring of flammable gases or vapours in ambient air by measuring the spectral absorption by the gases or vapours over extended optical paths, ranging typically from one metre to a few kilometres.

Such equipment measures the integral concentration of the absorbing gas over the optical path in units such as LFL metre for flammable gases.

NOTE 1 Actual values of concentration can be deduced only where it can be established that the concentration is uniform over the optical path, for example in very short optical paths (<100 mm). In such cases, the equipment is within the scope of IEC 60079-29-1.

NOTE 2 This standard is based upon present absorption techniques using infrared radiation. Other techniques and applications may require additional test considerations (e.g. pressure test).

Equipment falling within the scope of this standard is classified by the following types:

Type 1: an optical transmitter and receiver, located at either end of a path through the atmosphere to be monitored.

Type 2: an optical transceiver (i.e. combined transmitter and receiver) and a suitable reflector, which may be a topographic feature or a retroreflector, located at either end of a path through the atmosphere to be monitored.

This standard is also applicable when an equipment manufacturer makes any claims regarding any special features of construction or superior performance that exceed the minimum requirements of this standard. All such claims shall be verified and the test procedures should be extended or supplemented, where necessary, to verify the claimed performance. The additional tests shall be agreed between the manufacturer and the test laboratory and identified and described in the test report.

This standard does not apply to any of the following:

- a) equipment intended to provide range resolution of gas concentration (e.g. Light direction and ranging (LIDAR));
- b) equipment consisting of a passive optical receiver without a dedicated optical source;
- c) equipment intended to measure the local volumetric concentration of gas (point sensors);
- d) equipment intended for the detection of dusts or mists in air;
- e) equipment for cross stack monitoring;
- f) equipment intended for the detection of explosives; and
- g) equipment intended only for the identification of individual gas or vapour components, (e.g. Fourier transform infrared spectroscopy (FTIR)).

This standard is applicable to equipment which is intended for use in hazardous or non-hazardous areas, or both. Equipment for use in hazardous areas is also required to have explosion protection (see 4.1.1).