

Australian/New Zealand Standard™

Explosive atmospheres

**Part 33: Equipment protection by
special protection 's'**



AS/NZS 60079.33:2012

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-014, Equipment for Explosive Atmospheres. It was approved on behalf of the Council of Standards Australia on 14 November 2012 and on behalf of the Council of Standards New Zealand on 29 October 2012.
This Standard was published on 30 November 2012.

The following are represented on Committee EL-014:

Auckland Regional Chamber of Commerce
Australian Chamber of Commerce and Industry
Australian Coal Association
Australian Industry Group
Australian Institute of Petroleum
Australian Institute of Refrigeration Air Conditioning and Heating
Australian Petroleum Production and Exploration Association
Australian Pipeline Industry Association
Aviation and Marine Engineers Association
Bureau of Steel Manufacturers of Australia
Department of Natural Resources and Mines, Qld
Electrical Compliance Testing Association
Electrical Contractors Association of New Zealand
Electrical Regulatory Authorities Council
Energy Networks Association
Engineers Australia
Environmental Protection Authority New Zealand
Institute of Electrical Inspectors
Institute of Instrumentation, Control & Automation Australia
Institution of Professional Engineers New Zealand
Mining Electrical and Mining Mechanical Engineering Society
Ministry of Economic Development New Zealand
National Electrical and Communications Association
New Zealand Employers and Manufacturers Association (Central)
NSW Department of Trade and Investment, Regional Infrastructure and Services
Workcover New South Wales

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To remain in their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS IEC 60079.33.

Australian/New Zealand Standard™

Explosive atmospheres

**Part 33: Equipment protection by
special protection type**

First published as AS/NZS 60079.33:2012.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

ISBN 978 1 74342 312 7

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-014, Equipment for Explosive Atmospheres.

The objective of this Standard is to provide requirements and the specific methodology for the assessment, testing and marking of electrical equipment, parts of electrical equipment and Ex components with special protection 's'.

This Standard is identical with, and has been reproduced from IEC 60079-33, Ed.1.0 (2012), *Explosive atmospheres: Part 33: Equipment protection by special protection 's'*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number appears on the cover and title page while the International Standard number appears only on the cover.
- (b) In the source text 'this part of IEC 60079' should read 'this Australian/New Zealand Standard'.
- (c) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

*Reference to International Standard**Australian/New Zealand Standard*

IEC 61508 (all parts)	Functional safety of electrical/electronic/programmable electronic safety-related systems	AS 61508 (all parts)	Functional safety of electrical/electronic/programmable electronic safety-related systems
62061	Safety of machinery—Functional safety of safety-related electrical, electronic and programmable electronic control systems	62061	Safety of machinery—Functional safety of safety-related electrical, electronic and programmable electronic control systems
IEC 61511 (all parts)	Functional safety—Safety instrumented systems for the process industry sector	AS IEC 61511 (all parts)	Functional safety—Safety instrumented systems for the process industry sector
IEC 60079 60079-0	Explosive atmospheres Part 0: Equipment—General requirements	AS/NZS 60079 60079.0	Explosive atmospheres Part 0: Equipment—General requirements
60079-29-1	Part 29-1: Gas detectors—Performance requirements of detectors for flammable gases	60079.29.1	Part 29.1: Gas detectors—Performance requirements of detectors for flammable gases
60079-29-2	Part 29-2: Gas detectors—Selection, installation, use and maintenance of detectors for flammable gases and oxygen	60079.29.2	Part 29.2: Gas detectors—Selection, installation, use and maintenance of detectors for flammable gases and oxygen

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

CONTENTS

1	Scope	9
2	Normative references	9
3	Terms and definitions	10
4	General	11
4.1	Application	11
4.2	Equipment group and temperature classification.....	11
4.3	Level of protection (equipment protection level (EPL)).....	11
4.4	Manufacturer's justification	12
4.5	Verification	12
5	Independent verifier.....	12
5.1	General	12
5.2	Competence	12
5.3	Duties.....	13
5.4	Acceptance	13
5.5	Independence.....	13
6	Design and construction	13
6.1	Principles of an integrated approach to explosion safety	13
6.2	Design and construction	14
6.3	Overloading of equipment.....	14
6.4	Potential ignition sources	14
6.4.1	Hazards arising from different ignition sources	14
6.4.2	Hazards arising from overheating	14
6.4.3	Hazards arising from pressure compensation operations	14
6.5	Requirements in respect of safety-related devices.....	14
7	Application of equipment protection levels (EPL)	15
7.1	Equipment with EPL Ma	15
7.2	Equipment with EPL Mb	15
7.3	Equipment with EPL Ga	16
7.4	Equipment with EPL Gb.....	17
7.5	Equipment with EPL Gc.....	17
7.6	Equipment with EPL Da	17
7.7	Equipment with EPL Db.....	18
7.8	Equipment with EPL Dc.....	18
8	Preparation of assessment and test specification	18
8.1	General	18
8.2	Assessment and test specification.....	19
8.3	Assessment and testing.....	19
8.4	Reporting results of the assessment and test specification.....	19
9	Ignition hazard assessment	19
9.1	General	19
9.2	Protective measures.....	19
9.3	Explanation of the ignition hazard assessment procedure.....	20
9.4	Examples of ignition hazard assessment	20
10	Application of special protection "s"	20

10.1	General	20
10.2	Justification for the application of special protection “s”	20
10.2.1	Application	20
10.2.2	Equipment substantially meeting the requirements for the recognized types of protection	21
10.2.3	Equipment outside the scope of recognized types of protection	21
10.2.4	Protection technique with no alignment to the recognized types of protection	21
10.2.5	Enhanced EPL through additional means of protection	22
10.2.6	Combination of approaches	22
10.3	Adaption of recognized types of protection	22
10.4	Other innovative means of ensuring safety	22
10.5	Connection of conductor and cables	22
11	Type verification and tests	23
11.1	General	23
11.2	Temperature measurement test	23
12	Routine verification and test	23
13	Documentation	23
14	Ex components	23
15	Marking	23
15.1	General	23
15.2	Marking for Ex “s” only	23
15.3	Marking for Ex “s” with other recognized types of protection	23
16	Certificate information	24
16.1	Certificate for Ex “s” only	24
16.2	Certificate for Ex “s” with other recognized types of protection	24
16.3	Specific conditions of use	24
16.4	Schedule of limitations	24
17	Instructions	24
	Annex A (informative) Explanation of the ignition hazard assessment procedure	25
	Annex B (informative) Examples of ignition hazard assessment	31
	Bibliography	37
	Figure A.1 – Relationship between ignitions source definitions	26
	Table A.1 – Recommended documentation of initial assessment of equipment related ignition sources	27
	Table A.2 – Example for reporting identification of ignition hazards (step 1) and first assessment (step 2)	28
	Table A.3 – Example for reporting determination of preventive or protective measures (step 3) and concluding estimation and EPL assignment (step 4)	29
	Table B.1 – Common cases demonstrating the use of the reporting method – Electrostatic discharge	33
	Table B.2 – Ignition hazard assessment report for a linear motor with permanent magnets in the table-track, EPL Gb, in addition to the basic requirements of IEC 60079-0 (for example material characteristics, electrostatic, earthing)	35

INTRODUCTION

This part of IEC 60079 was created in response to a request from the IECEx certification system to provide a set of requirements to be used for certification within the IECEx product certification scheme when the standards for existing types of protection were not applicable.

The present standard refers to the use of one or more independent verifiers, in accordance with ISO/IEC rules on the writing of standards that mitigate against specifying particular forms of conformity assessment. The IECEx system will specify how the term "independent verifier" will be interpreted for the purposes of the scheme. For example, it may specify that in the case of three independent verifiers they shall all be certification body members of the scheme, each accepted specifically for the purpose of assessing special protection applications and each from a separate member country of the system.

The purpose of IEC 60079-33 special protection "s" for any equipment protection level (EPL) is to allow design, assessment and testing of equipment or parts of equipment that cannot be fully assessed within a recognized type of protection or combination of recognized types of protection because of functional or operational limitations and where the desired equipment protection level can be achieved by the use of this standard.

Special protection "s" allows a design concept that cannot comply or run with recognized types of protection, or where the design concept is not covered by recognized types of protection.

When specification for the equipment includes aspects as given above, additional information and data may be required from

- technical research,
- evaluation of existing data and information.

Manufacturers should first consider the possibilities for design to the recognized types of protection, or to combinations of recognized types of protection, before proceeding to special protection "s".

This standard is intended to provide a framework to demonstrate how essential safety requirements can be met if not covered by established standards, thus allowing for innovation and dealing with unknowns.

When equipment intended to meet a recognized type of protection does not comply with all the provisions of the relevant standard, it is not to be considered under this standard unless:

- it can be clearly demonstrated that complete compliance with the type of protection is not practicable and
- additional measures have been applied to establish an equivalent protection level.

Special protection "s" is based on identification of failure modes and ignition hazard assessment in the identified modes. In this regard, the assessed safety of the assigned EPL of the equipment will satisfy the EPL requirements and, where appropriate, be at least equivalent to the EPL provided by the defined levels for the recognized types of protection.

IEC 60079-26 [1]¹ provides for requirements for equipment with EPL Ga and Ga/Gb but depends on combining types of protection already described in other parts of the IEC 60079 series.

The responsibility of initially demonstrating the need to design for special protection "s" and establishing the criteria for verification lies with the manufacturer. The specification defines

¹ Figures in square brackets refer to the Bibliography.

the safety concepts and shows how the essential safety requirements are to be achieved. It is likely this will be done in consultation with experts in the assessment of explosion protection techniques.

The requirements in this standard take into account:

- allowance for first, second or third party verification;
- the use of EPLs;
- the use of equipment groups for mining, gas and dust;
- alignment with existing temperature requirements;
- compatibility with the marking requirements given in IEC 60079-0.

Where requirements for a product/design concept are developed and intended for repeated use in subsequent designs, they should be reviewed and, provided the manufacturer is prepared to release the intellectual property, be included initially in an annex of this standard with the intention of being removed and relocated to an appropriate place at a later time, e.g. in an existing or new type of protection standard.

Unlike other recognized types of protection, special protection “s” may require the application of reliability engineering tools and procedures such as failure modes and effects analysis (FMEA), fault tree analysis (FTA) and failure modes, effects and criticality analysis (FMECA) to identify the failure modes of the equipment being tested. This type of analysis will ensure that the failure modes and corresponding mitigation design are addressed by the most appropriate testing strategies, which simulate the environment in which the equipment will be operated, with appropriate factors of safety applied.

The probability of failure of the identified failure modes may need to be demonstrated to be of a similar likelihood as the failures expected in recognized types of protection.

Full life cycle conditions may need to be considered and any restrictions may form part of the mandatory directions for use of the equipment to ensure EPLs are maintained during the operational life of the equipment.

By its very nature, assessment and testing to special protection “s” cannot be as prescriptive as for the recognized types of protection. It is anticipated that considerable dialogue is required between the manufacturer and an independent verifier. Additional assessment and testing may be identified by the independent verifier to ensure the relevant EPL is achieved.

When undertaking verification, it is strongly recommended the guidance provided in this standard is followed including:

- applying different levels of verification to match the EPL (similar in concept to the approach given in the IEC 61508 series);
- always involving at least one independent person/organization (an independent verifier);
- not using personnel who have had any involvement in research or determining the criteria for establishing the essential safety requirements in conjunction with the manufacturer.

Where it is intended to apply the requirements of this standard within a certification system/scheme, the following recommendations are made:

- the requirements laid down in EN 50495 [2] for safety devices are observed;
- an assessment should be performed by independent certification bodies (as the independent verifier) according to the requirements in this standard before issuing a certificate of conformity;
- a certification body performing an assessment for equipment not covered by recognized types of protection should have demonstrated expertise in the field under question.

The need for a standard to address special protection “s” can be justified on the basis that:

- provision has been in IEC 60079-0 for many years with reference Ex “s” in a note in the marking requirements or elsewhere. This reference goes back to IEC standards that pre-date 1957;
- there have been standards used on a national basis for many years for certification to special protection “s”. Examples are SFA 3009 in the UK and AS/NZS 1826 in Australia and New Zealand;
- it is necessary to have an international approach that is consistent;
- there is an identified need and has been a request for a special protection “s” standard from IECEx.

Support for the approach in the standard:

- the approach draws on the experience of the use of verifiers already in other IEC standards.

AUSTRALIAN/NEW ZEALAND STANDARD

Explosive atmospheres**Part 33:****Equipment protection by special protection 's'****1 Scope**

This part of IEC 60079 gives the specific methodology for the assessment and testing, and requirements for marking of electrical equipment, parts of electrical equipment and Ex components with special protection "s".

This part of IEC 60079 applies to

- electrical equipment employing a method of protection not covered by any existing standard in the IEC 60079 series,
- electrical equipment employing one or more recognized types of protection where the design and construction is not fully compliant with the standard for the type of protection,
- electrical equipment where the intended use is outside the parameters of the scope of the standard for the type of protection.

This part of IEC 60079 is not intended for equipment that is covered by the scope of other IEC 60079 equipment standards unless

- it is clearly demonstrated that compliance with the type of protection is not feasible, and
- additional measures are applied to establish an equivalent equipment protection level.

This part of IEC 60079 for special protection "s" is applicable to Group I, Group II and Group III and for equipment protection levels Ma, Mb, Ga, Gb, Gc, Da, Db and Dc, as defined in IEC 60079-0.

Certain specific guidance for assessment and testing are provided in the annexes to this standard.

This standard supplements and/or modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard shall take precedence.

NOTE 1 This standard may be used where equipment requires a higher EPL than the underlying protection techniques provide. Additional control measures or additional design and test requirements would be applied.

NOTE 2 Parts of equipment that can be designed and tested to standardized techniques should be so designed. Only those parts where conformance with essential safety requirements is achieved through alternative controls should be considered for special protection "s". Equipment similar in attributes and performance to other equipment within a particular type of protection should be reviewed first to that method of protection prior to being considered for the use of Ex "s". Some parts of IEC 60079 allow a degree of variance from the equipment requirements and where determined to be close enough by independent verifiers, then it is preferable to prescribe to the original type of protection.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079 (all parts), *Explosive atmospheres*