

Australian/New Zealand Standard™

Electromagnetic compatibility (EMC)

Part 4.14: Testing and measurement techniques—Voltage fluctuation immunity test for equipment with input current not exceeding 16 A per phase



AS/NZS 61000.4.14:2012

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-034, Power Quality. It was approved on behalf of the Council of Standards Australia on 4 May 2012 and on behalf of the Council of Standards New Zealand on 26 April 2012.

This Standard was published on 22 May 2012.

The following are represented on Committee EL-034:

Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Information Industry Association
Bureau of Steel Manufacturers of Australia
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Electrical Regulatory Authorities Council
Electricity Engineers Association, New Zealand
Energy Networks Association
Engineers Australia
Lighting Council of Australia
Ministry of Economic Development, New Zealand
National Measurement Institute
New Zealand Coordinating Committee on Power & Telecommunication Systems
New Zealand Electric Fence Energiser Manufacturers Standards WG
Telstra Corporation
University of Canterbury, New Zealand
University of Wollongong

Keeping standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 61000.4.14.

Australian/New Zealand Standard™

Electromagnetic compatibility (EMC)

Part 4.14: Testing and measurement techniques—Voltage fluctuation immunity test for equipment with input current not exceeding 16 A per phase

Originally as AS/NZS 61000.4.14:2007.
Second edition 2012.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

ISBN 978 1 74342 113 0

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-034, Power Quality, to supersede AS/NZS 61000.4.14:2007, *Electromagnetic compatibility (EMC)—Part 4.14: Testing and measurement techniques—Voltage fluctuation immunity test*.

The objective of this Standard is to establish a common reference for evaluating the immunity of electric and electronic equipment when subjected to positive and negative low amplitude voltage fluctuations.

This Standard is identical with, and has been reproduced from IEC 61000-4-14, Ed.1.2 (2009), *Electromagnetic compatibility (EMC)—Part 4-14: Testing and measurement techniques—Voltage fluctuation immunity test for equipment with input current not exceeding 16 A per phase*.

IEC 61000-4-14, Ed.1.2 (2009) consists of the IEC 61000-4-14, Ed.1.0 (1999), its Amendment 1 (2001), and its Amendment 2 (2009). A vertical line in the margin of the source document shows where the base publication has been modified by Amendments 1 and 2.

As this Standard is reproduced from an International Standard, the following applies:

- Its number appears on the cover and title page while the International Standard number appears only on the cover.
- In the source text ‘this part of IEC 61000’ should read ‘this part of AS/NZS 61000’.
- A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
IEC		AS/NZS	
60068	Environmental testing	60068	Environmental testing
60068-1	Part 1: General and guidance	60068.1	Part 1: General and guidance
61000	Electromagnetic compatibility (EMC)	61000	Electromagnetic compatibility (EMC)
61000-2-4	Part 2-4: Environment—Compatibility levels in industrial plants for low-frequency conducted disturbances	61000.2.4	Part 2.4: Environment—Compatibility levels in industrial plants for low-frequency conducted disturbances

The term ‘informative’ has been used in this Standard to define the application of the annex to which it applies. An ‘informative’ annex is only for information and guidance.

CONTENTS

1	Scope	6
2	Normative references.....	6
3	General	6
3.1	Effects of voltage fluctuations	6
3.2	Sources.....	7
4	Definitions	7
5	Test levels.....	7
6	Test equipment.....	8
6.1	Test generator.....	8
6.2	Characteristics and performance of the test generator	9
6.3	Verification of the test generator	9
7	Test set-up	9
8	Test procedure	9
8.1	Climatic conditions.....	10
8.2	Execution of the test.....	10
9	Evaluation of test results.....	10
10	Test report.....	11
	Annex A (informative) Electromagnetic environment classes.....	16
	Bibliography.....	17
	Figure 1a – Test diagram	12
	Figure 1b – Example of a voltage step and falling voltage.....	13
	Figure 1c – Example of a voltage step and rising voltage	13
	Figure 1d – Example of a complete voltage fluctuation.....	14
	Figure 1 – Example of test sequences of voltage fluctuations	14
	Figure 2 – Example of successive applications of voltage fluctuations.....	14
	Figure 3 – Schematic (single-phase) of test instrumentation for voltage fluctuations, with power amplifier	15
	Figure 4 – Example of test generator verification load.....	15
	Table 1 – Test levels.....	8
	Table 2 – Characteristics of the test generator.....	9

FOREWORD

This consolidated version of IEC 61000-4-14 consists of the first edition (1999) as amendment 1 (2001) and as amendment 2 (2009).

The technical content is therefore identical to the base edition and its amendments and has been prepared for user convenience.

A vertical line in the margin shows where the base publication has been modified by amendments 1 and 2.

AUSTRALIAN/NEW ZEALAND STANDARD

Electromagnetic compatibility (EMC)

Part 4.14:

Testing and measurement techniques—Voltage fluctuation immunity test for equipment with input current not exceeding 16 A per phase**1 Scope**

This part of IEC 61000 is a basic electromagnetic compatibility (EMC) publication. It considers immunity tests for electrical and/or electronic equipment in their electromagnetic environment. Only conducted phenomena are considered, including immunity tests for equipment connected to public and industrial power supply networks.

This part aims to establish a reference for evaluating the immunity of electrical and electronic equipment when subjected to positive and negative low amplitude voltage fluctuation.

The voltage fluctuations considered by this standard do not include flicker, which is a physiological phenomenon due to lighting luminance fluctuations.

This standard applies to electrical and/or electronic equipment that have a rated input current up to 16 A per phase. It does not apply to electrical and/or electronic equipment connected to d.c. or a.c. 400 Hz distribution networks. Tests concerning these networks will be covered by other IEC standards.

The immunity test levels required for a specific electromagnetic environment, together with the performance criteria, are indicated in the product, product family or generic standards as applicable. However, most product groups do not have a history of being susceptible to voltage fluctuations. Consequently, testing for these phenomena is often not required.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(161), *International Electrotechnical Vocabulary (IEV) – Chapter 161: Electromagnetic compatibility*

IEC 60068-1, *Environmental testing – Part 1: General and guidance*

IEC 61000-2-4, *Electromagnetic compatibility (EMC) – Part 2: Environment – Section 4: Compatibility levels in industrial plants for low-frequency conducted disturbances*

3 General**3.1 Effects of voltage fluctuations**

Electrical and electronic equipment may be affected by voltage fluctuations. Examples of these effects include the following:

- degradation of performances in equipment using storage devices (e.g. capacitors);
- loss of function in control systems;