

AS/NZS 62110:2021



Australian/New Zealand Standard™

**Electric and magnetic field levels generated
by AC power systems — Measurement
procedures with regard to public exposure
(IEC 62110:2009/COR1:2015, MOD)**



Currently in preview, click buy full version

AS/NZS 62110:2021

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee TE-007, Human Exposure to Electromagnetic Fields. It was approved on behalf of the Council of Standards Australia on 16 April 2021 and by the New Zealand Standards Approval Board on 4 May 2021.

This Standard was published on 21 May 2021.

The following are represented on Committee TE-007:

- Australian Centre for Radiofrequency Bioeffects Research
- Australian Industry Group
- Australian Mobile Telecommunications Association
- Australian Radiation Protection and Nuclear Safety Agency
- Commercial Radio Australia
- Communications, Electrical and Plumbing Union — Electrical Division
- Department of Defence (Australian Government)
- Electrical Engineers Association of NZ
- Engineers Australia
- Ministry of Health, NZ
- National Measurement Institute
- National Radiation Laboratory New Zealand
- Victoria University of Wellington NZ

This Standard was issued in draft form for comment as DR AS/NZS 62110:2021.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

ISBN 978 1 76113 319 0

Australian/New Zealand Standard™

**Electric and magnetic field
levels generated by AC power
systems — Measurement
procedures with regard
to public exposure (IEC
62110:2009/COR1:2015, MOD)**

First published as AS/NZS 62110:2021.



© IEC Geneva Switzerland 2021 — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2021

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of either the IEC or the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand). If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please see the contact details on the back cover or the contact us page of the website for further information.

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee TE-007, Human Exposure to Electromagnetic Fields.

The objective of this document is to establish measurement procedures for electric and magnetic field levels generated by AC power systems to evaluate the exposure levels of the human body to these fields.

This document is applicable to public exposure in the domestic environment and in areas accessible to the public.

This document specifies fundamental procedures for the measurement of fields, and, with regard to human exposure, for obtaining a field value that corresponds to a spatial average over the entire human body.

This document is not applicable to DC power transmission systems.

This document is not applicable to occupational exposure associated with, for example, the operation and/or maintenance of the power systems. Such exposure may occur when working inside a distribution or transmission substation, a power plant, in a manhole or a tunnel for underground cables, or on an overhead line tower or pole.

This document is an adoption with national modifications, and has been reproduced from, IEC 62110:2009, *Electric and magnetic field levels generated by AC power systems — Measurement procedures with regard to public exposure* and its Corrigendum No 1 (2015) which has been added at the end of the source text.

The modifications are additional requirements and are set out in [Appendix ZZ](#), which has been added after Corrigendum No 1.

[Appendix ZZ](#) lists the variations to IEC 62110:2009 for the application of this document in Australia and New Zealand.

As this document has been reproduced from an International Standard the following applies:

- (a) In the source text “this International Standard” should read “this document”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

Currently in preview, click buy full version

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope	8
2 Normative reference	8
3 Terms and definitions	8
4 Measurement principle for electric and magnetic fields	9
4.1 General	9
4.2 Instruments	9
4.3 Harmonic content	10
4.4 Record of measurement result	10
4.5 Measurement considerations	11
4.5.1 Field orientation	11
4.5.2 Measurement locations	12
4.5.3 Perturbing effects of an operator in electric field measurement	12
4.5.4 Effects from other sources in magnetic field measurement	12
4.5.5 Humidity condition in electric field measurement	12
5 Fundamental measurement procedures for electric and magnetic fields	12
5.1 General procedure.....	12
5.2 Single-point measurement	13
5.3 Three-point measurement.....	13
5.4 Five-point measurement	14
6 Measurement procedures for finding the maximum exposure level to an electric field.....	15
6.1 Overhead lines	15
6.2 Underground cables	15
6.3 Substations and power system equipment.....	15
7 Measurement procedures for finding the maximum exposure level to a magnetic field.....	16
7.1 Overhead lines	16
7.2 Underground cables	16
7.3 Substation and power system equipment.....	16
Annex A (informative) Characteristics of electric fields generated by AC overhead lines	18
Annex B (informative) Characteristics of magnetic fields generated by AC power systems.....	30
Annex C (informative) Concept of the <i>three-point measurement</i> with regard to the <i>average exposure level</i>	42
Annex D (informative) Example of a reporting form for field measurement.....	47
Bibliography	50
Figure 1 – Heights of <i>the three-point measurement</i>	13
Figure 2 – Five-point measurement	14
Figure A.1 – Linear charge distribution above ground	19
Figure A.2 – General <i>n</i> -phase system with ground	20
Figure A.3 – Electric field levels under an overhead transmission line	22

Figure A.4 – Electric field levels under an overhead transmission line with bundled conductors.....	22
Figure A.5 – Electric field levels and non-uniformity under a 77 kV overhead transmission line – Effect of heights of conductors.....	24
Figure A.6 – Electric field levels and non-uniformity under a 500 kV overhead transmission line – Effects of the heights of conductors.....	25
Figure A.7 – Electric field levels under a 77 kV overhead transmission line – Effect of separation between conductors.....	26
Figure A.8 – Electric field levels and non-uniformity under a 500 kV overhead transmission line – Effect of separation between conductors.....	27
Figure A.9 – Vertical and horizontal components of electric field levels under a 77 kV overhead transmission line.....	27
Figure A.10 – Vertical and horizontal components of electric field levels under a 500 kV overhead transmission line.....	28
Figure A.11 – Electric field contour of a 25 kV overhead line.....	28
Figure A.12 – Electric field profile along the wall of a building and at 1 m above ground level.....	29
Figure B.1 – Magnetic field levels under a 77 kV overhead transmission line.....	32
Figure B.2 – Magnetic field levels under a 500 kV overhead transmission line.....	33
Figure B.3 – Magnetic field levels and non-uniformity under a 77 kV overhead transmission line – Effect of heights of conductors.....	34
Figure B.4 – Magnetic field levels and non-uniformity under a 500 kV overhead transmission line – Effect of heights of conductors.....	35
Figure B.5 – Magnetic field levels and non-uniformity under a 77 kV overhead transmission line – Effect of separation between conductors.....	36
Figure B.6 – Magnetic field levels under a 500 kV overhead transmission line – Effect of separation between conductors.....	37
Figure B.7 – Values of semi-major and semi-minor components (r.m.s.) of magnetic field levels under a 77 kV overhead transmission line.....	38
Figure B.8 – Values of semi-major and semi-minor components (r.m.s.) of magnetic field levels under a 500 kV overhead transmission line.....	38
Figure B.9 – Magnetic field levels and non-uniformity under an overhead distribution line (6 600 V / 100 V).....	39
Figure B.10 – Magnetic field levels and non-uniformity above underground cables – Effect of buried depth.....	40
Figure B.11 – Magnetic field levels and non-uniformity above underground cables – Effect of separation between conductors.....	40
Figure B.12 – Measured magnetic field levels and non-uniformity around a 6 600 V pad-mounted transformer.....	41
Figure B.13 – Measured magnetic field levels and non-uniformity around 6 600 V vertical cables.....	41
Figure C.1 – A spheroidal human model.....	42
Figure C.2 – The model in the magnetic field generated by a straight cable.....	43
Figure C.3 – Magnetic field levels generated by a straight cable.....	43
Figure C.4 – The model in the magnetic field generated by three parallel cables.....	44
Figure C.5 – Magnetic field levels generated by three balanced parallel cables.....	44
Figure C.6 – The model in the magnetic field generated by underground cables.....	45
Figure C.7 – Magnetic field levels generated by underground cables.....	45
Figure C.8 – The model in the magnetic field generated by overhead wires.....	46

Figure C.9 – Magnetic field levels generated by balanced overhead wires.....46

Currently in preview, click buy full version

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRIC AND MAGNETIC FIELD LEVELS GENERATED BY AC POWER
SYSTEMS – MEASUREMENT PROCEDURES
WITH REGARD TO PUBLIC EXPOSURE**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62110 has been prepared by IEC technical committee 106: Methods for the assessment of electric, magnetic and electromagnetic fields associated with human exposure.

The text of this standard is based on the following documents:

FDIS	Report on voting
106/177/FDIS	106/185/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

Terms defined in Clause 3 appear in *italics* throughout the document.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigendum of January 2015 have been included in this copy.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

All populations of the world are now exposed to electric and magnetic fields and the levels will continue to increase with developing industry and technology. A number of countries have implemented regulations on public exposure to these fields. Therefore, in order to evaluate human exposure levels to these fields adequately, common measurement procedures are required by not only professionals of national authorities and electric power industries, but also the general public.

This standard is applied to the measurement of fields generated by AC power systems in areas accessible to the public. It establishes a common measurement procedure to evaluate the exposure levels of the human body to electric and magnetic fields among the general public.

The values obtained are for use to determine whether the fields comply with exposure limits by comparing them with the field limits for general public exposure such as the reference levels from the ICNIRP (International Commission on Non-Ionizing Radiation Protection) Guidelines [1]¹⁾, MPE (maximum permissible exposure) from the IEEE (Institute of Electrical and Electronics Engineers) [2] or in national regulations. If the values obtained are higher than the reference level or MPE, it does not necessarily mean that the basic restriction has been exceeded, in which case other methods must be used to ensure that basic restriction is not exceeded.

The values obtained by using the procedures in this standard are for the load conditions occurring at the time of measurement. Therefore, in the case of magnetic field, in order to check compliance with some exposure guidelines or regulations these values may need to be extrapolated to take account of the maximum load of the circuits.

This standard is not applicable to occupational exposure associated with, for example, the operation and/or maintenance of the power systems. Such exposure may occur when working inside a distribution or transmission substation, a power plant, in a manhole or a tunnel for underground cables, or on an overhead line tower or pole.

1) Numbers in square brackets refers to the Bibliography.

ELECTRIC AND MAGNETIC FIELD LEVELS GENERATED BY AC POWER SYSTEMS – MEASUREMENT PROCEDURES WITH REGARD TO PUBLIC EXPOSURE

1 Scope

This International Standard establishes measurement procedures for electric and magnetic field levels generated by AC power systems to evaluate the exposure levels of the human body to these fields. This standard is not applicable to DC power transmission systems.

This International Standard is applicable to public exposure in the domestic environment and in areas accessible to the public.

This standard specifies fundamental procedures for the measurement of fields, and, with regard to human exposure, for obtaining a field value that corresponds to a spatial average over the entire human body.

This standard is not applicable to occupational exposure associated with, for example, the operation and/or maintenance of the power systems. Such exposure may occur when working inside a distribution or transmission substation, a power plant, in a manhole or a tunnel for underground cables, or on an overhead line tower or pole.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61786, *Measurement of low-frequency magnetic and electric fields with regard to exposure of human beings – Special requirements for instruments and guidance for measurements*

3 Terms and definitions

For the purposes of this document, the following terms and definitions given below apply. Internationally accepted SI-units are used throughout the standard.

NOTE The distinction between “magnetic flux density” and “magnetic field strength” is only relevant when considering magnetic fields in magnetic materials. In air it is common to use “magnetic fields” as a generic term to cover both of these two quantities.

3.1

single-point measurement

procedure to measure the field level at a specified height, used for uniform fields

NOTE The conditions under which the field can be considered as uniform or non-uniform are given in section 5.1.

3.2

three-point measurement

procedure to measure the field levels at three specified heights at a single location, used for non-uniform fields