

Australian/New Zealand Standard™

**Alarm and electronic security systems**

**Part 11.2: Electronic access control  
systems — Application guidelines**

STANDARDS  
Australia



STANDARDS®  
NEW ZEALAND  
PAEREWĀ AOTEAROA



AS/NZS IEC 60839.11.2:2019

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee EL-031, Intruder Alarm Equipment and Installations. It was approved on behalf of the Council of Standards Australia on 12 November 2019 and by the New Zealand Standards Approval Board on 4 December 2019.

This Standard was published on 20 December 2019.

The following are represented on Committee EL-031:

- Australian Digital and Telecommunications Industry Association
- Australian Federal Police
- Australian Industry Group
- Australian Security Industry Association
- Engineers Australia
- Fire Protection Association Australia
- Insurance Council of Australia
- New Zealand Security Association
- NSW Police Force
- Queensland Police Service
- Security Providers Association of Australia
- South Australia Police
- Victoria Police
- Victorian Security Institute

This Standard was issued in draft form for comment as DR AS/NZS IEC 60839.11.2:2019.

#### **Keeping Standards up-to-date**

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

[www.standards.org.au](http://www.standards.org.au)

[www.standards.govt.nz](http://www.standards.govt.nz)

ISBN 978 1 76072 676 8

Australian/New Zealand Standard™

## **Alarm and electronic security systems**

### **Part 11.2: Electronic access control systems — Application guidelines**

First published as AS/NZS IEC 60839.11.2:2019.

#### **COPYRIGHT**

© IEC 2019 — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2019

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

## Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-031, Intruder Alarm Equipment and Installations.

The objective of this Standard is to define the minimum requirements and guidance for the installation and operation of electronic access control systems (EACS) and/or accessory equipment to meet different levels of protection.

This Standard includes requirements for planning, installation, commissioning, maintenance and documentation for the application of EACS installed in and around buildings and areas. The equipment functions are defined in AS/NZS IEC 60839.11.1.

When the EACS includes functions relating to hold-up or the detection of intruders, the requirements in Standards relating to intrusion and hold-up are also applicable.

This Standard provides application guidelines intended to assist those responsible for establishing an EACS to ascertain the appropriate design and planning of the EACS, both in terms of levels of protection and levels of performance necessary to provide the degree of access control and protection considered appropriate for each installation.

This Standard does not cover the methods and procedures for conducting a risk assessment.

This Standard is identical with, and has been reproduced from, IEC 60839-11-2:2014, *Alarm and electronic security systems — Part 11-2: Electronic access control systems — Application guidelines*.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of IEC 60839” should read “this Australian/New Zealand Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standard, that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

Currently in preview, click buy full version

## CONTENTS

FOREWORD .....	4
INTRODUCTION .....	6
1 Scope .....	7
2 Normative references .....	7
3 Terms and definitions .....	7
4 Abbreviations .....	8
5 System architecture .....	8
6 Environmental and EMC considerations .....	9
6.1 General .....	9
6.2 Environmental Class I – Equipment situated in indoor but restricted to residential/office environment .....	9
6.3 Environmental Class II – Equipment situated indoor in general .....	9
6.4 Environmental Class III – Equipment situated outdoor – Sheltered or indoor extreme conditions .....	10
6.5 Environmental Class IV – Equipment situated outdoor – General .....	10
6.6 EMC .....	10
7 System planning .....	10
7.1 General .....	10
7.2 Risk assessment and security grading .....	11
7.3 System design .....	12
7.3.1 System and components selection .....	12
7.3.2 Operational considerations .....	14
8 System installation .....	16
8.1 General .....	16
8.2 Installation planning .....	17
8.2.1 Equipment .....	17
8.2.2 Cabling .....	19
9 Commissioning and system handover .....	19
9.1 Commissioning .....	19
9.2 System handover .....	20
10 System operation and maintenance .....	20
10.1 System operation .....	20
10.2 System maintenance .....	21
11 Documentation .....	21
11.1 General .....	21
11.2 Documentation for planning .....	21
11.3 Documentation for commissioning/system handover .....	22
11.4 Documentation for maintenance .....	22
Annex A (normative) Allowed exceptions for installed systems .....	23
A.1 General .....	23
A.2 Claims of compliance .....	23
A.3 Allowed exceptions .....	23
Annex B (informative) Standby battery capacity calculations .....	27
Bibliography .....	29

Figure 1 – Typical arrangement of components and interfaces of an EACS .....	9
Figure 2 – Risk assessment chart .....	11
Figure 3 – Example of system grade selection .....	13
Figure 4 – Equipment location versus security grade of protected area .....	17
Table 1 – Security grading .....	12
Table 2 – Power supply requirements for installed EACS .....	18
Table A.1 – Allowed exceptions for access point interface requirements .....	24
Table A.2 – Allowed exceptions for indication and annunciation requirements.....	24
Table A.3 – Allowed exceptions for recognition requirements .....	25
Table A.4 – Duress signalling requirements .....	25
Table A.5 – Overriding requirements.....	25
Table A.6 – Communication requirements .....	25
Table A.7 – Allowed exceptions for system self-protection requirements.....	25
Table A.8 – Allowed exceptions for power supply requirements .....	26

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ALARM AND ELECTRONIC SECURITY SYSTEMS –****Part 11-2: Electronic access control systems –  
Application guidelines**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, accept IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60839-11-2 has been prepared by IEC technical committee 79: Alarm and electronic security systems.

The text of this standard is based on the following documents:

FDIS	Report on voting
79/476/FDIS	79/489/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60839 series, published under the general title *Alarm and electronic security systems*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

This standard is part of the IEC 60839 series, written to include the following parts:

Part 11-1: Electronic access control systems – System and components requirements

Part 11-2: Electronic access control systems – Application guidelines

This part of IEC 60839 describes the general requirements for planning, installation, operation, maintenance and documentation for the application of electronic access control systems (EACS).

The performance of the EACS is determined by the security grades allocated to the access points. A risk assessment that identifies the risks and perceived threats should first be carried out in order to establish the appropriate security grades.

Four security grades are available based upon the knowledge and tools available to a person intent upon gaining unauthorised access and the type of application, taking into account specific organizational aspects and the value of the assets.

Separate guidance is provided for each activity along with recommendations for the documentation needed. A brief description of each section covering the activities is provided below:

System planning: this section is intended to assist the designer with the selection of an electronic access control system (EACS) that provides the control of access and security integrity commensurate with the value of the assets requiring protection and the associated risks. See Clause 7.

System design should minimise potential vulnerabilities that could be exploited to circumvent the access control measures. It is recommended that safeguards are incorporated to give early warning of attempts to circumvent the access control measures. See 7.3.

System installation: this section is intended to help those responsible for installing the EACS by identifying issues which should be considered prior to commencing the installation and during the installation of the system in order to ensure the EACS is correctly implemented as specified during system planning. See Clause 8.

Commissioning and system handover: this section provides guidance to ensure the level of performance required in the system planning is obtained and that the end user is provided with the necessary documentation, records and operating instructions during the handover of the EACS. See Clause 9.

System operation and maintenance: includes information regarding the responsibilities of the end user of the EACS to ensure the system is operated correctly and adequately maintained. It covers inspection, service and the use of remote diagnostics in order that the level of performance determined during the system planning stages can be maintained. See Clause 10.

## **ALARM AND ELECTRONIC SECURITY SYSTEMS –**

### **Part 11-2: Electronic access control systems – Application guidelines**

#### **1 Scope**

This part of IEC 60839 defines the minimum requirements and guidance for the installation and operation of electronic access control systems (EACS) and/or accessory equipment to meet different levels of protection.

This standard includes requirements for planning, installation, commissioning, maintenance and documentation for the application of EACS installed in and around buildings and areas. The equipment functions are defined in the IEC 60839-11-1.

When the EACS includes functions relating to hold-up or the detection of intruders, the requirements in standards relating to intrusion and hold-up are also applicable.

This standard provides application guidelines intended to assist those responsible for establishing an EACS to ascertain the appropriate design and planning of the EACS, both in terms of levels of protection and levels of performance necessary to provide the degree of access control and protection considered appropriate for each installation. This is achieved by scaling or classifying the features of electronic access control systems related to the security functionality (e.g. recognition, access point actuation, access point monitoring, duress signaling and system self-protection) in line with the known or perceived threat conditions.

This standard does not cover the methods and procedures for conducting a risk assessment.

#### **2 Normative references**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60839-11-1:2013, *Alarm and electronic security systems – Part 11-1: Electronic access control systems – System and components requirements*

#### **3 Terms and definitions**

For the purposes of this document the terms and definitions given in IEC 60839-11-1, as well as the following, apply.

##### **3.1**

##### **area zone**

part of a protected area which has its own set of access levels

Note 1 to entry: It may have a different security grade than other area zones within the same protected area.

##### **3.2**

##### **competent organization**

organization possessing sufficient resources and staff with adequate expertise and training in the maintenance of EACS