

Australian/New Zealand Standard™

Low-voltage switchgear and controlgear

Part 2: Circuit-breakers



AS/NZS IEC 60947.2:2015

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-006, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of Standards Australia on 26 May 2015 and on behalf of the Council of Standards New Zealand on 29 May 2015. This Standard was published on 29 June 2015.

The following are represented on Committee EL-006:

Association of Accredited Certification Bodies
Ausgrid
Australian Chamber of Commerce and Industry
Australian Industry Group
Bureau of Steel Manufacturers of Australia
Business New Zealand
Electrical Contractors Association of New Zealand
Engineers Australia
National Electrical and Communications Association
National Electrical Switchboard Manufacturers Association
Rail Industry Safety and Standards Board (RISSB)

Keeping Standards up-to-date

Standards are living documents, which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand website at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS IEC 60947.2:2015.

Australian/New Zealand Standard™

Low-voltage switchgear and controlgear

Part 2: Circuit-breakers

Original as AS 3858—1990.
Revised and redesignated as AS/NZS IEC 60947.2:2015.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-006, Industrial Switchgear and Controlgear, to supersede AS 60947.2—2005.

The objective of this Standard is to state—

- (a) the characteristics of circuit-breakers;
- (b) the conditions with which circuit-breakers are required to comply with reference to—
 - (i) operation and behaviour in normal service;
 - (ii) operation and behaviour in case of overload and operation and behaviour in case of short-circuit, including co-ordination in service (selectivity and back-up protection);
 - (iii) dielectric properties;
- (c) tests intended for confirming that these conditions have been met and the methods to be adopted for these tests; and
- (d) information to be marked on or given with the apparatus.

This Standard is identical with, and has been reproduced from, IEC 60947-2, Ed. 4.2 (2013), *Low-voltage switchgear and controlgear, Part 2: Circuit-breakers*. A vertical line in the margin shows where IEC 60947-2, Ed. 4.0 (2006), has been modified by its Amendments 1 (2009) and 2 (2013).

As this Standard is reproduced from an International Standard, a full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
IEC		AS	
60068	Environmental testing	60068	Environmental testing
60068-2-14	Part 2-14: Tests. Test N: Change of temperature Amendment 1 (1986)	60068-2.14	Part 2.14: Tests. Test N: Change of temperature
60068-2-30	Part 2-30: Tests—Test Db: Damp heat, cyclic (12 h + 12 h cycle)	60068.2.30	Part 2.30: Tests—Test Db: Damp heat, cyclic (12 h + 12 h cycle)
		AS/NZS	
60695	Fire hazard testing	60695	Fire hazard testing
60695-2-10	Part 2-10: Glowing/hot-wire based test methods—Glow-wire apparatus and common test procedure	60695.2.10	Part 2.10: Glowing/hot-wire based test methods—Glow-wire apparatus and common test procedure
60695-2-11	Part 2-11: Glowing/hot-wire based test methods—Glow-wire flammability test method for end-products	60695.2.11	Part 2.11: Glowing/hot-wire based test methods—Glow-wire flammability test method for end-products
60695-2-12	Part 2-12: Glowing/hot-wire based test methods—Glow-wire flammability test method for materials	60695.2.12	Part 2.12: Glowing/hot-wire based test methods—Glow-wire flammability test method for materials
60695-2-13	Part 2-13: Glowing/hot-wire based test methods—Glow-wire ignitability test method for materials	60695.2.13	Part 2.13: Glowing/hot-wire based test methods—Glow-wire ignitability test method for materials

IEC		AS/NZS IEC	
60947	Low-voltage switchgear and controlgear	60947	Low-voltage switchgear and controlgear
60947-4-1	Part 4-1: Contactors and motor-starters—Electromechanical contactors and motor-starters Amendment 1 (2002) Amendment 2 (2005)	60947-4-1	Part 4-1: Contactors and motor-starters—Electromechanical contactors and motor-starters
		AS/NZS	
61000	Electromagnetic compatibility (EMC)	61000	Electromagnetic compatibility (EMC)
61000-3-2	Part 3-2: Limits—Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)	61000.3.2	Part 3.2: Limits—Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)
61000-3-3	Part 3-3: Limits—Section 3: Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems for equipment with rated current—16 A per phase and not subject to conditional connection Amendment 1 (2001) Amendment 2 (2005)	61000.3.3	Part 3.3: Limits—Section 3: Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems for equipment with rated current—16 A per phase and not subject to conditional connection
		AS/NZS IEC	
61000-4-2	Part 4-2: Testing and measurement techniques—Electrostatic discharge immunity test Amendment 1 (1998) Amendment 2 (2000)	61000.4.2	Part 4.2: Testing and measurement techniques—Electrostatic discharge immunity test
61000-4-3	Part 4-3: Testing and measurement techniques—Radiated, radio-frequency, electromagnetic field immunity test	61000.4.3	Part 4.3: Testing and measurement techniques—Radiated, radio-frequency, electromagnetic field immunity test
61000-4-4	Part 4-4: Testing and measurement techniques—Electrical fast transient/burst immunity test	61000.4.4	Part 4.4: Testing and measurement techniques—Electrical fast transient/burst immunity test
		AS/NZS	
61000-4-5	Part 4-5: Testing and measurement techniques—Surge immunity test	61000.4.5	Part 4.5: Testing and measurement techniques—Surge immunity test
		AS/NZS IEC	
61000-4-6	Part 4-6: Testing and measurement techniques—Immunity to conducted disturbances, induced by radiofrequency fields Amendment 1 (2004) Amendment 2 (2006)	61000.4.6	Part 4.6: Testing and measurement techniques—Immunity to conducted disturbances, induced by radiofrequency fields
61000-4-11	Part 4-11: Testing and measurement techniques—Voltage dips, short interruptions and voltage variations immunity tests	61000.4.11	Part 4.11: Testing and measurement techniques—Voltage dips, short interruptions and voltage variations immunity tests

IEC		AS/NZS	
61000-4-13	Part 4-13: Testing and measurement techniques—Harmonics and interharmonics including mains signalling at a.c. power port, low-frequency immunity tests	61000.4.13	Part 4.13: Testing and measurement techniques—Harmonics and interharmonics including mains signalling at a.c. power port, low-frequency immunity tests
61008	Residual current operated circuit-breakers without integral over-current protection for household and similar uses (RCCBs)	61008	Residual current operated circuit-breakers without integral over-current protection for household and similar uses (RCCBs)
61008-1	Part 1: General rules Amendment 1 (2002) Amendment 2 (2006)	61008.1	Part 1: General rules
61009	Residual current operated circuit-breakers with integral over-current protection for household and similar uses (RCBOs)	61009	Residual current operated circuit-breakers with integral over-current protection for household and similar uses (RCBOs)
61009-1	Part 1: General rules Amendment 1 (2002) Amendment 2 (2006)	61009.1	Part 1: General rules
		AS IEC	
61131	Programmable controllers	61131	Programmable controllers
61131-1	Part 1: General information	61131-1	Part 1: General information
		AS/NZS CISPR	
CISPR		11	
11	Industrial, scientific and medical (ISM) radio-frequency equipment—Electromagnetic Radio-frequency disturbance characteristics—Limits and methods of measurement Amendment 1 (2004) Amendment 2 (2006)	11	Industrial, scientific and medical (ISM) radio-frequency equipment—Electromagnetic Radio-frequency disturbance characteristics—Limits and methods of measurement
22	Information technology equipment—Radio disturbance characteristics—Limits and methods of measurement	22	Information technology equipment—Radio disturbance characteristics—Limits and methods of measurement

Only normative references that have been adopted as Australian or Australian/New Zealand Standards have been listed.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annexes to which they apply. A ‘normative’ annex is an integral part of a Standard, whereas an ‘informative’ annex is only for information and guidance.

CONTENTS

1	General	9
1.1	Scope and object	9
1.2	Normative references	10
2	Definitions	12
3	Classification	16
4	Characteristics of circuit-breakers	17
4.1	Summary of characteristics	17
4.2	Type of circuit-breaker	17
4.3	Rated and limiting values of the main circuit	17
4.4	Selectivity categories	20
4.5	Control circuits	21
4.6	Auxiliary circuits	21
4.7	Releases	22
4.8	Integral fuses (integrally fused circuit-breakers)	23
5	Product information	23
5.1	Nature of the information	23
5.2	Marking	23
5.3	Instructions for installation, operation and maintenance	25
6	Normal service, mounting and transport conditions	25
7	Constructional and performance requirements	25
7.1	Constructional requirements	25
7.2	Performance requirements	27
7.3	Electromagnetic compatibility (EMC)	33
8	Tests	33
8.1	Kind of tests	33
8.2	Compliance with constructional requirements	33
8.3	Type tests	33
8.4	Routine tests	65
	Annex A (normative) Coordination under short-circuit conditions between a circuit-breaker and another short-circuit protective device associated in the same circuit	70
	Annex B (normative) Circuit-breakers incorporating residual current protection	81
	Annex C (normative) Individual pole short-circuit test sequence	113
	Annex D Variants	114
	Annex E (informative) Items subject to agreement between manufacturer and user	115
	Annex F (normative) Additional tests for circuit-breakers with electronic over-current protection	116
	Annex G (normative) Power loss	146
	Annex H (normative) Test sequence for circuit-breakers for IT systems	149
	Annex J (normative) Electromagnetic compatibility (EMC) – Requirements and test methods for circuit-breakers	151
	Annex K (informative) Glossary of symbols and graphical representation of characteristics	164

Annex L (normative) Circuit-breakers not fulfilling the requirements for overcurrent protection.....	173
Annex M (normative) Modular residual current devices (without integral current breaking device).....	178
Annex N (normative) Electromagnetic compatibility (EMC) – Additional requirements and test methods for devices not covered by Annexes B, F and M	222
Annex O Instantaneous trip circuit-breakers (ICB)	226
 Bibliography.....	 229
 Figure 1 – Test arrangement (connecting cables not shown) for short-circuit tests	 69
Figure A.1 – Over-current co-ordination between a circuit-breaker and a fuse or back-up protection by a fuse: operating characteristics	76
Figure A.2 Figure A.3.....	77
2 Total selectivity between two circuit-breakers	77
Figure A.4 Figure A.5.....	78
Back-up protection by a circuit-breaker – Operating characteristics.....	78
Figure A.6 – Example of test circuit for conditional short-circuit breaking capacity tests showing cable connections for a 3-pole circuit-breaker (C_1).....	79
2 Figure A.7 – Example of test circuit for the verification of selectivity.....	80
Figure B.1 – Test circuit for the verification of the operating characteristic (see B.8.2)	105
Figure B.2 – Test circuit for the verification of the limiting value of the non-operating current under over-current conditions (see B.8.5)	106
Figure B.3 – Test circuit for the verification of the behaviour of CBRs classified under B.3.1.2.2 (see B.8.9)	107
Figure B.4 – Current ring wave 0,5 μ s/100 kHz	108
Figure B.5 – Example of test circuit for the verification of resistance to unwanted tripping	109
Figure B.6 – Surge current wave 3/20 μ s	109
Figure B.7 – Test circuit for the verification of resistance to unwanted tripping in case of flashover without follow-on current (B.8.6.2)	110
Figure B.8 – Test circuit for the verification of the correct operation of CBRs, in the case of residual pulsating direct currents (see B.8.7.2.1, B.8.7.2.2 and B.8.7.2.3)	111
Figure B.9 – Test circuit for the verification of the correct operation of CBRs, in the case of a residual pulsating direct current superimposed by a smooth direct residual current (see B.8.7.2.1)	112
Figure F.1 – Representation of test current produced by back-to-back thyristors in accordance with F.4.1	125
Figure F.2 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.2 – Two phase poles in series.....	126
Figure F.3 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.2 – Three phase poles in series	127
Figure F.4 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.2 – Three-phase connection	128
Figure F.5 – Test current for the verification of the influence of the current dips and interruptions in accordance with F.4.7.1.....	129
Figure F.6 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Two phase poles in series.....	130

Figure F.7 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Three phase poles in series	131
Figure F.8 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Three-phase connection	132
Figure F.9 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Two phase poles in series	133
Figure F.10 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Three phase poles in series	134
Figure F.11 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Three-phase connection.....	135
Figure F.12 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Two phase poles in series	135
Figure F.13 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Three phase poles in series.....	136
Figure F.14 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Three-phase connection	137
Figure F.15 – Temperature variation cycles at a specified rate of change in accordance with F.9.1	137
Figure F.16 – General test set up for immunity tests	138
Figure F.17 – Test set up for the verification of immunity to radiated r.f. electromagnetic fields.....	139
Figure F.18 – Test set up for the verification of immunity to electrical fast transients/bursts (EFT/B) on power lines	140
Figure F.19 – Test set up for verification of immunity to electrical fast transients/bursts (EFT/B) on signal lines	141
Figure F.20 – General test set-up for the verification of immunity to conducted disturbances induced by r.f. fields (common mode)	142
Figure F.21 – Arrangement of connections for the verification of immunity to conducted disturbances induced by r.f. fields - Two phase poles in series configuration.....	143
Figure F.22 – Arrangement of connections for the verification of immunity to conducted disturbances induced by r.f. fields - Three phase poles in series configuration	144
Figure F.23 – Arrangement of connections for the verification of immunity to conducted disturbances induced by r.f. fields – Three-phase configuration	145
Figure G.1 – Example of power loss measurement according to G.2.1	148
Figure G.2 – Example of power loss measurement according to G.2.2 and G.2.3	148
Figure J.1 – EUT mounted in a metallic enclosure	158
Figure J.2 – Test set up for the measurement of radiated r.f. emissions.....	159
Figure J.3 – Test set up for the verification of immunity to electrostatic discharges	160
Figure J.4 – Test set up for the verification of immunity to radiated r.f. electromagnetic fields.....	161
Figure J.5 – Test set up for the verification of immunity to electrical fast transients/bursts (EFT/B) on power lines	162
Figure J.6 – Test set up for the verification of immunity to electrical fast transients/bursts (EFT/B) on signal lines	163
Figure K.1 – Relationship between symbols and tripping characteristics.....	166
Figure K.2 – Template for characteristics of cut-off current versus prospective current from 1 kA to 200 kA	167
Figure K.3 – Template for characteristics of cut-off current versus prospective current from 0,01 kA to 200 kA.....	168

Figure K.4 – Template for characteristics of let-through energy versus prospective current from 1 kA to 200 kA.....	169
Figure K.5 – Template for characteristics of let-through energy versus prospective current from 0,01 kA to 200 kA.....	170
Figure K.6 – Example of the use of template K.2	171
Figure K.7 – Example of the use of template K.4	172
Figure M.1 – Test circuits for the verification of operation in the case of a steady increase of residual current.....	201
Figure M.2 – Test circuits for the verification of operation in the case of a sudden appearance of residual current (with breaking device)	202
Figure M.3 – Test circuits for the verification of operation in the case of a sudden appearance of residual current (without breaking device).....	203
Figure M.4 – Test circuits for the verification of the limiting value of non-operating current under overcurrent conditions	204
Figure M.5 – Test circuits for the verification of the resistance to unwanted tripping in the case of loading of the network capacitance.....	205
Figure M.6 – Test circuit for the verification of the resistance to unwanted tripping in the case of flashover without follow-on current	206
Figure M.7 – Test circuits for the verification of operation in the case of a continuous rise of a residual pulsating direct current	207
Figure M.8 – Test circuits for the verification of operation in the case of a sudden appearance of residual pulsating direct current (without breaking device)	208
Figure M.9 – Test circuits for the verification of operation in the case of a sudden appearance of residual pulsating direct current (with breaking device)	209
Figure M.10 – Test circuits for the verification of operation in the case of a residual pulsating direct current superimposed by smooth direct current of 6 mA	210
Figure M.11 – Test circuits for the verification of operation in the case of a slowly rising residual smooth direct current	211
Figure M.12 – Test circuits for the verification of operation in the case of a sudden appearance of residual smooth direct current (without breaking device).....	212
Figure M.13 – Test circuits for the verification of operation in the case of a sudden appearance of residual smooth direct current (with breaking device).....	213
Figure M.14 – Test circuits for the verification of operation in the case of a slowly rising residual current resulting from a fault in a circuit fed by a three-pulse star or a six-pulse bridge connection.....	214
Figure M.15 – Test circuits for the verification of operation in the case of a slowly rising residual current resulting from a fault in a circuit fed by a two-pulse bridge connection line-to-line.....	215
Figure M.16 – Test circuit for the verification of the behaviour of MRCDs with separate sensing means in the case of a failure of the sensor means connection	216
Figure M.17 – Test circuit for the verification of the behaviour of MRCD with separate sensing means under short-circuit conditions	217
Figure M.18 – Test circuit for the verification of the behaviour of MRCD with integral sensing means under short-circuit conditions	218
Figure M.19 – Test circuit for the verification of the behaviour of terminal type MRCD under short-circuit conditions.....	219
Figure M.20 – Verification of immunity to radiated r.f. electromagnetic fields – Test set-up for MRCD with separate sensing means (additional to the test of Annex B)	220
Figure M.21 – Verification of immunity to electrical fast transients/bursts (EFT/B) on the sensing means connection of an MRCD with separate sensing means (additional to the test of Annex B)	221

Figure M.22 – Verification of immunity to conducted disturbances induced by r.f. fields –
 Test set up for MRCD with separate sensing means (additional to the test of Annex B)..... 221

2	Table 1 (void).....	19
	Table 2 – Ratio n between short-circuit making capacity and short-circuit breaking capacity and related power factor (for a.c. circuit-breakers)	20
	Table 3 – Minimum values of rated short-time withstand current	20
	Table 4 – Selectivity categories	21
	Table 5 – Preferred values of the rated control supply voltage, if different from that of the main circuit	21
	Table 6 – Characteristics of the opening operation of inverse time-delay over-current opening releases at the reference temperature	29
	Table 7 – Temperature-rise limits for terminals and accessible parts	30
	Table 8 – Number of operating cycles.....	32
	Alphabetical index of tests.....	35
	Table 9 – Overall schema of test sequences ^a	36
	Table 9a – Applicability of test sequences according to the relationship between I_{CS} , I_{CU} and I_{CW} ^a	37
2	Table 9b – Applicability of tests or test sequences to 1, 2 and 4-pole circuit-breakers according to the alternative programme 1 of 8.3.1.4	39
	Table 9c – Applicability of tests or test sequences to 1, 2 and 3-pole circuit-breakers according to the alternative programme 2 of 8.3.1.4	41
	Table 10 – Number of samples for test	44
	Table 11 – Values of power factors and time constants corresponding to test currents.....	46
	Table 12 – Test circuit characteristics for overload performance	57
	Table B.1 – Operating characteristic for non-time-delay type.....	86
	Table B.2 – Operating characteristic for time-delay-type having a limiting non-actuating time of 0,06 s	87
	Table B.3 – Requirements for CBRs functionally dependent on line voltage	91
	Table B.4 – Additional test sequences	94
	Table B.5 – Tripping current range for CBRs in case of an earth fault comprising a d.c. component.....	99
	Table F.1 – Test parameters for current dips and interruptions	121
	Table J.1 – EMC – Immunity tests	153
	Table J.2 – Reference data for immunity test specifications	154
	Table J.3 – EMC – Emission tests	157
	Table J.4 – Reference data for emission test specifications	157
	Table M.1 – Product information.....	184
	Table M.2 – Requirements for MRCDs with voltage source	186
	Table M.3 – Test sequences	188

AUSTRALIAN/NEW ZEALAND STANDARD

Low-voltage switchgear and controlgear**Part 2:
Circuit-breakers****1 General**

The provisions of the general rules dealt with in IEC 60947-1 are applicable to this standard, where specifically called for. Clauses and subclauses, tables, figures and annexes of the general rules thus applicable are identified by reference to IEC 60947-1, for example, 1.2.3 of IEC 60947-1, Table 4 of IEC 60947-1, or Annex A of IEC 60947-1.

1.1 Scope and object

This standard applies to circuit-breakers, the main contacts of which are intended to be connected to circuits, the rated voltage of which does not exceed 1 000 V a.c. or 1 500 V d.c.; it also contains additional requirements for integrally fused circuit-breakers.

It applies whatever the rated currents, the method of construction or the proposed applications of the circuit-breakers may be.

The requirements for circuit-breakers which are also intended to provide earth-leakage protection are contained in Annex B.

The additional requirements for circuit-breakers with electronic over-current protection are contained in Annex F.

The additional requirements for circuit-breakers for IT systems are contained in Annex H.

The requirements and test methods for electromagnetic compatibility of circuit-breakers are contained in Annex J.

The requirements for circuit-breakers not fulfilling the requirements for over-current protection are contained in Annex L.

The requirements for modular residual current devices (without integral current breaking device) are contained in Annex M.

The requirements and test methods for electromagnetic compatibility of circuit-breaker auxiliaries are contained in Annex N.

Supplementary requirements for circuit-breakers used as direct-on-line starters are given in IEC 60947-4-1, applicable to low-voltage contactors and starters.

The requirements for circuit-breakers for the protection of wiring installations in buildings and similar applications, and designed for use by uninstructed persons, are contained in IEC 60898.

The requirements for circuit-breakers for equipment (for example electrical appliances) are contained in IEC 60934.