

Australian/New Zealand Standard™

Low-voltage switchgear and controlgear

**Part 5.9: Control circuit devices and
switching elements — Flow rate switches**



AS/NZS IEC 60947.5.9:2015

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-006, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of Standards Australia on 27 May 2015 and on behalf of the Council of Standards New Zealand on 29 May 2015. This Standard was published on 29 June 2015.

The following are represented on Committee EL-006:

Association of Accredited Certification Bodies
Ausgrid
Australian Chamber of Commerce and Industry
Australian Industry Group
Bureau of Steel Manufacturers of Australia
Business New Zealand
Electrical Contractors Association of New Zealand
Engineers Australia
National Electrical and Communications Association
National Electrical Switchboard Manufacturers Association
Rail Industry Safety and Standards Board (RISSB)

Keeping Standards up-to-date

Standards are living documents, which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand website at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

Low-voltage switchgear and controlgear

**Part 5.9: Control circuit devices and
switching elements – Flow rate switches**

First published as AS/NZS IEC 60947.5.9:2015.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

ISBN 978 1 76035 080 2

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-006, Industrial Switchgear and Controlgear.

The objective of this Standard is to state for flow rate switches—

- (a) definitions;
- (b) classifications;
- (c) characteristics;
- (d) product information;
- (e) normal service, mounting and transport conditions;
- (f) constructional and performance requirements; and
- (g) tests to verify rated characteristics.

This Standard is identical with, and has been reproduced from, IEC 60947-5-9, Ed. 1.0 (2006), *Low-voltage switchgear and controlgear, Part 5.9: Control circuit devices and switching elements—Flow rate switches*.

As this Standard is reproduced from an International Standard, the following applies:

- (i) In the source text ‘this part of IEC 60947’ should read ‘this Australian/New Zealand Standard’.
- (ii) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
IEC		AS/NZS IEC	
60947	Low-voltage switchgear and controlgear	60947	Low-voltage switchgear and controlgear
60947-1	Part 1: General rules	60947.1	Part 1: General rules
60947-5-2	Part 5.2: Control circuit devices and switching elements—Proximity switches Amendment 1 (1999) Amendment 2 (2003)	60947.5.2	Part 5.2: Control circuit devices and switching elements—Proximity switches
		AS/NZS	
61000	Electromagnetic compatibility (EMC)	61000	Electromagnetic compatibility (EMC)
61000-3-2	Part 3.2: Limits—Limits for harmonic current emissions (equipment input current ≤16 A per phase)	61000.3.2	Part 3.2: Limits—Limits for harmonic current emissions (equipment input current ≤16 A per phase)

IEC		AS/NZS	
61000-3-3	Part 3-3: Limits— Section 3: Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems for equipment with rated current ≤ 16 A per phase and not subject to conditional connection Amendment 1 (2001) Amendment 2 (2005)	61000.3.3	Part 3.3: Limits— Section 3: Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems for equipment with rated current ≤ 16 A per phase and not subject to conditional connection
		AS/NZS IEC	
61000-4-2	Part 4-2: Testing and measurement techniques—Electrostatic discharge immunity test Amendment 1 (1998) Amendment 2 (2000)	61000.4.2	Part 4.2: Testing and measurement techniques—Electrostatic discharge immunity test
61000-4-3	Part 4-3: Testing and measurement techniques—Radiated, radio-frequency, electromagnetic field immunity test	61000.4.3	Part 4.3: Testing and measurement techniques—Radiated, radio-frequency, electromagnetic field immunity test
61000-4-4	Part 4-4: Testing and measurement techniques—Electrical fast transient/burst immunity test	61000.4.4	Part 4.4: Testing and measurement techniques—Electrical fast transient/burst immunity test
61000-4-6	Part 4-6: Testing and measurement techniques—Immunity to conducted disturbances, induced by radio-frequency fields Amendment 1 (2004) Amendment 2 (2006)	61000.4.6	Part 4.6: Testing and measurement techniques—Immunity to conducted disturbances, induced by radio-frequency fields
		AS/NZS	
61000-4-8	Part 4-8: Testing and measurement techniques—Power frequency magnetic field immunity test Amendment 1 (2000)	61000.4.8	Part 4.8: Testing and measurement techniques—Power frequency magnetic field immunity test
61000-4-11	Part 4-11: Testing and measurement techniques—Voltage dips, short interruptions and voltage variations immunity tests	61000.4.11	Part 4.11: Testing and measurement techniques—Voltage dips, short interruptions and voltage variations immunity tests
61000-4-13	Part 4-13: Testing and measurement techniques—Harmonics and interharmonics including mains signalling at a.c. power port, low-frequency immunity tests	61000.4.13	Part 4.13: Testing and measurement techniques—Harmonics and interharmonics including mains signalling at a.c. power port, low-frequency immunity tests
IEC		AS/NZS	
61558-2-6	Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers	61558.2.6	Part 2.6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers (IEC 61558-2-6 Ed 2, MOD)

CISPR		AS/NZS CISPR	
11	Industrial, scientific and medical (ISM) radio-frequency equipment—Electromagnetic Radio-frequency disturbance characteristics—Limits and methods of measurement Amendment 1:2004	11	Industrial, scientific and medical (ISM) radio-frequency equipment— Electromagnetic Radio-frequency disturbance characteristics—Limits and methods of measurement

Only normative references that have been adopted as Australian or Australian/New Zealand Standards have been listed.

CONTENTS

1	General	7
1.1	Scope and object.....	7
1.2	Normative references	7
2	Terms and definitions	8
2.1	Basic definitions	9
2.2	Characteristics of a flow rate switch	10
2.3	Delay times	11
3	Classification.....	11
3.1	General	11
3.2	Classification according to sensing means	12
3.3	Classification according to the construction form	12
3.4	Classification according to the switching element function.....	12
3.5	Classification according to the type of output.....	12
3.6	Classification according to the method of connection.....	12
4	Characteristics	12
4.1	Summary of characteristics	12
4.2	Operating conditions	12
4.3	Rated and limiting values for the flow rate switch.....	13
4.4	Utilization categories for the switching element	15
5	Product information	15
5.1	Nature of information.....	15
5.2	Marking	15
5.3	Instruction for installation, operation and maintenance	16
6	Normal service, mounting and transport conditions.....	16
6.1	Normal service conditions	16
6.2	Conditions during transport and storage	17
6.3	Mounting	17
6.4	Indicating means	17
7	Constructional and performance requirements.....	17
7.1	Constructional requirements	17
7.2	Performance requirements	19
7.3	Shock and vibration.....	25
8	Tests.....	25
8.1	Kinds of tests	26
8.2	Compliance with constructional requirements	26
8.3	Performance.....	26
8.4	Verification of set point and delay times	33
8.5	Verification of the electromagnetic compatibility	34
8.6	Test results and test report.....	36

Figure 1 – Relationship between operating points of a flow rate switch	13
Figure 2 – Relationship between U_e and U_B	13
Figure 3 – Test circuit for the verification of time delay before availability	29
Figure 4 – Signal output across load in Figure 3	29
Figure 5 – Test circuit for the verification of minimum operational current OFF-state current, voltage drop and independent snap action	30
Figure 6 – Short-circuit testing	33
Figure 7 – Testing set point and delay times	34
Table 1 – Classification of flow rate switches	1
Table 2 – Acceptance criteria	23
Table 3 – Immunity tests	24

AUSTRALIAN/NEW ZEALAND STANDARD

Low-voltage switchgear and controlgear

Part 5.9:

Control circuit devices and switching elements—Flow rate switches

1 General**1.1 Scope and object**

This part of IEC 60947 applies to flow rate switches that sense the rate of flow of a gas, a liquid or a granular solid. These switches change their output state if a pre-set value for the speed of flow is exceeded.

These flow rate switches are self-contained, have semiconductor switching element(s) and are intended to be connected to circuits, the rated voltage of which does not exceed 250 V 50 Hz/60 Hz a.c. or 300 V d.c.

This standard does not specify the additional measures that are necessary for flow rate switches used in conjunction with explosive sensing materials and in an explosive location.

This standard is not intended to cover devices with analogue outputs.

The object of this standard is to state for flow rate switches:

- definitions;
- classifications;
- characteristics;
- product information;
- normal service, mounting and transport conditions;
- constructional and performance requirements;
- tests to verify rated characteristics.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60445:1999, *Basic and safety principles for man-machine interface, marking and identification – Identification of conductors by colours or numerals*

IEC 60947-1:2004, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 60947-5-2:1997, *Low-voltage switchgear and controlgear – Part 5-2: Control circuit devices and switching elements – Proximity switches*

Amendment 1 (1999)

Amendment 2 (2003)