

Australian/New Zealand Standard™

**Connecting devices for low-voltage
circuits for household and similar
purposes**

**Part 2.2: Particular requirements for
connecting devices as separate entities
with screwless-type clamping units**



AS/NZS IEC 60998.2.2:2012

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-004, Electrical Accessories. It was approved on behalf of the Council of Standards Australia on 8 June 2012 and on behalf of the Council of Standards New Zealand on 8 June 2012.

This Standard was published on 25 June 2012.

The following are represented on Committee EL-004:

Australian Industry Group
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Electrical Compliance Testing Association
Electrical Regulatory Authorities Council
Engineers Australia
International Accreditation New Zealand
Ministry of Economic Development, New Zealand
New Zealand Manufacturers and Exporters Association
NSW Office of Fair Trading
Office of the Technical Regulator, SA
Plastics Industry Pipe Association of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand website at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS IEC 60998.2.2.

Australian/New Zealand Standard™

**Connecting devices for low voltage
circuits for household and similar
purposes**

**Part 2.2: Particular requirements for
connecting devices as separate entities
with screwless-type clamping units**

Originally as AS/NZS 60998.2.2:1998.
Jointly revised and designated AS/NZS IEC 60998.2.2:2012.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-004, Electrical Accessories to supersede AS/NZS 60998.2.2:1998 *Connecting devices for low-voltage circuits for household and similar purposes—Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units*.

The objective of this Standard is to provide Australian and New Zealand electrical industries with general requirements for connecting devices with screwless-type clamping units primarily suitable for connecting unprepared conductors.

The essential safety requirements in AS/NZS 3820, *Essential safety requirements for electrical equipment* that could be applicable to connecting devices for low voltage circuits for households are covered by this Standard.

This Standard is identical with, and has been reproduced from IEC 60998-2-2, Ed. 2.0 (2002), *Connecting devices for low-voltage circuits for household and similar purposes—Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units*. See the Foreword for guidance on how to use this Standard. Note that IEC 60998-1 has been adopted as AS/NZS IEC 60998.1.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number appears on the cover and title page while the International Standard number appears only on the cover.
- (b) A full point substitutes for a comma when referring to a decimal marker.

The terms ‘normative’ and ‘informative’ are used to define the application of the annex to which they apply. A ‘normative’ annex is an integral part of a standard, whereas an ‘informative’ annex is only for information and guidance.

CONTENTS

1	Scope	5
2	Normative references.....	5
3	Definitions	5
4	General	6
5	General notes on tests.....	6
6	Main characteristics	6
7	Classification	6
8	Marking	6
9	Protection against electric shock.....	7
10	Connection of conductors	7
11	Construction	11
12	Resistance to ageing, to humid conditions, to ingress of solid foreign objects and to harmful ingress of water.....	12
13	Insulation resistance and electric strength	12
14	Mechanical strength.....	12
15	Temperature rise	14
16	Resistance to heat.....	15
17	Clearances and creepage distances	15
18	Resistance of insulating material to abnormal heat and fire.....	15
19	Resistance of insulating material to tracking	16
20	EMC requirement.....	16
	Annex AA (normative) Number of sets of samples to be submitted to the tests.....	20
	Annex BB (informative) Approximate relationship between conductors of cross-sectional areas in mm ² and American Wire Gauge (AWG) sizes as used in North America	21
	Annex CC (informative) Examples for temperature-rise test according to 15.4.....	23
	Figure 101 – Test apparatus according to 10.105	16
	Figure 102 – Examples of screwless-type clamping units	17
	Figure 103 – Information for the bending test	18
	Figure CC.1 – Temperature-rise test – examples	23
	Table 101 – Rated connecting capacity and connectable conductors.....	8
	Table 102 – Relationship between mass, height and cross-sectional area of conductors.....	10
	Table 103 – Relationship between pull force and cross-sectional area	10
	Table 104 – Deflection test forces	13
	Table AA.1 – Number of sets of samples and test sequences.....	20
	Table BB.1 – Wire size, mm ² versus AWG.....	21
	Table BB.2 – Rated connecting capacity and connectable conductors.....	21
	Table BB.3 – Deflection test forces	22

FOREWORD

This Part 2-2 is intended to be used in conjunction with IEC 60998-1. It was established on the basis of the second edition (2002) of that standard.

It supplements or modifies the corresponding clauses in IEC 60998-1, so as to convert that publication into the IEC standard: *Particular requirements for connecting devices as separate entities with screwless-type clamping units*.

Where a particular subclause of Part 1 is not mentioned in this Part 2-2, that subclause applies as far as is reasonable. Where this standard states “addition”, “modification” or “replacement”, the relevant requirements, test specification or explanatory matter in Part 1 should be adapted accordingly.

In this standard:

- a) the following print types are used:
 - requirements proper: in roman type;
 - test specifications: *in italic type*;
 - explanatory matter: in smaller roman type.
- b) Subclauses and figures which are additional to those in Part 1 are numbered starting from 101; additional annexes are lettered AA, BB, etc.

AUSTRALIAN/NEW ZEALAND STANDARD

Connecting devices for low-voltage circuits for household and similar purposes**Part 2.2:**

Particular requirements for connecting devices as separate entities with screwless-type clamping units

1 Scope

This clause of Part 1 is applicable.

Addition:

This standard applies to connecting devices with screwless-type clamping units primarily suitable for connecting unprepared conductors.

In this standard, screwless-type terminals are referred to as terminals.

NOTE This standard does not include insulation piercing connecting devices (IEC 60998-2-3), twist-on connecting devices (IEC 60998-2-4) and flat, quick-connect terminations (IEC 60998-2-5).

2 Normative references

This clause of Part 1 is applicable.

3 Definitions

This clause of Part 1 is applicable except as follows:

*Addition:***3.101****screwless-type terminal**

terminal for the connection and subsequent disconnection of two or more conductors, the connection being made directly or indirectly by means of springs, wedges, or the like

NOTE Examples of screwless-type terminals are given in Figure 102.

3.101.1**universal terminal**

terminal for the connection and disconnection of all types of conductors (rigid and flexible)

3.101.2**non-universal terminal**

terminal for the connection and disconnection of a certain kind of conductor only (for example, solid conductors only or rigid [solid and stranded] conductors only)