

Australian/New Zealand Standard

**Low-voltage switchgear and controlgear assemblies**

**Part 5: Assemblies for power distribution in public networks**



## **AS/NZS IEC 61439.5:2016**

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-006, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of Standards Australia on 16 March 2016 and by the New Zealand Standards Approval Board on 4 May 2016.  
This Standard was published on 24 May 2016.

---

The following are represented on Committee EL-006:

Association of Accredited Certification Bodies  
Australian Industry Group  
Bureau of Steel Manufacturers of Australia  
Business New Zealand  
Electrical Contractors Association of New Zealand  
Engineers Australia  
National Electrical and Communications Association  
National Electrical Switchboard Manufacturers Association  
Rail Industry Safety and Standards Board

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at [www.saiglobal.com](http://www.saiglobal.com) or Standards New Zealand web site at [www.standards.govt.nz](http://www.standards.govt.nz) and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of Standards Australia or the New Zealand Standards Executive at the address shown on the back cover.

---

Australian/New Zealand Standard™

## Low-voltage switchgear and controlgear assemblies

### Part 5: Assemblies for power distribution in public networks

Originally as AS/NZS 3439.5:2001.

Second edition 2009.

Completely revised and redesignated as AS/NZS IEC 61439.5:2016.

#### **COPYRIGHT**

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, PO Box 10729, Wellington 6011.

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-006, Industrial Switchgear and Controlgear, to supersede AS/NZS 3439.5:2009 five years from the date of publication.

The AS/NZS 61439 series will supersede the AS/NZS 3439 series five years from the date of publication. During this period, low-voltage switchgear and controlgear assemblies may comply with either series. After five years it is anticipated that the AS/NZS 3439 series will be withdrawn.

The objective of this Standard is to provide the user with guidance on the specification that should be provided in order to achieve the desired design of a low-voltage switchgear and controlgear assembly.

This Standard is identical with, and has been reproduced from IEC 61439-5, Ed. 2.0 (2014), *Low-voltage switchgear and controlgear assemblies, Part 5: Assemblies for power distribution in public networks* and its Corrigendum 1 (2015), which has been added at the end of the source text.

Where tests on the ASSEMBLY have been conducted in accordance with the IEC 61439, IEC 61439 or AS/NZS 3439 series and the test results fulfil the requirements of the relevant part of AS/NZS 61439, the verification of these requirements need not be repeated (see Clause 10.1).

This edition includes the following significant technical changes with respect to the latest edition:

- (a) Confirmation that tests carried out on the most onerous PENDA are deemed to verify the performance of similar and less onerous assemblies of the same general construction and rating.
- (b) More precise timing/conditions for impact force with stand tests for PENDAs designed for operation in an arctic climate.
- (c) Correction of the direction of the applied force in the static load test.
- (d) This Standard is to be read in conjunction with AS/NZS 61439.1. The provisions of the general rules dealt with in AS/NZS 61439.1 (hereinafter referred to as Part 1) are only applicable to this standard insofar as they are specifically cited. When this standard states ‘addition’, ‘modification’ or ‘replacement’, the relevant text in Part 1 is to be adapted accordingly.
- (e) Subclauses that are numbered with a 101 (102, 103 etc.) suffix are additional to the same subclause in Part 1.
- (f) Tables and figures in this Part 5 that are new are numbered starting with 101.
- (g) New annexes in this Part 5 are lettered AA, BB, etc.
- (h) In this Standard, terms written in small capitals are defined in Clause 3.

The reader’s attention is drawn to the fact that Annex DD lists all of the ‘in-some-country’ clauses on differing practices of a less permanent nature relating to the subject of this standard.

As this Standard is reproduced from an International Standard, the following applies:

- (i) In the source text ‘this part of IEC 61439’ should read ‘this Australian/New Zealand Standard’.
- (ii) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>	<i>Australian/New Zealand Standard</i>
IEC	AS/NZS
61439 Low-voltage switchgear and controlgear assemblies	61439 Low-voltage switchgear and controlgear assemblies
61439-1 Part 1: General rules	61439.1 Part 1: General rules (IEC 61439-1, Ed. 2.0 (2011), MOD)

Only normative references that have been adopted as Australian or Australian/New Zealand Standards have been listed.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the annexes to which they apply. A 'normative' annex is an integral part of a Standard, whereas an 'informative' annex is only for information and guidance.

Currently in preview, click buy full version

## CONTENTS

1	Scope.....	5
2	Normative references.....	6
3	Terms and definitions .....	6
4	Symbols and abbreviations .....	7
5	Interface characteristics.....	7
6	Information.....	8
7	Service conditions .....	8
8	Constructional requirements .....	9
9	Performance requirements.....	11
10	Design verification .....	11
11	Routine verification.....	24
	Annexes .....	25
	Annex O (informative) Guidance on temperature rise verification .....	26
	Annex AA (normative) Cross-section of conductors.....	27
	Annex BB (informative) Items subject to agreement between the ASSEMBLY manufacturer and the user.....	29
	Annex CC (informative) Design verification.....	33
	Annex DD (informative) List of notes concerning certain countries .....	34
	Bibliography .....	35
	Figure 101 – Typical distribution network.....	6
	Figure 102 – Diagram of test to verify resistance to shock load of a PENDA-O .....	14
	Figure 103 – Diagram of test to verify impact force withstand of a PENDA-O.....	15
	Figure 104 – Diagram of test to verify resistance to static load .....	16
	Figure 105 – Sandbag for test to verify the resistance to shock load .....	17
	Figure 106 – Diagram of test to verify resistance to torsional stress of a PENDA-O .....	18
	Figure 107 – Diagram of test to verify the mechanical strength of doors .....	21
	Figure 108 – Striker element for test of resistance to mechanical shock impacts induced by sharp-edged objects.....	22
	Figure 109 – Typical test arrangement for mechanical strength of base.....	23
	Table 101 – Values of assumed loading .....	8
	Table 102 – Axial load to be applied to the inserts .....	22
	Table AA.1 – Minimum and maximum cross-section of copper and aluminium conductors, suitable for connection (see 8.8).....	27
	Table AA.2 – Standard cross-sections of round copper conductors and approximate relationship between mm <sup>2</sup> and AWG/kcmil sizes (see 8.8 of Part 1).....	28
	Table BB.1 – Items subject to agreement between the ASSEMBLY manufacturer and the user.....	29
	Table CC.1 – List of design verifications to be performed.....	33

## AUSTRALIAN/NEW ZEALAND STANDARD

**Low-voltage switchgear and controlgear assemblies**

## Part 5:

## Assemblies for power distribution in public networks

**1 Scope**

This part of IEC 61439 defines the specific requirements for public electricity network distribution assemblies (PENDAs).

PENDAs have the following criteria:

- used for the distribution of electrical energy in three phase systems for which the rated voltage does not exceed 1 000 V a.c. (see Figure 101 for a typical distribution network);
- stationary;
- open ASSEMBLIES are not covered by this standard;
- suitable for installation in places where only skilled persons have access for their use, however, outdoor types may be installed in situations that are accessible to ordinary persons;
- for indoor or outdoor use.

The object of this standard is to state the definitions and to specify the service conditions, construction requirements, technical characteristics and tests for PENDAs. Network parameters may require tests at higher performance levels.

PENDAs may also include control and or signalling devices associated with the distribution of electrical energy.

This standard applies to all PENDAs whether they are designed, manufactured on a one-off basis or fully standardised and manufactured in quantity.

The manufacture and/or assembly may be carried out other than by the original manufacturer (see 3.10.1 of IEC 61439-1:2011).

This standard does not apply to individual devices and self-contained components, such as motor starters, fuse switches, electronic equipment, etc. which comply with the relevant product standards.

This standard does not apply to specific types of ASSEMBLIES covered by other parts of IEC 61439 series.