

Australian/New Zealand Standard™

Electroacoustics—Sound level meters

Part 1: Specifications

STANDARDS
Australia



STANDARDS®
NEW ZEALAND
PAEREWĀ AOTEAROA



AS/NZS IEC 61672.1:2019

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee AV-003, Acoustics Human Effects. It was approved on behalf of the Council of Standards Australia on 29 January 2019 and by the New Zealand Standards Approval Board on 30 January 2019.

This Standard was published on 25 February 2019.

The following are represented on Committee AV-003:

- Accident Compensation Corporation (New Zealand)
- Association of Australasian Acoustical Consultants
- Australian Acoustical Society
- Australian Chamber of Commerce and Industry
- Australian Council of Trade Unions
- Australian Hearing
- Engineers Australia
- New Zealand Audiological Society
- Worksafe Division, Department of Commerce, Western Australia

This Standard was issued in draft form for comment as DR AS IEC 61672.1:2018

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

ISBN 978 1 76072 370 5

Australian/New Zealand Standard™

Electroacoustics—Sound level meters

Part 1: Specifications

Originated as AS Z37—1967 and AS Z38—1967.

Previous edition AS 1259.1—1990 and AS 1259.2—1990.

AS 1259.1—1990 and AS 1259.2—1990 revised, amalgamated and redesignated in part as AS IEC 61672.1—2004.

Completely revised and redesignated as AS/NZS IEC 61672.1:2019.

COPYRIGHT

© IEC 2019 — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2019

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee AV-003, Acoustics Human Effects, to supersede AS IEC 61672.1—2004, *Electroacoustics—Sound level meters, Part 1: Specifications*.

The objective of this Standard is to provide electroacoustical performance specifications for three kinds of sound measuring instruments:

- (a) time-weighting sound level meters that measure exponential-time-weighted, frequency-weighted sound levels;
- (b) integrating-averaging sound level meters that measure time-averaged, frequency-weighted sound levels; and
- (c) integrating sound level meters that measure frequency-weighted sound exposure levels.

Sound level meters specified in this Standard are intended to measure sounds which are generally in the range of human hearing. Two performance categories, class 1 and class 2, are specified in this Standard.

This Standard is identical with, and has been reproduced from, IEC 61672.1:2013 (ED 2.0), *Electroacoustics — Sound level meters — Part 1: Specifications*.

As this document has been reproduced from an International Standard, a full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

Currently in preview, click buy full version

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	8
3 Terms and definitions	8
4 Reference environmental conditions	14
5 Performance specifications.....	14
5.1 General.....	14
5.2 Adjustments at the calibration check frequency	14
5.3 Corrections to indicated levels.....	17
5.3.1 General	17
5.3.2 Reflections and diffraction	17
5.3.3 Windscreens.....	18
5.3.4 Format for correction data	18
5.3.5 Corrections for use during periodic testing.....	19
5.4 Directional response.....	19
5.5 Frequency weightings.....	20
5.6 Level linearity.....	23
5.7 Self-generated noise	24
5.8 Time-weightings F and S	24
5.9 Toneburst response.....	24
5.10 Response to repeated tonebursts	26
5.11 Overload indication	27
5.12 Under-range indication	27
5.13 C-weighted peak sound level.....	27
5.14 Stability during continuous operation.....	28
5.15 High-level stability.....	28
5.16 Reset	29
5.17 Thresholds	29
5.18 Display.....	29
5.19 Analogue or digital output.....	29
5.20 Timing facilities	30
5.21 Radio-frequency emissions and disturbances to a public power supply.....	30
5.22 Crosstalk.....	31
5.23 Power supply.....	31
6 Environmental, electrostatic, and radio-frequency requirements	32
6.1 General	32
6.2 Static pressure	32
6.3 Air temperature	32
6.4 Humidity.....	33
6.5 Electrostatic discharge	33
6.6 A.C. power-frequency and radio-frequency fields.....	33
6.7 Mechanical vibration.....	34
7 Provision for use with auxiliary devices	35
8 Marking	35
9 Instruction Manual	35

9.1	General	35
9.2	Information for operation	36
9.2.1	General	36
9.2.2	Design features	36
9.2.3	Power supply	37
9.2.4	Adjustments at the calibration check frequency	37
9.2.5	Corrections to indicated levels	37
9.2.6	Operating the sound level meter	37
9.2.7	Accessories	38
9.2.8	Influence of variations in environmental conditions	38
9.3	Information for testing	39
Annex A (informative)	Relationship between tolerance interval, corresponding acceptance interval and the maximum-permitted uncertainty of measurement	41
Annex B (normative)	Maximum-permitted uncertainties of measurement	42
Annex C (informative)	Example assessments of conformance to specifications of this standard	44
Annex D (normative)	Frequencies at fractional-octave intervals	47
Annex E (normative)	Analytical expressions for frequency-weightings C, A, and Z	49
Figure 1	– Principal steps involved in forming a time-weighted sound level	10
Figure A.1	– Relationship between tolerance interval, corresponding acceptance interval and the maximum-permitted uncertainty of measurement	41
Figure C.1	– Examples of assessment of conformance	46
Table 1	– Acceptance limits for the difference between a measured windscreen correction and the corresponding correction given in the Instruction Manual	18
Table 2	– Acceptance limits for deviations in directional response from the design goal	20
Table 3	– Frequency weightings and acceptance limits	22
Table 4	– Reference 4 kHz toneburst responses and acceptance limits	25
Table 5	– Reference differences for C-weighted peak sound levels and acceptance limits	28
Table 6	– Limits for conducted disturbance to the voltage of a public supply of electric power	31
Table B.1	– Maximum permitted uncertainties of measurement for a coverage probability of 95%	42
Table C.1	– Examples of assessment of conformance	45
Table D.1	– Frequencies at one-third-octave intervals	47
Table D.2	– Frequencies at one-sixth-octave intervals	48
Table D.3	– Frequencies at one-twelfth-octave intervals	48

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTROACOUSTICS –
SOUND LEVEL METERS –****Part 1: Specifications**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, accept IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61672-1 has been prepared by IEC technical committee 29, Electroacoustics, in cooperation with the International Organization of Legal Metrology (OIML).

This second edition cancels and replaces the first edition published in 2002. This second edition constitutes a technical revision.

The main technical changes with respect to the previous edition are as follows:

In this second edition, conformance to specifications is demonstrated when:

- a) measured deviations from design goals do not exceed the applicable acceptance limits, and
- b) the uncertainty of measurement does not exceed the corresponding maximum-permitted uncertainty, with both uncertainties determined for a coverage probability of 95 %.

The text of this second edition is based on that of the first edition and the following documents:

FDIS	Report on voting
29/812/FDIS	29/823/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61672 series, published under the general title *Electroacoustics Sound level meters*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

For assessments of conformance to performance specifications, this second edition of IEC 61672-1 uses different criteria than were used for the 2002 first edition.

In the period from 1961 to 1985, International Standards for sound level meters did not provide any requirements or recommendations to account for the uncertainty of measurement in assessments of conformance to specifications.

This absence of requirements or recommendations to account for uncertainty of measurement created ambiguity in determinations of conformance to specifications for situations where a measured deviation from a design goal was close to a limit of the allowed deviation. If conformance was determined based on whether a measured deviation did or did not exceed the limits, the end-user of the sound level meter incurred the risk that the true deviation from a design goal exceeded the limits.

To remove this ambiguity, IEC Technical Committee 29, at its meeting in 1996, adopted a policy to account for measurement uncertainty in assessments of conformance to International Standards that it prepares.

The first edition (2002) of IEC 61672-1 accounted for measurement uncertainty by giving two explicit criteria for determining conformance to the specifications. The two criteria were (a) that measured deviations from design goals, extended by the expanded uncertainty of measurement, do not exceed the applicable tolerance limits and (b) that the expanded uncertainty of measurement does not exceed agreed upon maximum values. For most performance specifications, the tolerance limits were calculated essentially by extending the allowances for design and manufacturing from the 1961 and 1985 International Standards for sound level meters by the applicable maximum-permitted expanded uncertainties of measurement. Tolerance limits were intended to represent the limits for true deviations from design goals with a coverage probability of 95 %.

This second edition of IEC 61672-1 uses an amended criterion for assessing conformance to a specification. Conformance is demonstrated when (a) measured deviations from design goals do not exceed the applicable *acceptance limits* and (b) the uncertainty of measurement does not exceed the corresponding maximum-permitted uncertainty. Acceptance limits are analogous to the allowances for design and manufacturing implied in the first edition (2002) of IEC 61672-1. Actual and maximum-permitted uncertainties are determined for a coverage probability of 95 %. The amended criterion for assessing conformance does not necessitate any change to the design of a sound level meter in order to conform to the specifications of this International Standard.

The maximum-permitted uncertainties of measurement are not equivalent to the uncertainties associated with the measurement of a sound level. The uncertainty of a measured sound level is evaluated from the anticipated deviations of the electroacoustical performance of the sound level meter from the relevant design goals as well as estimates of the uncertainties associated with the specific measurement situation. Unless more-specific information is available, the evaluation of the contribution of a specific sound level meter to a total measurement uncertainty can be based on the acceptance limits and maximum-permitted uncertainties specified in this standard.

ELECTROACOUSTICS – SOUND LEVEL METERS –

Part 1: Specifications

1 Scope

This part of IEC 61672 gives electroacoustical performance specifications for three kinds of sound measuring instruments:

- a time-weighting sound level meter that measures exponential-time-weighted, frequency-weighted sound levels;
- an integrating-averaging sound level meter that measures time-averaged, frequency-weighted sound levels; and
- an integrating sound level meter that measures frequency-weighted sound exposure levels.

Sound level meters conforming to the requirements of this standard have a specified frequency response for sound incident on the microphone from one principal direction in an acoustic free field or successively from random directions.

Sound level meters specified in this standard are intended to measure sounds generally in the range of human hearing.

NOTE The AU frequency weighting specified in IEC 61012 can be applied for measurements of A-weighted sound levels of audible sound in the presence of a source that contains spectral components at frequencies greater than 20 kHz.¹

Two performance categories, class 1 and class 2, are specified in this standard. In general, specifications for class 1 and class 2 sound level meters have the same design goals and differ mainly in the acceptance limits and the range of operational temperature. Acceptance limits for class 2 are greater than, or equal to, those for class 1.

This standard is applicable to a range of designs for sound level meters. A sound level meter may be a self-contained hand-held instrument with an attached microphone and a built-in display device. A sound level meter may be comprised of separate components in one or more enclosures and may be capable of displaying a variety of acoustical signal levels. Sound level meters may include extensive analogue or digital signal processing, separately or in combination, with multiple analogue and digital outputs. Sound level meters may include general-purpose computers, recorders, printers, and other devices that form a necessary part of the complete instrument.

Sound level meters may be designed for use with an operator present or for automatic and continuous measurements of sound level without an operator present. Specifications in this standard for the response to sound waves apply without an operator present in the sound field.

¹ IEC 61012, *Filters for the measurement of audible sound in the presence of ultrasound*.