

Australian/New Zealand Standard™

Electromagnetic compatibility (EMC)

**Part 2.8: Environment—Voltage dips
and short interruptions on public
electric power supply systems with
statistical measurement results**



AS/NZS IEC/TR 61000.2.8:2009

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-034, Power Quality. It was approved on behalf of the Council of Standards Australia on 3 June 2009 and on behalf of the Council of Standards New Zealand on 19 June 2009.

This Standard was published on 15 July 2009.

The following are represented on Committee EL-034:

Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Information Industry Association
Bureau of Steel Manufacturers of Australia
Consumers' Federation of Australia
Electrical Regulatory Authorities Council
Electricity Engineers Association (New Zealand)
Energy Networks Association
Engineers Australia
Ministry of Economic Development (New Zealand)
National Measurement Institute
New Zealand Coordinating Committee on Power & Telecommunication Systems
New Zealand Electric Fence Energiser Manufacturers Standards WG
Telstra Corporation Limited
University of Canterbury New Zealand
University of Wollongong

Keeping standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand StandardTM

Electromagnetic compatibility (EMC)

**Part 2.8: Environment—Voltage dips
and short interruptions on public
electric power supply systems with
statistical measurement results**

First published as AS/NZS IEC/TR 61000.2.8:2009.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 9198 0

PREFACE

This Technical Report was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-034, Power Quality. This document is informative and of a more descriptive nature than a normative Standard.

The objective of this Technical Report is to provide the users of electromagnetic emissions Standards with a description of the electromagnetic disturbance phenomena that can be expected on public electricity supply systems, and their effects on electrical equipment when subjected to voltage dips and short interruptions. It includes some statistical measurement results as a general reference.

This Technical Report is identical with, and has been reproduced from IEC/TR 61000-2-8, Ed. 1.0 (2002), *Electromagnetic compatibility (EMC)—Part 2.8: Environment—Voltage dips and short interruptions on public electric power supply systems with statistical measurement results*.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example 'state of the art'.

As this Technical Report is reproduced from an International Technical Report, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) A full point should be substituted for a comma when referring to a decimal marker.

CONTENTS

	<i>Page</i>
Introduction	iv
1 Scope	1
2 Definitions	1
3 Description of voltage dips and short interruptions	2
3.1 Source of voltage dips	2
3.2 Voltage dip duration	3
3.3 Voltage dip magnitude	4
3.4 Short interruptions	5
3.5 Causes of voltage dips and short interruptions	6
3.6 Example of fault on MV network	6
4 Effects of voltage dips and short interruptions	8
4.1 General effects	8
4.2 Effects on some particular devices	9
5 Remedial measures	11
5.1 General considerations	11
5.2 Some examples of remedial measures	12
6 Measurement of voltage dips and short interruptions	13
6.1 Conventions adopted in the measurement of voltage dips and short interruptions	13
6.2 Measurement of voltage dips	16
6.3 Measurement of short interruptions	16
6.4 Classification of measurement results	17
6.5 Aggregation of measurement results	18
7 Available measurement results	18
7.1 UNIPEDDE statistics	18
7.2 Statistics from EPRI survey [9] [10]	22
7.3 Some statistics from individual countries	24
8 Discussion of results and general conclusions	32
8.1 Comparison of results	32
8.2 Conclusions from the results	33
8.3 General conclusions	33
8.4 Recommendations	35
Bibliography	37

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)
Definitions, terminology

Part 2: Environment

Description of the environment
Classification of the environment
Compatibility levels

Part 3: Limits

Emission limits
Immunity limits (in so far as they do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques
Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines
Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts, published either as International Standards, technical specifications or technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and completed by a second number identifying the subdivision (example: 61000-6-1).

Detailed information on the various types of disturbances that can be expected on public power supply systems can be found in IEC 61000-2-1.

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Electromagnetic compatibility (EMC)****Part 2.8: Environment—Voltage dips and short interruptions on public electric power supply systems with statistical measurement results****1 Scope**

This technical report describes the electromagnetic disturbance phenomena of voltage dips and short interruptions in terms of their sources, effects, remedial measures, methods of measurement, and measurement results (in so far as these are available). They are discussed primarily as phenomena observed on the networks of public electricity supply systems and having an effect on electrical equipment receiving its energy supply from those systems.

“Voltage sag” is an alternative name for the phenomenon voltage dip.

2 Definitions**2.1****voltage dip****voltage sag**

sudden reduction of the voltage at a particular point on an electricity supply system below a specified dip threshold followed by its recovery after a brief interval

NOTE 1 Typically a dip is associated with the occurrence and termination of a short circuit or other extreme current increase on the system or installations connected to it.

NOTE 2 A voltage dip is a two-dimensional electromagnetic disturbance, the level of which is determined by both voltage and time (duration).

2.2**short interruption**

sudden reduction of the voltage on all phases at a particular point on an electricity supply system below a specified interruption threshold followed by its restoration after a brief interval

NOTE Short interruptions are typically associated with switchgear operation related to the occurrence and termination of short circuits on the system or installations connected to it.

2.3**(voltage dip) reference voltage****<measurement of voltage dips and short interruptions>**

value specified as the base on which depth, thresholds and other values are expressed in per unit or percentage terms

NOTE The nominal or declared voltage of the supply system is frequently selected as the reference voltage.

2.4**voltage dip start threshold****<voltage dip measurement>**

r.m.s. value of the voltage on an electricity supply system specified for the purpose of defining the start of a voltage dip

NOTE Typically values between 0,85 and 0,95 of the reference voltage have been used for this threshold.