



ATIS-0600319.2020

**Equipment Assemblies –
Fire Propagation Risk Assessment
Criteria**

AMERICAN NATIONAL STANDARD FOR TELECOMMUNICATIONS



As a leading technology and solutions development organization, the Alliance for Telecommunications Industry Solutions (ATIS) brings together the top global ICT companies to advance the industry's most pressing business priorities. ATIS' nearly 200 member companies are currently working to address the All-IP transition, 5G, network functions virtualization, big data analytics, cloud services, device solutions, emergency services, M2M, cyber security, network evolution, quality of service, billing support, operations, and much more. These priorities follow a fast-track development lifecycle — from design and innovation through standards, specifications, requirements, business use cases, software toolkits, open source solutions, and interoperability testing.

ATIS is accredited by the American National Standards Institute (ANSI). The organization is the North American Organizational Partner for the 3rd Generation Partnership Project (3GPP), a founding Partner of the oneM2M global initiative, a member of the International Telecommunication Union (ITU), as well as a member of the Inter-American Telecommunication Commission (CITEL). For more information, visit www.atis.org.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires review by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by direct and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made towards their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Notice of Disclaimer & Limitation of Liability

The information provided in this document is directed solely to professionals who have the appropriate degree of experience to understand and interpret its contents in accordance with generally accepted engineering or other professional standards and applicable regulations. No recommendation as to products or vendors is made or should be implied.

NO REPRESENTATION OR WARRANTY IS MADE THAT THE INFORMATION IS TECHNICALLY ACCURATE OR SUFFICIENT OR CONFORMS TO ANY STATUTE, GOVERNMENTAL RULE OR REGULATION. AND FURTHER, NO REPRESENTATION OR WARRANTY IS MADE OF MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE OR AGAINST INFRINGEMENT OF INTELLECTUAL PROPERTY RIGHTS. ATIS SHALL NOT BE LIABLE, BEYOND THE AMOUNT OF ANY SUM RECEIVED IN PAYMENT BY ATIS FOR THIS DOCUMENT, AND IN NO EVENT SHALL ATIS BE LIABLE FOR LOST PROFITS OR OTHER INCIDENTAL OR CONSEQUENTIAL DAMAGES. ATIS EXPRESSLY ADVISES THAT ANY AND ALL USE OF OR RELIANCE UPON THE INFORMATION PROVIDED IN THIS DOCUMENT IS AT THE RISK OF THE USER.

NOTE - The user's attention is called to the possibility that compliance with this standard may require use of an invention covered by patent rights. By publication of this standard, no position is taken with respect to whether use of an invention covered by patent rights will be required, and if any such use is required no position is taken regarding the validity of this claim or any patent rights in connection therewith. Please refer to [<http://www.atis.org/legal/patentinfo.asp>] to determine if any statement has been filed by a patent holder indicating a willingness to grant a license either without compensation or on reasonable and non-discriminatory terms and conditions to applicants desiring to obtain a license.

ATIS-0600319.2020, *Equipment Assemblies – Fire Propagation Risk Assessment Criteria*

Is an American National Standard developed by the ATIS **Network Physical Protection (NPP)** Subcommittee under the **ATIS Sustainability in Telecom: Energy and Protection Committee (STEP)**.

Published by
Alliance for Telecommunications Industry Solutions
1200 G Street, NW, Suite 500
Washington, DC 20005

Copyright © 2020 by Alliance for Telecommunications Industry Solutions
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher. For information contact ATIS at 202.628.6380. ATIS is online at < <http://www.atis.org> >.

ATIS-0600319.2020

(Revision of ATIS-0600319.2014)

American National Standard for Telecommunications

Equipment Assemblies – Fire Propagation Risk Assessment Criteria

Alliance for Telecommunications Industry Solutions

Approved September 7, 2020

American National Standards Institute, Inc.

Abstract

The purpose of this standard is to provide fire propagation hazard risk assessment criteria for communications equipment assemblies used in telecommunications network facilities.

Foreword

The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

The Alliance for Telecommunications Industry Solutions (ATIS) serves the public through improved understanding between providers, customers, and manufacturers. The Sustainability in Telecom: Energy and Protection (STEP) Committee – formerly the Network Interface, Power, and Protection Committee (NIPP) – engages industry expertise to develop standards and technical reports for communications equipment and telecommunications environments in the areas of energy efficiency, environmental impacts, power, and protection. The work products of STEP enable vendors, operators, and their customers to deploy and operate reliable, environmentally sustainable, energy efficient communications technologies. STEP is committed to proactive engagement with national, regional, and international standards development organizations and forums that share its scope of work.

Originally, this standard established a fire testing method for characterizing the fire propagation hazard of telecommunications equipment assemblies. The evolution of the communications industry has expanded the scope of relevant equipment to encompass both historic telecommunications equipment and emerging communications equipment. The standard was based on the 1992 research findings of Underwriters Laboratories (UL) who was commissioned to study the burning phenomena of then-current representative communications products, and to develop a fire testing methodology considered representative of how communications equipment fires are initiated and propagated. Included in UL's study was the determination that summing the total load and heat release rate of a standardized array of circuit packs using an oxygen calorimeter could effectively characterize the fire propagation hazard associated with a communications system. The size and construction of equipment used for communications purposes has substantially changed since this standard was initially published.

This standard was revised to include fire propagation hazard risk assessment criteria that can be applied to products according to their physical characteristics and performance results of fire testing. The criteria are based in part on the findings of UL, which was commissioned in the year 2000 to study the potential for applications of the established fire test methodology according to equipment size and construction. Additionally, the risk assessment criteria are based on extensive equipment fire test performance experience gathered since the standard was originally published.

This standard contains an informative annex (Annex B), which is not considered a part of this standard.

ANSI guidelines specify two categories of requirements, mandatory and recommendation. The mandatory requirements are designated by the word *shall* and recommendations by the word *should*. Where both a mandatory requirement and a recommendation are specified for the same criterion, the recommendation represents a goal currently identifiable as having distinct compatibility or performance advantages.

Suggestions for improvement of this document are welcome. They should be sent to the Alliance for Telecommunications Industry Solutions – STEP, 1200 G Street NW, Suite 500, Washington, DC 20005.

At the time of consensus on this document, STEP, which was responsible for its development, had the following leadership:

- E. Gallo, STEP Chair (Ericsson)
- J. Fuller, STEP Vice Chair (AT&T)
- C. Forbes, STEP-STEP Vice Chair (NTS)
- C. Von Hagel, STEP-NIPP Chair (Intertek)

The Network Physical Protection (NPP) Subcommittee was responsible for the development of this document.

Table of Contents

1	SCOPE, PURPOSE, & APPLICATION	1
1.1	SCOPE.....	1
1.2	PURPOSE.....	1
1.3	APPLICATION.....	1
1.4	UNITS OF MEASURE.....	1
2	NORMATIVE REFERENCES	2
3	DEFINITIONS, ABBREVIATIONS, & ACRONYMS.....	2
3.1	DEFINITIONS.....	2
3.2	ACRONYMS & ABBREVIATIONS.....	4
4	FIRE PROPAGATION HAZARD OBJECTIVES.....	5
4.1	GENERAL.....	5
4.2	MATERIALS, COMPONENTS, CABLES, & WIRES.....	5
4.3	CONSTRUCTION ASSESSMENT CRITERIA.....	5
4.3.1	<i>Limited Power Source (LPS) & Passive Equipment.....</i>	<i>5</i>
4.3.2	<i>Physical Construction.....</i>	<i>6</i>
4.3.3	<i>Additional Physical Construction Test Exemption.....</i>	<i>6</i>
4.3.4	<i>Equipment or Compartments Containing Horizontally Oriented Printed Circuit.....</i>	<i>6</i>
4.4	EQUIPMENT SUBJECTED TO FIRE PROPAGATION TEST.....	7
5	FIRE PROPAGATION HAZARD TEST APPARATUS & CALIBRATION.....	7
5.1	TEST APPARATUS.....	7
5.1.1	<i>Test Building.....</i>	<i>7</i>
5.1.2	<i>Collection Hood & Exhaust Duct.....</i>	<i>7</i>
5.1.2.1	<i>Collection Hood.....</i>	<i>7</i>
5.1.2.2	<i>Exhaust Duct.....</i>	<i>8</i>
5.1.3	<i>Instrumentation.....</i>	<i>9</i>
5.1.3.1	<i>Flow Rate.....</i>	<i>9</i>
5.1.3.2	<i>Gas Sampling Equipment.....</i>	<i>9</i>
5.1.3.3	<i>Oxygen Analyzer.....</i>	<i>11</i>
5.1.3.4	<i>Data Acquisition.....</i>	<i>11</i>
5.1.3.5	<i>Video Recording Equipment.....</i>	<i>11</i>
5.1.3.6	<i>Line Burner.....</i>	<i>11</i>
5.1.4	<i>Methane Flow Control System.....</i>	<i>12</i>
5.1.4.1	<i>Automated Mass Flow Control System.....</i>	<i>12</i>
5.1.4.2	<i>Manual Mass Flow Control.....</i>	<i>12</i>
5.1.4.3	<i>Mechanical Gas Flow.....</i>	<i>13</i>
5.1.5	<i>Ignition Indicators – Shelf Level (SLIIM) & Frame Level (FLIIM).....</i>	<i>14</i>
5.1.5.1	<i>SLIIM Ignition Indicator Construction Details.....</i>	<i>14</i>
5.1.5.2	<i>FLIIM Ignition Indicator Construction Details.....</i>	<i>15</i>
5.2	CALIBRATION OF EQUIPMENT.....	17
5.2.1	<i>Heat Release Rate Calibration.....</i>	<i>17</i>
5.2.2	<i>Pretest Instrument Calibration.....</i>	<i>18</i>
5.2.3	<i>Line Burner Calibration.....</i>	<i>19</i>
5.2.3.1	<i>Calibration Using a Cone Calorimeter.....</i>	<i>19</i>
5.2.3.2	<i>Calibration of the Methane Mass Flow Controller.....</i>	<i>19</i>
5.2.4	<i>Qualification of Ignition Indicator Modules for Use as Ignition Indicators.....</i>	<i>19</i>
6	TEST SETUPS.....	20

6.1	FRAME LEVEL EQUIPMENT TESTS	20
6.2	SHELF LEVEL EQUIPMENT TESTS	21
7	TEST SPECIMENS	23
7.1	GENERAL	23
7.2	CONDITIONING	23
8	TEST PROCEDURE	23
8.1	PREPARATION	24
8.2	PROCEDURE	24
8.2.1	Subassembly Tests.....	24
8.2.2	Frame & Shelf Level Tests.....	24
8.2.3	Line Burner Placement.....	25
8.2.4	Airflow Characteristics.....	26
8.2.5	Chassis Design.....	26
8.2.6	Start of Test.....	26
8.2.7	Data Collection & Observations During Test.....	27
8.2.8	End of Test.....	28
9	CALCULATIONS.....	28
9.1	HEAT RELEASE RATE	28
10	PERFORMANCE CRITERIA	28
10.1	SHELF LEVEL	28
10.2	FRAME LEVEL.....	30
11	REPORT OF RISK ASSESSMENT.....	30
12	GUIDELINES FOR RE-ASSESSMENT/RETESTING	31
A	SLIIM MECHANICAL DRAWINGS	32
B	SAMPLE LINE BURNER PLACEMENT.....	45

Table of Figures

FIGURE 3.1: BAFFLE PLATE CONSTRUCTION.....	3
FIGURE 5.1: COLLECTION HOOD.....	8
FIGURE 5.2: GAS ANALYSIS SYSTEM.....	10
FIGURE 5.3: LINE BURNER.....	11
FIGURE 5.4: ELECTRONIC MASS FLOW CONTROL SYSTEM.....	12
FIGURE 5.5: SCALE LINE BURNER GRAPH.....	14
FIGURE 5.6: SLIIM DETAILS.....	16
FIGURE 5.7: CALIBRATION SAND BURNER.....	18
FIGURE 5.8: COLLECTION MODULE QUALIFICATION TEST.....	19
FIGURE 6.1: FRAME LEVEL FIRE TEST - FRONT VIEW.....	21
FIGURE 6.2: SHELF LEVEL FIRE TEST - FRONT VIEW.....	22
FIGURE 6.3: SHELF LEVEL FIRE TEST - SIDE VIEW.....	23
FIGURE A.1: FRAME CONSTRUCTION DETAILS.....	32
FIGURE A.2: FRAME CONSTRUCTION DETAILS.....	33
FIGURE A.3: FRAME CONSTRUCTION DETAILS.....	34

FIGURE A.4: FRAME CONSTRUCTION DETAILS	35
FIGURE A.5: FRAME CONSTRUCTION DETAILS	36
FIGURE A.6: FRAME CONSTRUCTION DETAILS	37
FIGURE A.7: FRAME CONSTRUCTION DETAILS	38
FIGURE A.8: FRAME CONSTRUCTION DETAILS	39
FIGURE A.9: FRAME CONSTRUCTION DETAILS	40
FIGURE A.10: FRAME CONSTRUCTION DETAILS	41
FIGURE A.11: FRAME CONSTRUCTION DETAILS	42
FIGURE A.12: FRAME CONSTRUCTION DETAILS	43
FIGURE A.13: FRAME CONSTRUCTION DETAILS	44

Table of Tables

TABLE 5.1: CALIBRATION OF HEAT RELEASE	17
TABLE 10.1: CONDITIONS IN WHICH FLAMES MAY EXIT THE CONFINES OF THE EQUIPMENT.....	29

American National Standard for Telecommunications –

Equipment Assemblies – Fire Propagation Risk Assessment Criteria

1 Scope, Purpose, & Application

1.1 Scope

The fire hazard risk assessment criteria defined in this standard are considered applicable to floor and cabinet-mounted equipment intended to be installed in environmentally controlled telecommunications network facilities. Examples of such locations are Central Offices, Controlled Environmental Vaults, and aboveground Huts.

This standard does not apply to auxiliary monitoring equipment such as oscilloscopes, personal computers, portable test equipment, etc., which are not integral to the equipment.

It also does not apply to network equipment that is designed to be solely used in an outside plant cabinet/enclosure, or equipment intended to be located solely at a customer premises location.

Smoke, contamination, or other byproducts of combustion data for assessing the fire hazard of equipment is considered outside the scope of this standard.

1.2 Purpose

The purpose of this American National Standard is to provide fire propagation hazard risk assessment criteria for communications equipment assemblies used in telecommunication network facilities.

1.3 Application

This standard is intended for equipment installed in telecommunications network facilities. The hazard assessment criteria provided by this standard may be used as one of the elements of a fire hazard risk assessment for a telecommunication facility and spaces with similar functions.

The results of standardized fire propagation testing or constructional evaluation may be used as elements of a fire propagation hazard analysis or risk assessment. Such an analysis should consider all of the factors pertinent to assessing the fire hazard within a telecommunications network facility and spaces with similar functions.

However, the results of evaluating communications equipment in compliance with this standard does not, unto itself, eliminate the potential risk of a fire hazard in a telecommunications network facility and in spaces with similar functions.

1.4 Units of Measure

Units of measure in this standard are shown in both SI and American Standard Units. Where a unit of measure is followed by a value enclosed in parentheses, the second value may be a mathematical approximation of the first value.