



ATIS-0600321.2020

**Electrical Protection For Network
Operator Type Equipment Positions**

AMERICAN NATIONAL STANDARD FOR TELECOMMUNICATIONS



As a leading technology and solutions development organization, the Alliance for Telecommunications Industry Solutions (ATIS) brings together the top global ICT companies to advance the industry's most pressing business priorities. ATIS' nearly 200 member companies are currently working to address the All-IP transition, 5G, network functions virtualization, big data analytics, cloud services, device solutions, emergency services, M2M, cyber security, network evolution, quality of service, billing support, operations, and much more. These priorities follow a fast-track development lifecycle — from design and innovation through standards, specifications, requirements, business use cases, software toolkits, open source solutions, and interoperability testing.

ATIS is accredited by the American National Standards Institute (ANSI). The organization is the North American Organizational Partner for the 3rd Generation Partnership Project (3GPP), a founding Partner of the oneM2M global initiative, a member of the International Telecommunication Union (ITU), as well as a member of the Inter-American Telecommunication Commission (CITEL). For more information, visit www.atis.org.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires review by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by direct and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made towards their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether it has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Notice of Disclaimer & Limitation of Liability

The information provided in this document is directed solely to professionals who have the appropriate degree of experience to understand and interpret its contents in accordance with generally accepted engineering or other professional standards and applicable regulations. No recommendation as to products or vendors is made or should be implied.

NO REPRESENTATION OR WARRANTY IS MADE THAT THE INFORMATION IS TECHNICALLY ACCURATE OR SUFFICIENT OR CONFORMS TO ANY STATUTE, GOVERNMENTAL RULE OR REGULATION. AND FURTHER, NO REPRESENTATION OR WARRANTY IS MADE OF MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE, OR AGAINST INFRINGEMENT OF INTELLECTUAL PROPERTY RIGHTS. ATIS SHALL NOT BE LIABLE, BEYOND THE AMOUNT OF ANY SUM RECEIVED IN PAYMENT BY ATIS FOR THIS DOCUMENT, AND IN NO EVENT SHALL ATIS BE LIABLE FOR LOST PROFITS OR OTHER INCIDENTAL OR CONSEQUENTIAL DAMAGES. ATIS EXPRESSLY ADVISES THAT ANY AND ALL USE OF OR RELIANCE UPON THE INFORMATION PROVIDED IN THIS DOCUMENT IS AT THE RISK OF THE USER.

NOTE - The user's attention is called to the possibility that compliance with this standard may require use of an invention covered by patent rights. By publication of this standard, no position is taken with respect to whether use of an invention covered by patent rights will be required, and if any such use is required no position is taken regarding the validity of this claim or any patent rights in connection therewith. Please refer to [<http://www.atis.org/legal/patentinfo.asp>] to determine if any statement has been filed by a patent holder indicating a willingness to grant a license either without compensation or on reasonable and non-discriminatory terms and conditions to applicants desiring to obtain a license.

ATIS-0600321.2020, *Electrical Protection For Network Operator-Type Equipment Positions*

Is an American National Standard developed by the ATIS **Network Electrical Protection (NEP)** Subcommittee under the **ATIS Sustainability in Telecom: Energy and Protection Committee (STEP)**.

Published by
Alliance for Telecommunications Industry Solutions
1200 G Street, N.W., Suite 500
Washington, DC 20005

Copyright © 2020 by Alliance for Telecommunications Industry Solutions
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher. For information contact ATIS at 202.628.6380. ATIS is online at < <http://www.atis.org> >.

American National Standard for Telecommunications

ELECTRICAL PROTECTION FOR NETWORK OPERATOR-TYPE EQUIPMENT POSITIONS

Alliance for Telecommunications Industry Solutions

Approved September 7, 2020

American National Standards Institute, Inc.

Abstract

This standard addresses electrical protection at new installations of network operator-type equipment positions, and at buildings housing such positions. Electrical disturbances may appear at network operator-type equipment positions arising either from Electrostatic Discharge (ESD), or from other sources that are internal or external to the building containing these positions, such as lightning or ac power disturbances. Measures are presented that are intended to help to control ESD in the network operator-type environment, and to provide electrical protection measures that are intended to minimize potential differences at the network operator-type equipment position.

Foreword

The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

The Alliance for Telecommunication Industry Solutions (ATIS) serves the public through improved understanding between providers, customers, and manufacturers. The Sustainability in Telecom: Energy and Protection (STEP) Committee – formerly the Network Interface, Power, and Protection Committee (NIPP) -- engages industry expertise to develop standards and technical reports for telecommunications equipment and environments in the areas of energy efficiency, environmental impacts, power and protection. The work products of STEP enable vendors, operators and their customers to deploy and operate reliable environmentally sustainable, energy efficient communications technologies. STEP is committed to proactive engagement with national, regional and international standards development organizations and forums that share its scope of work.

Electrical disturbances may appear at network operator-type equipment positions arising either from Electrostatic Discharge (ESD), or from other sources that are internal or external to the building containing these positions, such as lightning or ac power disturbances. Measures are presented that are intended to help to control ESD in the network operator-type environment. Additional measures are presented that are intended to help minimize the effects of lightning, surges from commercial ac power lines, and power switching operations, both at the facility (building) level and at the network operator-type equipment position. In no way is this standard intended, however, to guarantee against damage or injury that may result from ESD or other similar occurrences.

Although a large resource of information exists within the telecommunications industry regarding control of ESD, as well as the electrical protection, bonding, and grounding of telecommunications installations, there are presently no U.S. standards that are specific to the network operator-type equipment position environment. American National Standard National electrical code, NFPA 70® [Ref 10], as well as American National Standard for Telecommunications – Electrical protection applied to telecommunications network plant at entrances to customer structures or buildings, ATIS-0600318 [Ref 4] (formerly T1.318), contain basic safety and electrical protection requirements applicable to network operator-type equipment position installations. It is not intended that this standard supersede NFPA 70® [Ref 10] or ATIS-0600318 [Ref 4], but that it provide additional information to reduce electrical disturbances at network operator-type equipment installations.

The need for this standard was recognized by the Protection Engineers Group of the Alliance for Telecommunications Industry Solutions (ATIS) which submitted the initial project proposal and provided the seed documentation. Subject matter experts were gathered under the auspices of STEP to determine the necessary criteria to minimize electrical disturbances at network operator-type equipment positions.

There is one annex to this standard. Annex A is informative and is not considered a part of this standard.

Suggestions for improvement of this document are welcome. They should be sent to the Alliance for Telecommunications Industry Solutions, STEP, 1200 G Street NW, Suite 500, Washington, DC 20005.

At the time it approved this document, STEP, which is responsible for the development of this Standard, had the following members:

Ernie Gallo, STEP Chair (Ericsson)
John Fuller, STEP Vice-Chair and STEP NEP Vice-Chair (AT&T)
Dan Ashton, STEP NEP Chair (CenturyLink)

The NEP Subcommittee was responsible for the development of this document.

Table of Contents

1	INTRODUCTION	1
1.1	PURPOSE.....	1
1.2	SCOPE.....	1
2	NORMATIVE REFERENCES	2
2.1	NORMATIVE REFERENCES.....	2
2.2	INFORMATIVE REFERENCES.....	2
3	DEFINITIONS, ACRONYMS, & ABBREVIATIONS	3
3.1	DEFINITIONS.....	3
3.2	ACRONYMS & ABBREVIATIONS.....	4
4	MEASURES FOR CONTROLLING ELECTROSTATIC DISCHARGE	5
4.1	RELATIVE HUMIDITY CONTROL.....	6
4.2	FLOORING.....	6
4.3	CHAIRS.....	6
4.4	POSITION DESKTOPS (WORK SURFACES).....	6
4.5	ANTISTATIC SOLUTIONS.....	6
4.6	VIDEO DISPLAY TERMINALS.....	6
5	BUILDING ENTRANCE FACILITIES	7
5.1	SITING THE PEF, CEF, & PGP.....	7
5.2	COMMUNICATION CABLE PROTECTION.....	7
5.3	POWER ENTRANCE PROTECTION.....	7
5.4	INTERSYSTEM BONDING.....	7
5.5	BUILDINGS HAVING A RING GROUND SYSTEM.....	7
5.6	PUBLIC SAFETY ANSWERING POINT (PSAP) LOCATION.....	9
5.6.1	<i>Single Point Ground System</i>	9
5.6.2	<i>(P) – Surge Producers</i>	9
5.6.3	<i>(A) – Surge Absorbers</i>	9
5.6.4	<i>(N) – Non-Isolated Ground Plane (NIGP) Equipment Grounds</i>	10
5.6.5	<i>(I) – Isolated Ground Zone (IGZ) Equipment Grounds</i>	10
5.7	RADIO TOWER GROUNDING.....	10
6	EQUIPMENT ROOM BONDING	13
7	EQUIPOTENTIAL BONDING AT NETWORK OPERATOR-TYPE EQUIPMENT POSITIONS	13
7.1	POSITION BONDING TERMINALS (PBT).....	13
7.2	BONDING CONDUCTORS.....	13
7.3	BONDING TO POWER AT THE OPERATOR-TYPE EQUIPMENT POSITION.....	13
7.4	BONDING OF FURNITURE AND EQUIPMENT AT THE OPERATOR-TYPE EQUIPMENT POSITION.....	13
7.5	BONDING OF TELECOMMUNICATIONS CABLE METALLIC MEMBERS.....	14
7.6	BONDING OF NEARBY METALLIC OBJECTS.....	14
7.7	INTERPOSITIONAL BONDING.....	14
7.7.1	<i>Placement & Interconnection of the Bonding Grid</i>	14
7.7.2	<i>Bonding the Grid to Other Equipment in the Room</i>	14
8	VOLTAGE LIMITING OF COMMUNICATIONS CONDUCTORS AT NETWORK OPERATOR-TYPE EQUIPMENT POSITIONS	15
8.1	GENERIC CRITERIA FOR SECONDARY PROTECTORS.....	15
9	VOLTAGE LIMITING OF AC POWER CONDUCTORS AT NETWORK OPERATOR-TYPE EQUIPMENT POSITIONS	16
9.1	GENERIC CRITERIA FOR SURGE PROTECTIVE DEVICES (SPD).....	16
10	MULTI-PORT (MULTI-SERVICE) SURGE PROTECTIVE DEVICE	16

Table of Figures

FIGURE 5.1 – EXAMPLE OF ENTRANCE FACILITY BONDING, PBT, EXTERNAL SECONDARY PROTECTOR AND EXTERNAL SPD AT AC-POWERED NETWORK OPERATOR-TYPE EQUIPMENT POSITIONS	8
FIGURE 5.2: EXAMPLE OF BONDING IN A BUILDING WITH ADDITIONAL ENTRANCE FACILITIES	8
FIGURE 5.3 – EXAMPLE OF TOWER AND WAVE GUIDE GROUNDING ON BUILDING EXTERIOR	11
FIGURE 5.4 – SUPPLEMENTAL RADIO TOWER SITE GROUNDING	11
FIGURE 7.1 – EXAMPLE OF BONDING GRID AND INTERCONNECTION TO OTHER EQUIPMENT	5