

ANSI/AWWA **A100-20**  
(Revision of ANSI/AWWA A100-15)

AWWA Standard

# Water Wells

**Effective date: July 1, 2020.**

First edition approved by Board of Directors May 10, 1946.

15<sup>th</sup> edition approved Jan. 23, 2020.

Approved by American National Standards Institute Feb. 6, 2020.



American Water Works  
Association




## AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

## American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags and labels that the goods are produced in conformity with particular American National Standards.

**CAUTION NOTICE:** The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900, or emailing [info@ansi.org](mailto:info@ansi.org).



ISBN-13, print: 978-1-64717-001-9

ISBN-13, electronic: 978-1-61300-548-4

DOI: <http://dx.doi.org/10.12999/AWWA.A100.20>

---

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher.

Copyright © 2020 by American Water Works Association  
Printed in USA

## Committee Personnel

The AWWA Standards Committee on Wells, which reviewed and approved this standard, had the following personnel at the time of approval:

Ernest B. Williams, *Chair*

Gregory D. Buffington, *Vice-Chair*

### *General Interest Members*

D.W. Abbott, Oakland, Calif.

R.N. Davee, Wright-Pierce Engineers, Portsmouth, N.H.

F. Getchell, WSP USA, Upper Saddle River, N.J.

R.J. Kyle, KYLE Groundwater, Pomona, Calif.

D. Mason (*liaison, nonvoting*), Standards Council Liaison, Allstate Consultants, Lees Summit, Miss.

E. Meek (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.

L. Thomas, Stanley Consultants, Crystal Lake, Ill.

T. Watkins (*alternate*), GEOSCIENCE Support Services, Claremont, Calif.

D.E. Williams, GEOSCIENCE Support Services, Claremont, Calif.

E.B. Williams, Bennett & Williams Inc., Columbus, Ohio

S. Wojtkiewicz, Donohue & Associates, Pic Lake, Wis.

C.P. Wolf, Daniel B. Stephens & Associates, Albuquerque, N.M.

### *Producer Members*

G.D. Buffington, Layne Christensen Company, Aurora, Ill.

A.C. Fiedler, Johnson Screens, Colorado Springs, Colo.

K.S. Kaplan, Red Mint Sand and Gravel, Eau Claire, Wis.

T.D. Lynch, Roscoe Moss Company, Los Angeles, Calif.

K.B. McCillipuddy (*alternate*), Roscoe Moss Company, Los Angeles, Calif.

M.H. Mehmert, Aqseptence Group/Johnson Screens, Evergreen, Colo.

M.D. Richardson, J&S Well Service, Bellville, Tex.

K.M. Wartick (*alternate*), Layne Christensen Company, The Woodlands, Tex.

M.J. Williams, Peerless-Midwest, Inc., Mishawaka, Ind.

*User Members*

G.C. Burchard, Metropolitan Domestic Water Improvement District, Tucson, Ariz.

D. Corliss, Emerald Coast Utilities Authority, Pensacola, Fla.

T. Gee, San Jose Water Company, San Jose, Calif.

R. Parks, Independence Water Department, Independence, Mo.

R. Sorensen, California Water Service Company, Torrance, Calif.

# Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.	PAGE	SEC.	PAGE
<b>Foreword</b>		4.6	Filter Pack ..... 19
I	Introduction..... ix	4.7	Well Construction..... 20
I.A	Background..... ix	4.8	Well Development..... 24
I.B	History..... ix	4.9	Well Disinfection ..... 25
I.C	Acceptance ..... ix	4.10	Decommissioning of Test Holes, Partially Completed Wells, and Abandoned Wells ..... 26
II	Special Issues..... x	4.11	Permeation ..... 26
II.A	Screen Capacity..... x	<b>5 Verification</b>	
III	Use of This Standard ..... xi	5.1	Performance Testing ..... 27
III.A	Purchaser Options and Alternatives.... xi	5.2	Water Quality Testing..... 28
III.B	Modification to Standard ..... xii	5.3	Basis of Rejection ..... 29
IV	Major Revisions..... xii	<b>6 Delivery</b>	
V	Comments ..... xii	6.1	Affidavit of Compliance ..... 29
<b>Standard</b>		<b>Figures</b>	
<b>1 General</b>		D.1	Details of Cylindrical Plummets ..... 41
1.1	Scope..... 1	D.2	Suspension of the Plummets Using Drill Rig..... 43
1.2	Purpose ..... 1	D.3	Plumbness and Alignment Test Data Sheet..... 44
1.3	Application..... 1	D.4	Longitudinal Projections of Well and Constructed Pump Centerlines on North–South and East–West Vertical Planes ..... 45
<b>2 References</b> .....	1	D.5	Graphic Representation of Requirements for Plumbness in Sec. 4.7.9 ..... 46
<b>3 Definitions</b> .....	3	D.6	Graphic Representation of Requirements for Alignment in Sec. 4.7.9 ..... 46
<b>4 Requirements</b>			
4.1	General ..... 5		
4.2	Investigation of Geologic and Hydrologic Conditions and Groundwater Quality..... 5		
4.3	Material Requirements ..... 9		
4.4	Well Casing..... 13		
4.5	Well Screens ..... 16		

D.7	Relationship Between Misalignment Diameter From Figure D.6, Effective Diameter of the Well, and Inside Diameter of the Well.....	47
E.1	Rossum Sand Sampler .....	52
J.1	Type 1 .....	71
J.2	Type 2 .....	71
J.3	Type 3 .....	71
J.4	Type 4 .....	71
J.5	Type 5 .....	72
J.6	Type 6 .....	72
J.7	Type 7 .....	72
J.8	Type 8 .....	72
J.9	Type 9 .....	73
J.10	Type 10 .....	73
J.11	Type 11 .....	73
J.12	Type 12 .....	73

**Tables**

1	USGS Grain-Size Classification.....	8
2	Water-Well Casing Materials .....	10
3	Standard Well-Casing Sizes for Wells .....	14
4	Minimum Thickness for Steel Well Casing—Single Casing.....	15
5	Minimum Thickness for Two-Ply Steel Well Casing.....	15
6	Casing Joints .....	21
K.1	Collapse Strength of Steel Well Casing.....	79
K.2	Axial-Compressive Strength and Tensile Strength of Steel Well Casing.....	82
K.3	Collapse Strength and Axial-Compression Strength of Two-Ply Steel Well Casing.....	86
K.4	Hydraulic Collapse Pressure and Unit Weight of PVC Well Casing.....	88

**Appendixes**

A	Bibliography.....	31
B	Filter Pack Installation Methods .....	33
B.1	General .....	33
B.2	Poured From the Surface With Direct Circulation.....	33
B.3	Pumped Through Filter Pack Feed Line With Direct Circulation.....	34
B.4	Poured From the Surface With Reverse Circulation .....	34
B.5	Pumped Under Pressure From the Surface With Reverse Circulation.....	35
B.6	Crossover Method .....	35
C	Grouting and Sealing—Methods of Placement .....	37
C.1	Tremie Method .....	37
C.2	Positive Displacement—Exterior Method.....	37
C.3	Interior Method—Without Plug.....	38
C.4	Positive Placement, Interior Method—Drillable Plug .....	38
C.5	Placement Through Float Shoe Attached to Bottom of Casing... ..	39
D	Plumbness and Alignment—Procedure for Testing.....	41
D.1	Procedure for Testing.....	41
D.2	Apparatus Required for Plumbness and Alignment Tests.....	42
D.3	Procedure for Test Measurements ....	42
D.4	Determination of Drift (Horizontal Deviation).....	43
D.5	Items to Be Provided by Constructor.....	47
D.6	Plotting and Interpretation of Test Results.....	48
E	Well Development and Testing.....	51
E.1	Well Development Procedure.....	51

E.2	Measurement of Operating Parameters During Development .....	51	H.3	Wells in Creviced Formations.....	62
E.3	Development Records .....	52	H.4	Wells in Noncreviced Rock Formations.....	62
E.4	Methods of Measuring Operating Parameters During Testing .....	53	H.5	Multiple-Aquifer Wells .....	63
F	Water Sampling—Suggested Methods.....	57	H.6	Wells With Artesian Flow.....	63
F.1	General .....	57	H.7	Sealing Materials .....	64
F.2	A Well in a Consolidated Formation .....	57	I	Geophysical Borehole Logs.....	67
F.3	A Well in an Unconsolidated Formation .....	57	J	Types of Wells .....	69
G	Factors Influencing the Duration of Pumping Test .....	59	J.1	General .....	69
G.1	General .....	59	J.2	Basic Types of Wells.....	69
G.2	Local Experience .....	59	K	Collapse Strength of Well Casing.....	75
H	Decommissioning of Test Holes, Partially Completed Wells, and Abandoned Completed Wells....	61	K.1	General .....	75
H.1	General .....	61	K.2	Collapse Strength, or Hydraulic Collapse Pressure, Values.....	75
H.2	Wells in Unconsolidated Formations.....	61	K.3	Casing Tensile Strength Values.....	77
			K.4	Casing Axial Compressive Strength Values.....	78
			L	Screen Length and Entrance Velocities.....	89
			L.1	General .....	89
			L.2	Theoretical Relationships .....	89
			L.3	Design Examples .....	90

---



**American Water Works Association**

*Dedicated to the World's Most Important Resource®*

**ANSI/AWWA A100-20**  
(Revision of ANSI/AWWA A100-15)

**AWWA Standard**

---

## Water Wells

---

### SECTION 1: GENERAL

---

**Sec. 1.1 Scope**

This standard describes the minimum requirements for vertical water supply wells and is designed primarily for municipal and industrial applications.

**Sec. 1.2 Purpose**

The purpose of this standard is to provide the minimum requirements for water wells, including consideration of the influences of geologic and hydrologic conditions and water quality and well construction.

**Sec. 1.3 Application**

This standard can be referenced in specifications for constructing water wells and can be used as a guide for vertical water supply wells. The stipulations of this standard apply when this document has been referenced and only to water wells used in water supply service applications. Application of this standard is not limited by well depth.

---

### SECTION 2: REFERENCES

---

This standard references the following documents. In their latest editions, they form a part of this standard to the extent specified within the standard. In any case of conflict, the requirements of this standard shall prevail.