



**American Water Works  
Association**

*Dedicated to the World's Most Important Resource®*

**ANSI/AWWA B304-18**  
(Revision of ANSI/AWWA B304-13)

**AWWA Standard**

# Liquid Oxygen for Ozone Generation for Water, Wastewater, and Reclaimed Water Systems

Effective date: March 1, 2019.

First edition approved by AWWA Board of Directors June 12, 2005.

This edition approved Oct. 24, 2018.

Approved by American National Standards Institute Oct. 22, 2018.




## AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

## American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags and labels that the goods are produced in conformity with particular American National Standards.

**CAUTION NOTICE:** The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing [info@ansi.org](mailto:info@ansi.org).



ISBN-13, print: 978-1-62576-351-7

eISBN-13, electronic: 978-1-61300-504-0

DOI: <http://dx.doi.org/10.12999/AWWA.B304.18>

---

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher.

Copyright © 2019 by American Water Works Association  
Printed in USA

# Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.	PAGE	SEC.	PAGE
<b>Foreword</b>		1.3	Application..... 1
I	Introduction..... vii	<b>2</b>	<b>References</b> ..... 2
I.A	Background..... vii	<b>3</b>	<b>Definitions</b> ..... 2
I.B	History..... viii	<b>4</b>	<b>Requirements</b>
I.C	Purpose of Standard ..... viii	4.1	Materials ..... 3
I.D	Acceptance ..... viii	4.2	Physical Description ..... 3
II	Special Issues ..... ix	4.3	Chemical Requirements ..... 3
II.A	Storage and Handling Precautions... ix	4.4	Impurities..... 4
II.B	Gas Pretreatment..... xi	<b>5</b>	<b>Verification</b>
III	Use of This Standard ..... xi	5.1	Introduction..... 5
III.A	Purchaser Options and Alternatives ..... xi	5.2	Sampling..... 5
III.B	Modification to Standard ..... xii	5.3	Test Procedures..... 5
IV	Major Revisions..... xii	5.4	Notice of Nonconformance..... 8
V	Comments ..... xii	<b>6</b>	<b>Delivery</b>
<b>Standard</b>		6.1	Marking ..... 9
<b>1</b>	<b>General</b>	6.2	Packaging and Shipping ..... 9
1.1	Scope..... 1	6.3	Affidavit of Compliance and Certified Analysis ..... 10
1.2	Purpose ..... 1		



**American Water Works  
Association**

*Dedicated to the World's Most Important Resource®*

**ANSI/AWWA B304-18**  
(Revision of ANSI/AWWA B304-13)

**AWWA Standard**

---

# Liquid Oxygen for Ozone Generation for Water, Wastewater, and Reclaimed Water Systems

---

## SECTION 1: GENERAL

---

### **Sec. 1.1 Scope**

This standard describes liquid oxygen (LOX) for use in the treatment of potable water, wastewater, or reclaimed water.

### **Sec. 1.2 Purpose**

The purpose of this standard is to provide the minimum requirements for LOX intended for water, wastewater, and reclaimed water systems. This standard includes physical, chemical, packaging, shipping, sampling, and testing requirements.

### **Sec. 1.3 Application**

This standard can be referenced in purchase documents for LOX and can be used as a guide for sampling and testing the physical and chemical properties of LOX samples. The stipulations of this standard apply when this document has been referenced and then only for LOX used for generation of ozone for water supply applications and in the treatment of potable water, wastewater, or reclaimed water.